

European Commission

Final Report

Collection and analysis of data to support the Commission in reporting in line with Article 73(2)(a) of Directive 2010/75/EU on industrial emissions on the need to control emissions from the combustion of fuels in installations with a total rated thermal input below 50MW



AMEC Environment & Infrastructure UK Limited in partnership with the Regional Environmental Center for Central and Eastern Europe

September 2012

Copyright and Non-Disclosure Notice

The contents and layout of this report are subject to copyright owned by AMEC (©AMEC Environment & Infrastructure UK Limited 2012), save to the extent that copyright has been legally assigned by us to another party or is used by AMEC under licence. To the extent that we own the copyright in this report, it may not be copied or used without our prior written agreement for any purpose other than the purpose indicated in this report.

The methodology (if any) contained in this report is provided to you in confidence and must not be disclosed or copied to third parties without the prior written agreement of AMEC. Disclosure of that information may constitute an actionable breach of confidence or may otherwise prejudice our commercial interests. Any third party who obtains access to this report by any means will, in any event, be subject to the Third Party Disclaimer set out below.

Third-Party Disclaimer

Any disclosure of this report to a third party is subject to this disclaimer. The report was prepared by AMEC at the instruction of, and for use by, our client named on the front of the report. It does not in any way constitute advice to any third party who is able to access it by any means. AMEC excludes to the fullest extent lawfully permitted all liability whatsoever for any loss or damage howsoever arising from reliance on the contents of this report. We do not however exclude our liability (if any) for personal injury or death resulting from our negligence, for fraud or any other matter in relation to which we cannot legally exclude liability.

Document Revisions

| No. | Details | Date |
|-----|--|------------------|
| 1 | Draft final report outline | 4 November 2011 |
| 2 | Draft final report outline taking into account client comments | 24 November 2011 |
| 3 | Interim report | 16 January 2012 |
| 4 | Draft final report | 3 May 2012 |
| 5 | Final report | 3 July 2012 |
| 6 | Final report taking into account client comments 1227711 | 19 July 2012 |
| 7 | Final report taking into account Member State feedback | 6 September 2012 |

Report for

European Commission
DG Environment
Beaulieu laan 9
BU-9 06/188
BE-1049 Brussels
Belgium

Main Contributors

Tim Scarbrough
Ben Grebot
Jenny Hill
Richard Noden
Tom Jennings

Issued by

.....
Ben Grebot

Approved by

.....
Keith Lawton

**AMEC Environment & Infrastructure
UK Limited**

17 Angel Gate, City Road, London EC1V 2SH,
United Kingdom
Tel +44 (0) 207 843 1400
Fax +44 (0) 207 843 1410

Doc Reg No. 30310-02 12277i2

h:\projects\30310 ppaq ec ied reviews\c client\reports\final report\post
consultation to issue\30310 final report (combustion).doc

European Commission

Final Report

Collection and analysis of data to support the Commission in reporting in line with Article 73(2)(a) of Directive 2010/75/EU on industrial emissions on the need to control emissions from the combustion of fuels in installations with a total rated thermal input below 50MW

AMEC Environment & Infrastructure
UK Limited

September 2012



Certificate No. FS 13881



Certificate No. EMS 69090

In accordance with an environmentally responsible approach,
this document is printed on recycled paper produced from 100%
post-consumer waste, or on ECF (elemental chlorine free) paper

Executive Summary

Introduction

This report is one in a series resulting from the following study: “Collection and analysis of data to inform certain reviews required under Directive 2010/75/EU on industrial emissions (IED) and to inform Commission Guidance on the content of the baseline report under Article 22 of the IED”. This report describes the work undertaken to support the Commission in reporting in line with Article 73(2)(a) of the IED on **the need to control emissions from the combustion of fuels in installations with a total rated thermal input below 50MW**. The scope of the study has been focussed on assessing combustion plants of capacities between 1MW_{th} and 50MW_{th} .

This report and appendices has been updated (September 2012) to take into account feedback received from Member States as part of a consultation undertaken during July-August 2012. The consultation was aimed at correcting any errors in the interpretation of information provided by Member States during the study rather than inviting feedback on the findings of the analysis.

Data Gathering and Compilation

Within this study, data on combustion plants less than 50MW_{th} have been gathered directly from the Member States. This has included data on numbers, capacities, fuel consumption and emissions from the plants, as well as information on relevant national legislation (where applicable), combustion techniques used, abatement measures typically applied, and the degree to which the combustion plants may already be regulated under the IED as directly associated activities. Chapter 3 describes in full the data received in this study.

Where necessary (and possible), the newly gathered data have been supplemented with data from a range of existing sources and studies. From these data, an EU wide dataset of combustion plants of capacities between 1MW_{th} and 50MW_{th} has been developed through use of extrapolation and other assumptions in an attempt to compile a sufficiently complete dataset with which to assess possible control options. The dataset is separated into three capacity classes of rated thermal inputs 1-5 MW, 5-20 MW and 20-50 MW. The compilation of this EU dataset is described in Chapter 4.

Options for the Possible Control of Emissions from Combustion Installations Less than 50 MW

The following options for controlling emissions to air from combustion plants $1-50\text{MW}_{\text{th}}$ have been assessed:

1. Do nothing: no change to current regulation in each Member State. All other options have been compared against this baseline.

- 2a. “Full IED”: Inclusion of 1-50 MW_{th} installations as a new activity in Annex I of the IED. The option has been assessed assuming EU wide minimum ELVs would be in force set at the level of the most stringent national Member State legislation.
- 2b. As per 2a, but with EU ELVs set at level of the ELVs for 50-100 MW_{th} existing plants in the IED.
3. “Light IED”: Inclusion of 1-50 MW_{th} installations within the IED as a separate chapter but without a full permitting regime and no coverage under Chapter II. Installations would be subject to EU wide emission limit values for atmospheric emissions only as for option 2a.


An alternative (or additional) approach for smaller plants of rated thermal input 1 to 5 MW was also considered in which product standards could be developed setting emission limits for selected pollutants, targeted at new units only, similar to those currently being developed under the Ecodesign Directive. Section 5.1 describes each of the options in more detail.

Analysis of Options

For options 2a, 2b and 3, the potential costs have been estimated in terms of compliance costs – due to the need to reduce emissions by implementing abatement measures to meet the relevant ELVs – and administrative costs associated with a permitting or non-permitting regime. Potential SO₂, NO_x and dust emission reductions associated with the implementation of abatement measures have been estimated and monetised using CAFE damage cost functions to derive indicative benefits. The methodology for this analysis is described in Section 5.2.

The results of the analysis, described in Section 5.3, suggest that the estimated average benefits outweigh the average costs (compliance and administrative) for all options (2a, 2b and 3), with the highest cost-benefit ratios for the largest capacity class (20-50 MW_{th}), as shown below in Figure 1 which presents the results for option 2a. However, for some capacity classes the lower range of indicative benefits does not exceed the high end estimate of costs for each of these options. The sensitivity analyses undertaken do not affect the overall conclusion of average benefits exceeding average costs (see Section 5.3.2).


Figure 1 Option 2a costs and benefits across capacity classes



Option 2b is estimated to have 17% higher average costs and 8% higher average benefits compared to option 2a.

The administrative costs associated with a permitting regime are estimated to form an increasingly large component of total costs for the smaller capacity classes; for example, Figure 1 shows these to form around half of total costs for the 1 to 5 MW_{th} capacity class for option 2a. The assessment of option 3 in which a non-permitting approach is assumed to apply suggests that the large administrative cost element associated with permitting a large number of smaller installations could be significantly reduced. Figure 2 below shows the estimated costs for option 3. The benefits estimated for option 3 are the same as for option 2a.

Figure 2 Option 3 costs across capacity classes



In response to anticipated concerns over controlling emissions from a very large number of small sources in the 1 to 5 MW_{th} capacity class, an alternative (or additional) approach for these smaller plants could be the development of product standards that would apply to new plants in this category. However, further investigations would be required to determine how feasible – and suitable – such an approach would be taking into account some of the learning experiences from developments under the Ecodesign Directive.

Conclusions, uncertainties and limitations

The review of current national legislation in place in the Member States for regulating combustion plants 1 to 50MW_{th} has highlighted that many Member States already regulate these plants to some extent, and that many of the various pieces of legislation adopt similar approaches.

The results of the options assessment suggests that the estimated benefits of controlling atmospheric emissions from combustion plants of rated thermal input 1 to 50 MW exceed the estimated costs associated with compliance and administration. The administrative costs associated with the controlling of these plants under the IED or similar legislation are estimated to be higher than those that would be associated with a non-permitted approach. The analysis suggests that the highest benefits may come from controlling of atmospheric emissions from plants in the 5 to 20MW_{th} capacity class. The sensitivity analyses do not affect the conclusions, but their impacts on the cost-benefit ratios begin to establish some aspects of the uncertainties of the analysis. Full conclusions are described in Section 6.2.

A number of assumptions were made in extrapolating data to be considered representative of the EU27, which has led to a number of uncertainties and limitations in the underlying dataset which must be considered when assessing the results of the assessment of control options. The limitations and uncertainties are described in Section 6.2.

Considering the limitations of the data gathered, it is recommended that further work be undertaken to improve data capture on the combustion plants, in particular for the smallest capacity class 1 to 5 MW_{th}. Further work is also recommended to investigate the alternative product standard approach that could be applied for the smallest plants in more detail.

Contents

| | | |
|-----------|---|-----------|
| 1. | Project Understanding | 1 |
| 1.1 | This Report | 1 |
| 1.2 | Project Context | 1 |
| 1.2.1 | IED background | 1 |
| 1.2.2 | Combustion installations and plants less than 50 MW _{th} | 2 |
| 1.3 | Objectives | 4 |
| 1.4 | Structure of this Report | 4 |
| | | |
| 2. | Data Gathering | 7 |
| 2.1 | Overview | 7 |
| 2.2 | Approach to stakeholder consultation | 7 |
| 2.2.1 | Member States | 7 |
| 2.2.2 | Other consultees | 8 |
| 2.3 | Status of data collection | 8 |
| | | |
| 3. | Data received in this study | 11 |
| 3.1 | Overview of data | 11 |
| 3.1.1 | Note on combustion installations versus combustion plants | 11 |
| 3.1.2 | Numbers of plants | 11 |
| 3.1.3 | Capacity of plants | 14 |
| 3.1.4 | Fuel consumption of plants | 16 |
| 3.1.5 | Emissions of key pollutants | 19 |
| 3.1.6 | Typical combustion techniques used | 23 |
| 3.1.7 | Typical sectors in which the combustion plants operate | 25 |
| 3.1.8 | Degree to which the combustion installations below 50 MW _{th} may be already covered under IED | 27 |
| 3.2 | Overview of Current Regulation of Combustion Plants/Installations Less than 50 MW | 28 |
| 3.2.1 | EU legislation | 28 |
| 3.2.2 | Member States' national legislation | 30 |
| 3.2.3 | Gothenburg Protocol and revision | 33 |
| 3.3 | Overview of abatement measures typically used in combustion plants less than 50 MW_{th} | 34 |
| | | |
| 4. | Development of an EU dataset of combustion plants 1 to 50 MW_{th} | 37 |
| 4.1 | Overview | 37 |

| | | |
|-----------|--|-----------|
| 4.2 | Adjusting partially complete data gathered | 37 |
| 4.3 | Supplementing with existing data on 20 to 50 MW_{th} | 37 |
| 4.4 | Extrapolating to missing Member States and capacity classes | 40 |
| 4.4.1 | Number of plants | 40 |
| 4.4.2 | Capacity of plants | 40 |
| 4.4.3 | Fuel consumption of plants | 41 |
| 4.4.4 | SO ₂ , NO _x and dust emissions of plants | 42 |
| 4.5 | Overview of resulting EU27 dataset | 43 |
| 5. | Options for the Possible Control of Emissions from Combustion Installations Less than 50 MW | 45 |
| 5.1 | Overview of Options | 45 |
| 5.2 | Assessment methodology | 46 |
| 5.2.1 | Overview | 46 |
| 5.2.2 | Emission levels | 46 |
| 5.2.3 | EU wide limit values | 47 |
| 5.2.4 | Administrative costs | 49 |
| 5.2.5 | Compliance costs | 50 |
| 5.2.6 | Abatement matrix | 50 |
| 5.2.7 | Emission reductions and monetised benefits | 56 |
| 5.3 | Results | 56 |
| 5.3.1 | Main results | 56 |
| 5.3.2 | Sensitivity analysis | 63 |
| 6. | Conclusions | 67 |
| 6.1 | Overall conclusions | 67 |
| 6.2 | Uncertainties and Limitations | 68 |
| 6.3 | Further work | 69 |

| | |
|------------|---|
| Appendix A | Proforma |
| Appendix B | Summary of existing data on 20 to 50 MW _{th} combustion installations |
| Appendix C | Member State profiles |
| Appendix D | Industry responses to the proforma |
| Appendix E | Adjustments made to data provided by Member States |
| Appendix F | ELVs applied in Member State national legislation on combustion plants less than 50MW _{th} . |
| Appendix G | EU27 dataset on 1-50 MW _{th} combustion plants |

| | | |
|------------|---|------|
| Table 2.1 | Overview of data received from Member States in response to the proforma | 9 |
| Table 3.1 | Numbers of combustion plants of rated thermal input less than 50MW reported by Member States to this study, split by capacity class (Note 1) | 12 |
| Table 3.2 | Capacity of combustion plants of rated thermal input less than 50 MW _{th} reported by Member States to this study, split by capacity class | 14 |
| Table 3.3 | Fuel consumption reported by Member States from combustion plants < 50MW _{th} , split into five fuel types | 16 |
| Table 3.4 | Dust/PM ₁₀ , SO ₂ /SO _x and NO _x emissions of combustion plants of rated thermal input less than 50MW reported by Member States to this study, split by capacity class | 20 |
| Table 3.5 | Typical combustion techniques used by combustion plants of rated thermal input less than 50MW reported by Member States to this study, split by capacity class | 24 |
| Table 3.6 | Sectoral information received from Member States on combustion plants 1 to 50 MW _{th} | 25 |
| Table 3.7 | Proportion of reported combustion plants below 50MW _{th} that are considered to be covered by the IED as directly associated activities because the aggregated combustion capacity on site is at least 50 MW _{th} | 28 |
| Table 3.8 | Summary of EU level policies other than IPPC/IED with implications for small combustion plants | 29 |
| Table 3.9 | Summary of National Legislation regulating combustion plants less than 50MW _{th} | 31 |
| Table 3.10 | Summary of abatement techniques reported by Member States as being currently employed at 1-50MW _{th} combustion plants | 34 |
| Table 4.1 | Summary of which existing data sources on 20 to 50 MW _{th} combustion plants and installations have been utilised to supplement new data gathered from Member States | 38 |
| Table 4.2 | Assumed average capacity per plant | 40 |
| Table 4.3 | Ratio of numbers of plants at each capacity class | 40 |
| Table 4.4 | Ratio of capacity of plants at each capacity class | 41 |
| Table 4.5 | Average load factors for each capacity class | 41 |
| Table 4.6 | Specific flue gas volumes assumed in this study | 42 |
| Table 4.7 | Resulting EU27 dataset | 43 |
| Table 5.1 | General case emission levels (applied in the absence of Member State-specific ELVs) | 47 |
| Table 5.2 | EU wide ELVs applied in this study | 48 |
| Table 5.3 | Typical techniques assumed to be applied to meet the hypothetical EU-wide ELVs for those plants / sectors modelled as having emission levels exceeding the limits | 49 |
| Table 5.4 | Administrative cost data assumed in this study | 50 |
| Table 5.5 | Abatement matrix for 1-5MW _{th} plants | 53 |
| Table 5.6 | Abatement matrix for 5-20MW _{th} plants | 54 |
| Table 5.7 | Abatement matrix for 20-50MW _{th} plants | 55 |
| Table 5.8 | Summary of total additional costs and benefits (low and high) | 57 |
| Table 5.9 | Summary of total cost-benefit ratios | 58 |
| Table 5.10 | Abatement matrix for engine plants | 64 |
| Table 5.11 | Summary of sensitivity analyses on option 2a | 65 |
| Table B1 | Summary of existing data available on the <50MW _{th} sector, which is primarily drawn from Entec (2009) which focussed on 20-50MW _{th} installations | 1 |
| Table F.2 | General case emission levels (applied in the absence of Member State-specific ELVs) | 2 |
| Table G.3 | Number of combustion plants | 2 |
| Table G.4 | Capacity of combustion plants (GW _{th}) | 3 |
| Table G.5 | Total fuel consumption of combustion plants (PJ) | 4 |
| Table G.6 | Fuel consumption of 1-5MW _{th} combustion plants (PJ) | 5 |
| Table G.7 | Fuel consumption of 5-20MW _{th} combustion plants (PJ) | 6 |
| Table G.8 | Fuel consumption of 20-50MW _{th} combustion plants (PJ) | 7 |
| Table G.9 | Emissions (kt) of combustion plants | 8 |
| Figure 1 | Option 2a costs and benefits across capacity classes | vii |
| Figure 2 | Option 3 costs across capacity classes | viii |
| Figure 1.1 | Schematic of (A) boilers exhausting via (B) flues in a (C) common stack | 3 |
| Figure 3.1 | Split of reported fuel consumption of combustion plants 1 to 50MW _{th} by fuel type and capacity class | 19 |
| Figure 3.2 | Split of reported fuel consumption of large combustion plants across five fuel types and four capacity classes (source: AMEC, 2012) | 19 |
| Figure 3.3 | (a) SO ₂ (b) NO _x and (c) dust emissions data reported by Member States from small combustion plants, split by capacity class where available | 22 |
| Figure 3.4 | (a) SO ₂ (b) NO _x and (c) dust emissions data reported by Member States from 20-50MW _{th} plants, compared to estimates in AEA (2007) | 23 |
| Figure 5.1 | Option 2a costs across capacity classes | 60 |
| Figure 5.2 | Option 2a benefits across capacity classes | 60 |
| Figure 5.3 | Option 2a costs and benefits across capacity classes | 61 |
| Figure 5.4 | Option 3 costs across capacity classes | 62 |
| Figure 5.5 | Comparison of sensitivity analyses on option 2a | 66 |

1. Project Understanding

1.1 This Report

The purpose of this final report is to provide the Commission with the results of the data gathering and analysis for Task 2a of the following study: “Collection and analysis of data to inform certain reviews required under Directive 2010/75/EU on industrial emissions (IED) and to inform Commission Guidance on the content of the baseline report under Article 22 of the IED” (contract number 070307/2011/600007/FRA/C3).

The task covered in this report is Task 2a: **Gathering and analysing information to support the Commission in reporting in line with Article 73(2)(a) of the IED on the need to control emissions from the combustion of fuels in installations with a total rated thermal input below 50MW.**

This report describes the data gathered, how these data have been supplemented and the results of an options analysis for controlling emissions from these combustion installations.

This report and appendices has been updated (September 2012) to take into account feedback received from Member States as part of a consultation undertaken during July-August 2012. The consultation was aimed at correcting any errors in the interpretation of information provided by Member States during the study rather than inviting feedback on the findings of the analysis. In some instances, Member States have provided additional information of relevance to the study. Whilst it has not been possible to take this into account in the report this information has been summarised in the appendices.

1.2 Project Context

1.2.1 IED background

The Commission adopted its proposal for a Directive on industrial emissions (IED¹) on 21 December 2007, which consolidated seven existing Directives² related to industrial emissions into a single legislative instrument. The Commission’s accompanying impact assessment³ identified a number of problems related “(1) to shortcomings in

¹ “Proposal for a Directive of the European Parliament and of the Council on industrial emissions (integrated pollution prevention and control) (recast)”. Available from: <http://ec.europa.eu/environment/ipcc/proposal.htm>

² The titanium dioxide industry related directives (78/176/EEC, 82/883/EEC, 92/112/EEC), the IPPC Directive (96/61/EC, now 2008/1/EC), the Solvent Emission Directive (1999/13/EC), the Waste Incineration Directive (2000/76/EC) and the LCP Directive (2001/80/EC).

³ “Commission Staff Working Document: Accompanying document to the Proposal for a Directive of the European Parliament and of the Council on industrial emissions (integrated pollution prevention and control) (recast). Impact Assessment.” Available from: <http://ec.europa.eu/environment/ipcc/proposal.htm>

the current legislation that lead to unsatisfactory implementation and difficulties in Community enforcement actions and, thereby, to loss of health and environmental benefits and (2) to the complexity and lack of coherence of parts of the current legal framework". The impact assessment and proposed Directive were informed by a series of studies undertaken over several years as part of the review of the IPPC Directive.

Following the co-decision procedure, Directive 2010/75/EU on industrial emissions was formally adopted on 24 November 2010 and published in the Official Journal on 17 December 2010; and entered into force on 6 January 2011.

The Directive places a number of requirements on the European Commission to undertake additional actions over the coming years. The key requirements from the IED of relevance to this task on combustion plants below 50 MW_{th} are:

Recitals (28)

The combustion of fuel in installations with a total rated thermal input below 50 MW contributes significantly to emissions of pollutants into the air. With a view to meeting the objectives set out in the Thematic Strategy on Air Pollution, it is necessary for the Commission to review the need to establish the most suitable controls on emissions from such installations. That review should take into account the specificities of combustion plants used in healthcare facilities, in particular with regard to their exceptional use in the case of emergencies.

and

Article 73 Review

2. The Commission shall by 31 December 2012, review the need to control emissions from:


(a) the combustion of fuels in installations with a total rated thermal input below 50MW;

The Commission shall report the results of that review to the European Parliament and to the Council accompanied by a legislative proposal where appropriate.

1.2.2 Combustion installations and plants less than 50 MW_{th}

It is important to make clear the distinction between a combustion plant and a combustion installation before describing further the legislative requirements in place. A combustion *plant* is considered under the LCP Directive as being defined with the ‘common stack’ approach, i.e. that one chimney or stack (regardless of the number of flues contained therein) is one ‘plant’. Individual combustion *units* will discharge exhaust gases via *flues* that are contained within the chimney. The figure below represents these three levels of aggregation. A combustion *installation* (as defined in the IPPC Directive) is a site on which there may be multiple combustion plants (i.e. stacks) for one industrial complex.

Figure 1.1 Schematic of (A) boilers exhausting via (B) flues in a (C) common stack



Where:

A = Boilers with A1 and A2 each having a capacity of 40MW_{th} and A3 and A4 each a capacity of 210MW_{th}.

B = Flue in this example B1 having a capacity of 80MW_{th} and B2 a capacity of 420MW_{th}

C = Common Stack in this example being a capacity of 500MW_{th}

The IPPC Directive covers combustion installations with a rated thermal input exceeding 50 MW. It is possible for combustion plants (and units) with a thermal input of less than 50 MW to be covered by the IPPC Directive in situations where the aggregated capacity on site is more than 50 MW (see aggregation rule in chapeau provisions of Annex I to the IPPC Directive) or if they are ‘directly associated activities with a technical connection’ to other IPPC activities (see definition of “installation” under the IPPC Directive).

In its Proposal for a Directive on industrial emissions (December 2007), the Commission proposed to lower the thermal threshold to include combustion installations in the range of 20 to 50 MW_{th} aggregate total capacity (changing the scope of activity 1.1. of Annex I), while adding a ‘de minimis’ rules for exclusion of the following combustion units in the aggregation calculations:

- units with a rated thermal input below 3 MW; and
- units with a rated thermal input below 50 MW and operating no more than 350 hours per year.

During the co-decision negotiations on the IED Proposal a number of Member States raised concerns about the inclusion of combustion installations below 50 MW so the proposed change to Annex I was dropped in the IED and a clause requesting the Commission to “review the need to control emissions” from installations below 50 MW was entered under Article 73(2)(a) of the Directive.

The IED will regulate combustion installations and plants through the following provisions:

- Article 3 of the IED defines an installation as including “*any other directly associated activities on the same site which have a technical connection with the activities listed in those Annexes and which could have an effect on emissions and pollution*”.

- Article 10 of the IED sets the scope of coverage of **Chapter II** of the IED to the activities listed in Annex I. The relevant combustion activity is “*1.1. Combustion of fuels in installations with a total rated thermal input of 50 MW or more*”. I.e. the provisions of Chapter II of the IED (permitting, permit conditions, monitoring, BREFs, BAT) apply to combustion **installations** $\geq 50\text{MW}_{\text{th}}$.
- **Chapter III** (and the associated Annex V) of the IED has its scope set out in Article 28 which states that it applies to “*combustion plants, the total rated thermal input of which is equal to or greater than 50MW*”. Article 29 defines the aggregation rules (“common stack” and “de minimis” approaches), which are to be applied for the purpose of Chapter III.

In terms of combustion plants (“common stack” level) less than 50MW_{th} , Chapter II of the IED will regulate such plants in two instances:

- In the case of combustion installations with a total rated thermal input equal to or greater than 50MW_{th} containing combustion plants less than 50MW_{th}
- In the case of an installation operating an activity listed in Annex I, to which a combustion plant of less than 50MW_{th} operated on the same site is directly associated and has a technical connection (see definition of “installation” in IED article 3(3))

It should be noted that combustion plants (“common stack” level) of less than 50MW_{th} are not regulated under Chapter III, while combustion units of less than 50MW_{th} being part of a combustion plant of 50MW_{th} or more may be.

1.3 Objectives

The overall objective of Task 2a is to revisit this issue, building on data from existing studies and supplemented with additional data gathering, to provide support to the Commission in reviewing whether or not emissions from combustion installations below the current 50MW_{th} threshold need to be controlled at the EU level. As set out in Recital 28 of the IED, this should be seen in the context of achieving the objectives set out in the Thematic Strategy on Air Pollution. The scope of this task is not limited to installations between 20 and 50MW_{th} but it considers all (industrial) combustion installations between 1MW_{th} and 50MW_{th} . Some of the smallest plants in this capacity range are not industrial plants, and may be to some extent covered by the Ecodesign Directive 2009/125/EC e.g. if they comprise combustion units of individual capacity less than 0.4MW . In addition, Article 73(2)(a) does not restrict the scope of this review in terms of the instrument through which emissions from this activity may be controlled, i.e. options for control could include regulation through IED or other legislative instruments, as well as non-legislative instruments.

1.4 Structure of this Report

This report is structured as follows:

- Section 2 provides an overview of the process of data gathering for this study and the status of data collection.

- Section 3 presents the data received from Member States in this study on combustion plants <math><50 \text{ MW}_{\text{th}}</math>, as well as a summary of currently applicable legislation at an EU level and Member States' national regulations on combustion plants 1-50 MW_{th} .
- Section 4 describes how the data gathered were supplemented with existing data, and how these data were extrapolated to produce a sufficiently complete dataset on combustion plants 1 to 50 MW_{th} .
- Section 5 describes the methodology and results of the assessment of options for the possible control of emissions from combustion plants 1 to 50 MW_{th} .
- Section 6 presents the main conclusions of the study as well as key uncertainties and limitations.



2. Data Gathering

2.1 Overview

The study aimed to gather additional new data on combustion installations less than 50 MW_{th} to help the Commission decide whether there is a need to control emissions from this sector at an EU level. In recognition of the previous work undertaken on this subject in relation to 20-50 MW_{th} installations, some existing data on this topic already exists. In this study we have gathered new data from Member States on combustion plants between 1 MW_{th} and 50 MW_{th}, and where necessary supplemented with existing data that is already held and further extrapolated from the new and existing data in order to compile a sufficiently complete dataset with which to assess possible control options.

This chapter briefly summarises the process and status of collection of data from Member States in relation to combustion plants <50 MW_{th}:

- Numbers;
- Capacity;
- Fuel consumption;
- Emissions;
- Abatement measures; and
- Legislation currently in place.

Summaries of the data provided by Member States are included in Section 3, whilst Section 4 describes how these data were extrapolated to form a sufficiently representative dataset for the EU-27 for the purposes of assessing options for the control of emissions.

2.2 Approach to stakeholder consultation

2.2.1 Member States

All Member States have been consulted as part of this task. This consultation has involved the development of a data collection proforma for this task. A copy of the combustion data collection proforma is included in Appendix A. Follow-up communications by email and telephone were made with the Member State representatives by AMEC in collaboration with the Regional Environmental Center for Central and Eastern Europe (REC).

2.2.2 Other consultees

The consultation with stakeholders other than Member States focussed on gathering the views of a small selection of European-wide energy associations (Cogen Europe and Euro heat and power) and a combustion plant operator (Dalkia) which are most likely to be affected by the inclusion of plants <50 MW_{th}. A response was received from Dalkia and is included in Appendix D.

Further communications were undertaken with CEFIC, IMA Europe and the European Asphalt Pavement Association. However, it was considered that for the purposes of this study which relies on a representative set of data on combustion plants, it was expected that Member States would be in the best position to contribute to the study, and furthermore that not attempting to include separate data from industrial sectors' associations would help to ensure plants in the 1 to 50 MW_{th} category are not overlooked or double counted.

2.3 Status of data collection

A table summarising the Member States that have provided a response to the data collection proforma is included on the next page. This table also provides an overview of the data received from each Member State using a 'traffic light' system to assess the data of interest for each topic. In this table different colours are used to represent whether a Member State has provided full, partial or no information about a particular topic according to the following key.




| | |
|---|--|
|  | Fully completed section in proforma provided by Member State |
|  | Some data provided by Member State |
|  | No data provided by Member State |

Table 2.1 Overview of data received from Member States in response to the proforma

| Data requested | MW _{th} | AT | BE | BG | CY | CZ | DE | DK | EE | EL | ES | FI | FR | HU | IE | IT | LU | LT | LV | MT | NL | PL | PT | RO | SE | SI | SK | UK |
|---|------------------|--------|--------|-----|--------|--------|--------|-------|-------|--------|--------|--------|--------|-----|-----|-----|-----|-----|-----|-----|-------|-------|-------|--------|--------|--------|--------|--------|
| Numbers of combustion plants | 1-5 | Red | Yellow | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Green | Red | Green | Yellow | Green | Yellow | Green | Yellow |
| | 5-20 | Yellow | Yellow | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Green | Yellow | Green | Yellow | Green |
| | 20-50 | Green | Green | Red | Green | Green | Green | Red | Green | Red | Green | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Green | Red | Green | Yellow | Green | Green | Green |
| Numbers of combustion plants by sector | 1-5 | Red | Yellow | Red | Yellow | Green | Yellow | Red | Green | Red | Yellow | Green | Yellow | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| | 5-20 | Red | Yellow | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| | 20-50 | Green | Green | Red | Green | Green | Green | Red | Green | Red | Green | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Green | Red | Green | Yellow | Green | Green | Green |
| Capacity of plants | 1-5 | Red | Yellow | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| | 5-20 | Yellow | Yellow | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| | 20-50 | Green | Green | Red | Green | Green | Green | Red | Green | Red | Green | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Green | Red | Green | Yellow | Green | Green | Green |
| Fuel consumption split by fuel type | 1-5 | Red | Red | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| | 5-20 | Red | Red | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| | 20-50 | Red | Red | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| Emissions of key pollutants – quantities | 1-5 | Red | Yellow | Red | Yellow | Green | Yellow | Red | Green | Red | Yellow | Green | Yellow | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| | 5-20 | Red | Yellow | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| | 20-50 | Red | Yellow | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| Emissions of key pollutants: contribution to national total | | Red | Yellow | Red | Yellow | Green | Yellow | Red | Green | Red | Yellow | Green | Yellow | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| Typical combustion techniques in use | | Yellow | Yellow | Red | Green | Green | Green | Red | Green | Red | Yellow | Green | Yellow | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| Existing coverage as directly associated activities | | Red | Red | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Yellow | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| Legislative requirements | | Red | Yellow | Red | Green | Yellow | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Yellow | Green |
| Abatement measures | | Yellow | Yellow | Red | Green | Green | Red | Green | Red | Yellow | Green | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red | Red |

3. Data received in this study

This chapter summarises the quantitative data gathered from Member States in the scope of this study and additional descriptive and legislative aspects as requested using the proforma.

As a high level indication of the completeness and/or quality of the data, traffic light colour coding has again been employed for the quantitative data according to the following key for text colour:

| | |
|--|--|
| | The data appear complete, i.e. they represent the entire capacity class with no known omissions |
| | The data appear to be partially complete and not fully representative, e.g. they are known to exclude certain plants |
| | The data appear to be extremely limited, i.e. it is not possible to extrapolate complete data from them |

3.1 Overview of data

3.1.1 Note on combustion installations versus combustion plants

Section 1.2 in this report noted that Chapter II of the IED regulates combustion **installations** of 50 MW_{th} or more, with additional provisions in Chapter III for combustion **plants** of 50MW_{th} or more. As described in Section 1.2.2 an installation may comprise multiple plants (stacks), and each plant may comprise multiple combustion units (e.g. boilers). For the purposes of data collection for this study, data has been requested on combustion plants (at the stack level), in accordance with the scope of how large combustion plants are presently regulated in Chapter III of the IED. Nonetheless, some of the data returns from Member States have been indicated to be at the boiler level (Finland, Brussels region of Belgium and Sweden). It is unclear whether any of the data returns are at the installation level.

3.1.2 Numbers of plants

The data reported by Member States on the numbers of combustion plants less than 50 MW_{th} are summarised below in Table 3.1. Any Member States not listed in the table below have not reported numbers of combustion plants. As is noted in the final column of the table, in many cases the data provided by a Member State do not represent a complete picture of combustion plants in that Member State.

Table 3.1 Numbers of combustion plants of rated thermal input less than 50MW reported by Member States to this study, split by capacity class (Note 1)

| Member State | Total number of combustion plants | | | | Comments on completeness of the data by Member States and AMEC (denoted separately) |
|----------------|--|--------|---------|--------|---|
| | 1-5MW | 5-20MW | 20-50MW | Total | |
| Austria | - | 190 | 116 | 306 | <p>MS: These numbers are for steam boilers only. However, we suppose that most of the combustion plants with a rated thermal input > 5 MW are steam boilers.</p> <p>These numbers also exclude any combustion plant < 10 MW that is operated by gaseous fuel or gasoil.</p> <p>The number of 20-50MWth plants should be more or less the correct number. However, the submitted number of plants < 10 MW is very rough information. The number of combustion plants [5-20 MW] is with complete certainty much higher than 190 because of the non-registered plants 5-10 MW using gasoil or natural gas. There is no official view on estimated number of plants, but the correct number could be two or three times higher than 190.</p> |
| Belgium | 2,880 | 890 | 144 | 3,914 | <p>MS: The Wallonia figures are indicated to relate to emission trading only (although include plants less than 20MW_{th}) and exclude combustion installations of residential buildings and tertiary sector. The Brussels figures (1-5MW_{th} and 5-20MW_{th} only) are at a boiler level.</p> <p>AMEC: These numbers are the combined totals from three separate regions Wallonia, Brussels and Flanders.</p> |
| Cyprus | 172 | 36 | 3 | 211 | |
| Czech Republic | 4,068 | 748 | 175 | 4,991 | |
| Estonia | 537 | 174 | 29 | 740 | |
| Finland | 196 | 205 | 181 | 582 | <p>MS: These numbers are at the boiler level. Source of data is the Finnish national emission register VAHTI. In the VAHTI emissions register, data concerning larger units (20 - 50 MW) is more accurate than data concerning smaller units.</p> <p>AMEC: Estimates of the number of Finnish plants have been derived from the boiler level data using the unique (x,y,z) coordinates of boilers as recommended and supplied by the authorities. These estimates have not been confirmed: 136 1-5MW_{th} plants, 140 5-20MW_{th} plants, 133 20-50MW_{th} plants.</p> |
| France | 20,000 for category 2 to 20MW _{th} | | 1,500 | 21,500 | <p>MS: Estimates for range 2 to 20MW_{th}. Rough figures for 20 to 50 MW_{th}. Only rough estimates were provided from 2MW – 50MW. Figure of 20,000 is a total for capacity range 2-20MW_{th}.</p> <p>AMEC: The estimates provided by the French authorities appear to be quite high. This point is discussed further in section 4.</p> |
| Germany | 6,400 | 118 | 658 | 7,176 | <p>MS: The figure for capacity class 5-20MW_{th} is for solid biomass fired plant only and excludes any plants not fired with this fuel.</p> <p>The figure for capacity class 1-5MW_{th} includes (a) estimated 400 solid biomass fired plant, and (b) estimated 6000 biogas fired engine plants some of which may fall below 1MW_{th}. Plants fired by fuels other than solid biomass and biogas are excluded from this estimate.</p> |
| Netherlands | 6,995 | 2,250 | 110 | 9,355 | The figures presented are a rough estimate. |
| Poland | - | 2 | 241 | 243 | AMEC: Submitted data for 5-20MW _{th} class are considered incomplete and have been removed in subsequent analysis. |

| Member State | Total number of combustion plants | | | | Comments on completeness of the data by Member States and AMEC (denoted separately) |
|----------------------|-----------------------------------|--------|--------------|---------------|--|
| | 1-5MW | 5-20MW | 20-50MW | Total | |
| Portugal | - | - | 34 | 34 | |
| Romania | 790 | 370 | 146 | 1306 | |
| Slovakia | 2,023 | 600 | 93 | 2,716 | |
| Slovenia | 222 | 119 | 18 | 359 | MS: The numbers in class 1-5MW _{th} are only boilers using solid fuel. The numbers in class 5-20MW _{th} exclude boilers using natural gas below 10 MW. |
| Spain | - | - | 1,130 | 1,130 | AMEC: the figures provided appear high and may be an overestimate. |
| Sweden | 4 | 173 | 105 | 282 | MS: These figures are at a boiler level. They exclude plants from the inventory with missing capacity category. Data source is the inventory for the NO _x tax. AMEC: The figures for the 1 to 5MW _{th} capacity class are considered incomplete due to the limitations of the underlying data source. |
| United Kingdom | >38 | >35 | 413 | 486 | MS: The numbers in classes 1-5MW _{th} and 5-20MW _{th} are for Northern Ireland only. |
| Subtotal (17) | 50,235 | | 5,096 | 55,331 | |

Note 1: Boxes marked with “-“ indicate no data provided.

From the data gathered it appears that robust data on numbers of combustion plants less than 50 MW_{th} (in particular below 20 MW_{th}) are not widely held by Member States. Some Member States appear to have provided seemingly robust figures on these (Cyprus, Czech Republic, Estonia, Finland, Romania and Slovakia), but for many Member States the estimates are either only approximate (Netherlands, France) or exclude certain categories of plants or even whole regions (Austria, Germany, Poland, Slovenia, Spain and United Kingdom). Furthermore, no data have been gathered for several Member States: Bulgaria, Denmark, Greece, Hungary, Ireland, Italy, Latvia, Lithuania, Luxembourg and Malta.

As such, the numbers of plants presented in the table above are considered to be an underestimate for the Member States presented, as well as being an underestimate for the EU.

It is also important to note two points in particular for this table: (a) that the estimated figures reported by France make up 40% of the total reported by the Member States which appears high; and (b) some Member States (Belgium [Brussels region], Finland, Sweden) are known to have reported at the boiler level, which can lead to a slight overestimate in the number of plants/installations.

The above estimates of numbers of plants rated 1 to 50 MW_{th} are very much higher than the numbers of large combustion plants currently regulated in the EU: the number of LCPs of capacity 50-100 MW_{th} is reported to be 987, and the total number of LCPs is reported to be 3,243.⁴

3.1.3 Capacity of plants

The data reported by Member States on the capacity of combustion plants 1 to 50 MW_{th} are summarised below in Table 3.2. Any Member States not listed in the table have not reported capacity of combustion plants. The percentage share of total capacity among the three capacity classes has been included for those Member States whose data have been highlighted in green (i.e. whose data appear to be complete).

Table 3.2 Capacity of combustion plants of rated thermal input less than 50 MW_{th} reported by Member States to this study, split by capacity class

| Member State | Total capacity of combustion plants (GW _{th}) | | | | Comments on completeness of the data by Member States and AMEC (denoted separately) |
|----------------|---|-----------|-----------|-------|---|
| | 1-5MW | 5-20MW | 20-50MW | Total | |
| Austria | - | 2.2 | 3.7 | 5.9 | <p>MS: These numbers are for steam boilers only, i.e. they exclude combustion plants that exclude steam boilers. However, we suppose that most of the combustion plants with a rated thermal input > 5 MW are steam boilers.</p> <p>MS: The Wallonia figures are indicated to relate to emission trading only (although include plants less than 20MW_{th}) and exclude combustion installations of residential buildings and tertiary sector. The Brussels figures (1-5MW_{th} and 5-20MW_{th} only) are at a boiler level.</p> <p>AMEC: These numbers are the combined totals from three separate regions Wallonia, Brussels and Flanders. Although the Wallonia figures are indicated to relate to emission trading only they include plants less than 20MW_{th}.</p> <p>MS: Source of data is the Finnish national emission register VAHTI. In this register, data concerning larger units (20 - 50 MW) is more accurate than data concerning smaller units.</p> |
| Belgium | 6.5 | 8.5 | 4.6 | 19.7 | |
| Cyprus | 0.4 (50%) | 0.3 (35%) | 0.1 (15%) | 0.7 | |
| Czech republic | 8.5 (41%) | 7.2 (34%) | 5.2 (25%) | 20.9 | |
| Estonia | 1.2 (30%) | 1.8 (45%) | 1.0 (25%) | 4.0 | |
| Finland | 0.6 (6%) | 2.1 (23%) | 6.4 (71%) | 9.1 | |

⁴ AMEC (2011) Analysis and summary of the Member State's emission inventories 2007-2009 and related information under the LCP Directive. Final report to the European Commission.

| Member State | Total capacity of combustion plants (GW _{th}) | | | | Comments on completeness of the data by Member States and AMEC (denoted separately) |
|----------------------|---|-----------|------------|------------|---|
| | 1-5MW | 5-20MW | 20-50MW | Total | |
| France | 400 for 2 to 20MW _{th} class | | 75 | 475 | MS: No data available on plants 1-2MW _{th} . These figures are maximum capacities, assuming that plants in the capacity class ranges are at the upper end of the scale. AMEC: Based on the capacity classes, AMEC calculates that the capacities of the French plants will lie within the range of 70 to 475 GW _{th} and are unlikely to be close to the total maximum capacity (475 GW _{th}) provided by the French authorities. A mid-range estimate of around 270 GW _{th} may be more realistic |
| Germany | 2.3 | - | 22.5 | 25.8 | MS: No capacity data are available for the solid biomass plants reported in the numbers table. Figures for 20-50MW _{th} plants are derived from ETS data. The figure for 1-5MW _{th} plants covers approximately 6000 biogas engine plants which are mostly less than 3MW _{th} AMEC: The figure for 1-5MW _{th} plants covers approximately 6000 biogas engine plants which are mostly less than 3MW _{th} and much of which must fall below the 1MW _{th} threshold since the average plant capacity of the reported data is <1MW _{th} . |
| Netherlands | 21 (44%) | 23 (48%) | 3.7 (8%) | 47.7 | MS: The figures presented are a rough estimate. |
| Poland | - | 0.01 | 8.1 | 8.1 | AMEC: Submitted data for 5-20MW _{th} class are considered incomplete and have been removed in subsequent analysis. |
| Portugal | - | - | 1.2 | 1.2 | |
| Romania | 1.6 (22%) | 2.7 (37%) | 3.1 (42%) | 7.4 | |
| Slovakia | 4.3 (35%) | 5.4 (43%) | 2.8 (22%) | 12.5 | |
| Slovenia | 0.5 | 1.3 | 0.5 | 2.3 | MS: The numbers in class 1-5MW _{th} are only boilers using solid fuel. The numbers in class 5-20MW _{th} exclude boilers using natural gas below 10 MW. |
| Sweden | 0.02 | 1.8 | 3.0 | 4.8 | MS: These figures exclude plants from the inventory with missing capacity category. AMEC: The figures for the 1 to 5MW _{th} capacity class are considered incomplete due to the limitations of the underlying data source. |
| United Kingdom | 0.1 | 0.4 | 13.3 | 13.8 | MS: The capacities in classes 1-5MW _{th} and 5-20MW _{th} are for Northern Ireland only. The capacity for 20-50MW _{th} is estimated to lie in a range from 11.3GW _{th} to 15.4GW _{th} . |
| Subtotal (16) | 503 (combined 1 to 20MW_{th}) | | 155 | 659 | |

The figures reported by France are estimates based on assuming the average capacity of a plant in a capacity class is the maximum capacity of that class. This assumption is unlikely to be correct, and more realistic figures are calculated by AMEC and noted in the table above.

As such, the total capacity of plants presented in the table above are considered to be on the one hand an underestimate due to those plants excluded in some Member State reports and the Member States that have not reported, and on the other hand to be an overestimate for the Member States presented, due to the French estimates (which, as reported, comprise over 70% of the reported capacity).

For comparison with the above estimates of capacities of plants rated 1 to 50 MW_{th}, the total capacity of large combustion plants 50-100 MW_{th} is reported to be 74 GW_{th}, and the total capacity of all LCPs (> 50 MW) is reported to be 1,354 GW_{th} in 2009.⁵

3.1.4 Fuel consumption of plants

The data reported by Member States on the fuel consumption of combustion plants between 1 and 50MW_{th} are summarised below in Table 3.3. Any Member States not listed in the table below have not reported these data.

Table 3.3 Fuel consumption reported by Member States from combustion plants < 50MW_{th}, split into five fuel types

| Member State | Fuel type | Fuel consumption (PJ) | | | | % of MS total | Notes |
|----------------|-------------|-----------------------|--------|---------|-------|---------------|---|
| | | 1-5MW | 5-20MW | 20-50MW | Total | | |
| Cyprus | Biomass | 0.03 | | | 0.03 | 1% | Cyprus provided combined data for a 1-20 MW band |
| | Liquid | 1.5 | | 1.2 | 2.7 | 91% | Includes Gas oil & fuel oil, Cyprus provided combined data for a 1-20 MW band |
| | Other gases | 0.2 | | | 0.2 | 8% | Cyprus provided combined data for a 1-20 MW band |
| Czech republic | Biomass | 1.8 | 1.8 | 2.9 | 6.5 | 2% | |
| | Other solid | 1.8 | 1.1 | 6.0 | 8.9 | 3% | Mostly brown coal |
| | Liquid | 0.7 | 0.4 | 2.0 | 3.2 | 1% | Mostly heating oil |
| | Natural Gas | 74.6 | 214.0 | 18.7 | 307 | 94% | |
| Estonia | Biomass | 2.1 | 2.5 | 2.8 | 7.3 | 30% | firewood & wood waste |
| | Other solid | 0.1 | 0.1 | 0.3 | 0.5 | 2% | coal, peat & oil shale |
| | Liquid | 1.2 | 1.4 | 0.7 | 3.3 | 13% | light heating oil, shale oil, waste oil & diesel fuel |
| | Natural gas | 2.4 | 4.5 | 2.1 | 9.0 | 37% | |
| | Other gases | 0.2 | 0.1 | 4.2 | 4.5 | 18% | pyrolysis process gases & biogas |

⁵ AMEC (2012) Analysis and summary of the Member State's emission inventories 2007-2009 and related information under the LCP Directive. Final report to the European Commission.


| Member State | Fuel type | Fuel consumption (PJ) | | | | % of MS total | Notes |
|--------------|-------------|-----------------------|--------|---------|-------|---------------|--|
| | | 1-5MW | 5-20MW | 20-50MW | Total | | |
| Finland | Biomass | 4 | 4 | 9 | 17 | 28% | Typically wood-based |
| | Other solid | 1 | 1 | 8 | 11 | 17% | Includes: Peat, some coal in larger units |
| | Liquid | 1 | 5 | 10 | 17 | 27% | Includes: Heavy oil & some light oil |
| | Natural gas | 2 | 4 | 9 | 15 | 24% | |
| | Other gases | 0.5 | 1 | 1 | 2 | 3% | Includes: biogas, waste gas, liquid gas |
| France | Biomass | - | - | - | - | 15% | |
| | Other solid | - | - | - | - | 2% | Other solid fuel is coal |
| | Liquid | - | - | - | - | 25% | Liquid fuel is LPG, HFO and domestic heating fuel oil |
| | Natural gas | - | - | - | - | 56% | |
| Germany | Biomass | | | 10 | 174 | | Other solid fuels are coal and lignite. Figures for total 1-50MW _{th} plants are derived from the national emission inventory. Figures for 20-50MW _{th} plants are derived from ETS data. The figure for 1-5MW _{th} plants covers approximately 6000 biogas engine plants which are mostly less than 3MW _{th} and so some of this may be below the 1MW _{th} threshold. The data presented in earlier tables on solid biomass plants are not represented in this table due to lack of fuel consumption data on the solid biomass plants. |
| | Other solid | | | 13 | 52 | | |
| | Liquid | | | 6 | 83 | | |
| | Natural gas | | | 117 | 426 | | |
| | Other gases | 130 | | 5 | 135 | | |
| Netherlands | Biomass | 1 | | | 1 | 0.3% | All figures presented are a rough estimate. |
| | Natural gas | 130 | 160 | 40 | 330 | 99% | |
| | Other fuels | 1 | | | 1 | 0.3% | |
| Poland | Biomass | | | 0.2 | 0.2 | 0.4% | Biomass includes biomass from waste (code: 030105). Other solid includes black coal and sub-bituminous coal. Liquid includes diesel, furnace oil, HFO and light oil. Natural gas includes Natural gas with high methane concentration & Nitrogen-rich natural gas. Other gases includes coke oven gas, mine gas and biogas. <i>AMEC: Submitted data for 5-20MW_{th} class are considered incomplete and have been removed in subsequent analysis.</i> |
| | Other solid | | 0.01 | 44 | 44 | 77.8% | |
| | Liquid | | 1.3 | 0.2 | 1.5 | 2.6% | |
| | Natural gas | | | 10.5 | 10.5 | 18.6% | |
| | Other gases | | | 0.3 | 0.3 | 0.6% | |
| Portugal | Biomass | - | - | 4.4 | 4.4 | 29% | Liquid fuels include diesel, fuel oil, and LPG |
| | Liquid | - | - | 4.0 | 4.0 | 27% | |
| | Natural gas | - | - | 6.7 | 6.7 | 44% | |
| Slovakia | Biomass | 0.7 | 1.7 | 3.1 | 5.4 | 13% | Includes wood and woodchips & other vegetal matter |
| | Other solid | 0.5 | 1.0 | 1.9 | 3.4 | 8% | Includes: anthracite, Polish black coal CZ black coal, Czech brown coal, Slovak brown coal SK, lignite, coke, other solid fuels, waste from agriculture, horticulture, |

| Member State | Fuel type | Fuel consumption (PJ) | | | | % of MS total | Notes |
|----------------|-------------|-----------------------|--------|---------|-------|---------------|--|
| | | 1-5MW | 5-20MW | 20-50MW | Total | | |
| | Liquid | 0.006 | 0.024 | 0.004 | 0.03 | 0.1% | forestry, hunting and fishing, aquaculture production, food production and processing, waste from wood processing and manufacturing of paper, paperboard, pulp, sawn timber and furniture and waste from medical or veterinary care or related research Include: heavy fuel oil, medium fuel oil, light fuel oil, other liquid fuels, diesel and propane-butane |
| | Natural gas | 11.2 | 14.9 | 7.5 | 33.6 | 79% | |
| | Other gases | 0.17 | 0.01 | 0.04 | 0.2 | 0.5% | |
| Sweden | Biomass | 0.5 | 28.9 | 28.0 | 57.3 | 57% | Other solid fuels include coal, peat and waste. Liquid fuel is fuel oil. <i>AMEC: Fuel data have been estimated from the MWh energy data supplied by the authorities, together with the supplied percentage fuel splits.</i> |
| | Other solid | | 8.9 | 17.7 | 26.6 | 24% | |
| | Liquid | | 0.5 | 4.1 | 4.6 | 5% | |
| | Natural gas | | 2.1 | 9.6 | 11.7 | 12% | |
| United Kingdom | Biomass | | | 2 | 2 | 0.1% | Data are only applicable to Northern Ireland. No data for England, Scotland or Wales. Liquid fuels include heavy fuel oil and gas oil |
| | Other solid | | | 0.1 | 0.1 | 0.01% | |
| | Liquid | | 0.1 | 1 | 1 | 0.1% | |
| | Natural gas | 3 | 85 | 1,695 | 1,783 | 91% | |
| | Other gases | | 1 | 174 | 184 | 9% | |

The data in the above table that are highlighted in green are also summarised in Figure 3.1. This figure shows that the dominant fuel for reported small combustion plants is natural gas (92% for plants 1-5MW_{th}, 87% for plants 5-20MW_{th} and 54% for plants 20-50MW_{th}). With increasing capacity, usage of solid fuels (biomass and other solid fuels) increases. Biomass makes up less than 15% of fuels in all capacity classes. Liquid fuels make up less than 7% of fuels in all capacity classes. Other gaseous fuels make up less than 3% in all capacity classes.

In some countries the main fuel used differs from the overall EU average. For example, in Poland, the use of other solid fuels dominates, in Sweden biomass is the primary fuel type and Cyprus mainly uses liquid fuels.


Figure 3.1 Split of reported fuel consumption of combustion plants 1 to 50MW_{th} by fuel type and capacity class



Note: fuel consumption data reported by CY for combined capacity classes was split equally among the classes for the purposes of producing this figure.

By way of comparison against large combustion plants, fuel consumption of currently regulated >50MW plants are presented below in Figure 3.2.

Figure 3.2 Split of reported fuel consumption of large combustion plants across five fuel types and four capacity classes (source: AMEC, 2012)



Note: this figure represents the total from the Member States whose data are presented in Figure 3.1 (i.e. CY, CZ, EE, FI, DE, NL, PL, PT, SK, SE).

3.1.5 Emissions of key pollutants

The data reported by Member States on the emissions of combustion plants between 1 and 50MW_{th} are summarised below in Table 3.4, including data provided by Member States on the percentage of total Member State emissions

that the emissions from 1 to 50 MW_{th} combustion plants make up. Any Member States not listed in the table below have not reported these data to this study. For those Member States that did not provide an estimate of the proportion of national emissions, national totals have been retrieved from CLRTAP submissions and included in *italics*.

No information has been gathered to identify whether the emissions data submitted by Member States have mainly been calculated or monitored. Whilst no Member States have declared the method by which the emissions data have been derived, some Member States have indicated that emissions have been extracted from national databases, e.g. Estonia, whilst for others the data are considered a reliable source (e.g. Swedish NO_x emissions are from the Swedish NO_x tax database).

Table 3.4 Dust/PM₁₀, SO₂/SO_x and NO_x emissions of combustion plants of rated thermal input less than 50MW reported by Member States to this study, split by capacity class


| Member State | Pollutant | Emissions from combustion plants (t) | | | | | Notes |
|----------------|------------------------------------|--------------------------------------|--------------|--------------|--------------|---|--|
| | | 1-5MW | 5-20MW | 20-50MW | 1-50MW | % of MS total emissions | |
| Belgium | Dust | - | - | - | 487 | 3% | The figures presented are for the Wallonia region only. The boilers around 1MW _{th} of the tertiary sector were not taken into account (hospitals, schools). The boilers of residential buildings above 1MW _{th} are not taken into account. Total emissions of heavy metals were also reported. |
| | PM ₁₀ | - | - | - | 393 | 5% | |
| | SO ₂ (SO _x) | - | - | - | 1,726 | 8% | |
| | NO _x | - | - | - | 5,176 | 6% | |
| Cyprus | Dust | 65 | 44 | 109 | 2% | The Member State also provided data for emissions of Pb, Cd, Hg, As, Cr, Cu, Ni, Se and Zn. Cyprus has provided aggregated figures for the capacity class 1 to 20MW _{th} | |
| | SO ₂ | 972 | 494 | 1,466 | 8% | | |
| | NO _x | 212 | 1,959 | 2,171 | 11% | | |
| Czech republic | Dust | 321 | 308 | 223 | 852 | 1% | |
| | SO ₂ | 1,807 | 1,248 | 4,080 | 7,136 | 4% | |
| | NO _x | 1,941 | 1,958 | 2,236 | 6,135 | 3% | |
| Estonia | Dust | 1,141 | 1,015 | 1,386 | 3,542 | 13% | Data were also provided for emissions of HCl, Pb, Hg, Ni, As, Cd, Cr, Cu & Zn |
| | SO ₂ | 4,431 | 648 | 3,990 | 9,069 | 17% | |
| | NO _x | 552 | 754 | 529 | 1,835 | 6% | |
| Finland | Dust | 220 | 320 | 320 | 860 | - | |
| | SO ₂ | 560 | 1,800 | 3,680 | 6,040 | - | |
| | NO _x | 1,680 | 1,940 | 4,420 | 8,040 | - | |

| Member State | Pollutant | Emissions from combustion plants (t) | | | | % of MS total emissions | Notes |
|--------------|-----------------|--------------------------------------|--------|---------|--------|-------------------------|---|
| | | 1-5MW | 5-20MW | 20-50MW | 1-50MW | | |
| France | Dust | 3,739 | | 2,479 | 6,218 | 1% | France has provided aggregated figures for the capacity class 1 to 20MW _{th} . |
| | SO ₂ | 18,480 | | 8,034 | 26,514 | 9% | |
| | NO _x | 36,242 | | 10,284 | 46,526 | 4% | |
| Germany | Dust | | | | 3,770 | 1% | Data were also provided for emissions of Mercury. Germany provided combined 1-50MW figures for emissions. |
| | SO ₂ | | | | 29,800 | 7% | |
| | NO _x | | | | 62,900 | 5% | |
| Netherlands | NO _x | 8,600 | 11,700 | 1,600 | 21,900 | 8% | The figures presented are a rough estimate. Additional information provided as part of the consultation on the final report (July 2012) indicates SO ₂ and dust emissions of 0.5kt for both pollutants for plants <50MW _{th} . |
| Poland | Dust | - | 2 | 3,832 | 3,834 | 1% | <i>AMEC: Submitted data for 5-20MW_{th} class are considered incomplete and have been removed in subsequent analysis.</i> <i>The year of the provided emissions data was not indicated. Latest national totals (2009) were used.</i> |
| | SO ₂ | - | 3 | 11,866 | 11,869 | 1% | |
| | NO _x | - | 1 | 5,629 | 5,630 | 1% | |
| Slovakia | Dust | 269 | 192 | 111 | 572 | 2% | The Member State also provided data for emissions of Pb, Cd, As, Hg, Cr, Cu, Ni, Se, Zn Emissions data for year 2010. |
| | SO ₂ | 160 | 260 | 222 | 642 | 1% | |
| | NO _x | 698 | 1,185 | 845 | 2,728 | 3% | |
| Slovenia | Dust | 126 | 126 | 24 | 276 | 1% | The numbers in class 1-5MW _{th} are only boilers using solid fuel. The numbers in class 5-20MW _{th} exclude boilers using natural gas below 10 MW. |
| | SO ₂ | 107 | 193 | 137 | 437 | 4% | |
| | NO _x | 926 | 794 | 541 | 2,261 | 5% | |
| Sweden | NO _x | 39 | 2,923 | 3,761 | 6,723 | 4% | <i>AMEC has estimated NO_x emissions from the reported 2009 data on mg NO_x/MWh using supplied energy data with assumptions on plant efficiencies supplied by the Swedish authorities.</i> <i>The figures for the 1 to 5MW_{th} capacity class are considered incomplete due to the limitations of the underlying data source.</i> |

Note: The figures of % of MS total emissions for Poland, Slovakia, Slovenia and Sweden have been calculated by AMEC on the basis of supplied emissions data for the combustion plants together with national total emissions reported to CLRTAP.

The SO₂, NO_x and dust emissions data in the above table (excluding those highlighted in red) are summarised below in Figure 3.3.

Figure 3.3 (a) SO₂ (b) NO_x and (c) dust emissions data reported by Member States from small combustion plants, split by capacity class where available




The emissions data for capacity class 20 to 50MW_{th} provided by Member States have been compared to the emissions estimates assumed in the AEA (2007) study. This comparison is shown in the Figure below. It shows that:

- For SO₂ emissions, two Member States (EE and FR) reported to this study significantly higher SO₂ emissions than were estimated in AEA (2007), whilst the opposite is true for most MS (CZ, PL, SI and SK). For only one MS do the two data sources match closely (FI).
- For NO_x emissions, all the Member States reported to this study significantly lower NO_x emissions than were estimated in AEA (2007).

- For dust emissions, most Member States (CZ, FI, SI, SK) reported to this study significantly lower dust emissions than were estimated in AEA (2007), whilst the opposite is true for two MS (EE, FR). For only one MS do the two data sources match closely (PL).

Figure 3.4 (a) SO₂ (b) NO_x and (c) dust emissions data reported by Member States from 20-50MW_{th} plants, compared to estimates in AEA (2007)



Note: AEA (2007) refers to 'PM' emissions. It has been assumed that this represents the pollutant PM_{TSP}.

3.1.6 Typical combustion techniques used

The information reported by Member States on the typical combustion techniques used in combustion plants less than 50MW are summarised below in Table 3.5. Any Member States not listed in the table have not reported this information.

Table 3.5 Typical combustion techniques used by combustion plants of rated thermal input less than 50MW reported by Member States to this study, split by capacity class

| Member State | Typical combustion techniques used | | | Member State comments |
|----------------|--|--|---|--|
| | 1-5MW | 5-20MW | 20-50MW | |
| Austria | - | - | - | Data in above tables relates to steam boilers only. No further data available on use of furnaces, turbines or engines. |
| Cyprus | Boilers | Boilers | Engines | |
| Czech republic | Mostly gas furnaces (80%) | Mostly gas furnaces (80%) | Mostly gas furnaces (60%) and coal boilers (20%) | |
| Estonia | Boilers | Boilers | Boilers | |
| Finland | Boilers | Boilers | Boilers | |
| Germany | Boilers, turbines, furnaces, engines | Boilers, turbines, furnaces, engines | Boilers, turbines, furnaces | |
| Netherlands | gas engines 41%, boilers 33%, furnaces 22%, turbines 3%, diesel engines 1% | Boilers 49%, gas engines 24%, furnaces 19%, turbines 7%, diesel engines 1% | Boilers 32%, turbines 26%, furnaces 41%, gas engines 1% | Percentages are estimates |
| Poland | - | Boilers | Boilers mostly | |
| Portugal | - | - | boilers, turbines, engines | |
| Romania | furnaces, boilers | furnaces, boilers, blast furnace, turbogenerators, thermal/heat treatment furnaces | furnaces, blast furnaces, boilers | |
| Slovakia | Boilers | Boilers | Boilers | |
| Slovenia | Boilers, turbines, furnaces, engines | Boilers, turbines, furnaces, engines | Boilers, turbines, furnaces, engines | |
| Sweden | 1 boiler, 3 CHP | 69 boilers, 93 CHP, 11 GT | 45 boilers, 51 CHP, 9 GT | |
| United Kingdom | 33 burners, 5 boilers | 33 boilers, 2 furnaces | 81% boilers, 1% turbines, 18% engines | The classes 1-5MW _{th} and 5-20MW _{th} are for Northern Ireland only. |

The reported techniques in the table above indicate that boilers make up the majority of the combustion units in EU combustion plants of rated thermal input 1 to 50 MW, and for each sub-capacity class 1-5MW_{th}, 5-20MW_{th} and 20-50MW_{th}. All the other combustion techniques – turbines, furnaces and engines – are reported by at least two Member States to be in use at all capacity ranges 1-5MW_{th}, 5-20MW_{th} and 20-50MW_{th}.

On the basis of this conclusion – that the majority of the combustion units for small combustion plants are boilers – this will be used for the assessment for analysing options for the control of emissions in this sector in order to simplify the analysis.

3.1.7 Typical sectors in which the combustion plants operate

Table 3.6 below contains the data received from Member States on the typical sectors within which the combustion plants less than 50 MW_{th} operate. It is important to note that the numbers presented in this figure exclude (i) those Member States that did not report data; and (ii) those plants for which sector data was unavailable. Due to the latter point, the numbers presented in this table may not agree with those included in Table 3.1 (which should be assumed to be correct).

Table 3.6 Sectoral information received from Member States on combustion plants 1 to 50 MW_{th}

| Member State | Sector | Number of plants | Notes |
|----------------|---|------------------|--|
| Cyprus | Public electricity generation | 3 | |
| | Hospitals and universities | 13 | |
| | Food industry (excl. greenhouses) | 97 | |
| | Industrial (other than food) | 98 | Includes: pharmaceutical Ind. Rendering Plants, Laundries, Carton industries, Production of Paints & Varnishes, Cement Plants etc |
| Czech republic | Public heat generation (incl. district heating) | 986 | Includes: Public electricity generation / Public heat generation (including district heating) / Combined heat and power generation |
| | Hospitals and universities | 1454 | Includes: Hospitals and universities administrative institutions and office buildings. <i>AMEC: This data appears high compared to other Member States except the Netherlands. The plants reported by the Member State are almost exclusively in the 1 to 5 MW_{th} category.</i> |
| | Food industry (excl. greenhouses) | 945 | Includes: Agriculture, silviculture and aquaculture |
| | Industrial (other than food) | 179 | Includes: Mineral oil refineries, Coal processing, Production and processing of iron and steel, Production and processing of non-ferrous metals, Chemical industry, Pulp, paper and printing |
| | Other | 1427 | |
| Estonia | Public electricity generation | 6 | |
| | Public heat generation (incl. district heating) | 241 | |
| | Hospitals and universities | 7 | |
| | Food industry (excl. greenhouses) | 54 | |
| | Industrial (other than food) | 167 | Includes: textiles, wood, chemicals , metal products, furniture |
| | Other | 265 | Includes oil terminals, asphalt concrete plants, farms, heating in service sector. |

| Member State | Sector | Number of plants | Notes | |
|--------------|---|------------------|--|--|
| Finland | Public heat generation (incl. district heating) | 442 | Includes public electricity generation, public heat generation (including district heating) and combined heat and power generation | |
| | Food industry (excl. greenhouses) | 16 | | Includes: fodder production |
| | Industrial (other than food) | 112 | | Includes: mining industry, chemical industry, metal industry, pulp and paper manufacturing, mechanical forest industry, construction industry, other industry |
| | Other | 12 | | Includes: (waste incineration, wastewater treatment plants, fuel storage) |
| Germany | Public electricity generation | 225 | These figures exclude the approximate 6000 biogas plants in capacity class 1-5MW _{th} of unknown sector. | |
| | Public heat generation (incl. district heating) | 662 | | |
| | Combined heat and power generation | 10 | | |
| | Hospitals and universities | 18 | | |
| | Food industry (excl. greenhouses) | 43 | | |
| | Industrial (other than food) | 189 | | |
| | Other | 29 | | |
| Netherlands | Public heat generation (incl. district heating) | 10 | Includes: Public electricity generation & Public heat generation (including district heating) | |
| | Combined heat and power generation | 95 | | |
| | Hospitals and universities | 1830 | | <i>AMEC: This datum appears high compared to other Member States apart from the Czech Republic. The plants reported by the Member State are almost exclusively in the 1 to 5 MW_{th} category.</i> |
| | Greenhouses | 4460 | | |
| | Food industry (excl. greenhouses) | 350 | | |
| | Industrial (other than food) | 860 | | |
| | Other | 1750 | | |
| Portugal | Public electricity generation | 6 | Textile, Agroforestry, others | |
| | Public heat generation (incl. district heating) | 1 | | |
| | Combined heat and power generation | 16 | | |
| | Food industry (excl. greenhouses) | 3 | | |
| | Industrial (other than food) | 8 | | |

| Member State | Sector | Number of plants | Notes |
|---|---|------------------|--|
| Romania | Public electricity generation | 18 | |
| | Public heat generation (incl. district heating) | 325 | |
| | Combined heat and power generation | 84 | |
| | Hospitals and universities | 147 | |
| | Greenhouses | 1 | |
| | Food industry (excl. greenhouses) | 159 | |
| | Industrial (other than food) | 503 | |
| | Other | 69 | |
| Slovakia | Public heat generation (incl. district heating) | 759 | |
| | Food industry (excl. greenhouses) | 150 | Includes: Crop and animal production, hunting and related service activities, Manufacture of food products, Manufacture of beverages, Food and beverage service activities |
| | Industrial (other than food) | 622 | The Slovak authorities provided a breakdown of plants according to a significant list of sectors. AMEC has grouped industrial activities together. |
| | Other | 1185 | |
| United Kingdom (data only represent Northern Ireland) | Combined heat and power generation | 3 | |
| | Hospitals and universities | 2 | |
| | Food industry (excl. greenhouses) | 19 | |
| | Industrial (other than food) | 49 | Includes: Rendering; Paper and Pulp; Tyre Manufacture; Combustion; Tobacco Production, Incineration; Animal Feed; Slaughtering; Galvanising; Pharmaceutical; Aluminium casting, coating process, Road stone coating, mineral drying; coating |

3.1.8 Degree to which the combustion installations below 50 MW_{th} may be already covered under IED

Article 3(3) of Directive 2010/75/EU on industrial emissions (IED) defines an installation as, ‘a stationary technical unit within which one or more activities listed in Annex I or in Part VII are carried out, and any other directly associated activities on the same site which have a technical connection with the activities listed in those Annexes and which could have an effect on emissions and pollution’.

Therefore combustion units with a rated thermal input less than 50MW_{th} may already be regulated under IED as part of installations where the aggregated combustion capacity on site is at least 50MW_{th} or where combustion is a *directly associated activity with a technical connection* to the IED activity. Competent authorities were requested to estimate the number of combustion units in each capacity class which are already regulated under the IED. The response from competent authorities was limited and is summarised in Table 3.7 (below).

Table 3.7 Proportion of reported combustion plants below 50MW_{th} that are considered to be covered by the IED as directly associated activities because the aggregated combustion capacity on site is at least 50MW_{th}

| Member State | Actual data / Estimate | Proportion of plants $<50\text{MW}_{\text{th}}$ covered by IED as DAAs | | |
|----------------|------------------------|--|------------------------------|-------------------------------|
| | | 1- 5MW_{th} | 5- 20MW_{th} | 20- 50MW_{th} |
| Cyprus | Actual Data | 23% | 19% | 100% |
| Czech Republic | Estimate | (not split by capacity class) 20 – 30% | | |
| Finland | Actual Data | 0% | 1% | 77% |
| France | Estimate | 15% (combined 1- 20MW_{th}) | | 46% |
| Netherlands | Estimate | 27 installations or fewer (In industry only) | | |
| Portugal | Actual data | no data | no data | 24% |

For the data received for the six Member States listed in Table 3.7, it is apparent that a greater proportion of 20 to 50MW_{th} combustion plants may be covered as directly associated activities with IED installations than plants less than 20MW_{th} . It is not considered sufficiently robust to try to estimate the proportions covered as directly associated activities from supplied sectoral information.

The following EU level assumptions have been made for the Member States not listed in Table 3.7: 5% of plants in 1-5 MW_{th} capacity class, 10% of plants in 5-20 MW_{th} capacity class and 40% of plants in 20-50 MW_{th} capacity class. These assumptions feed into the estimation of administrative costs. The figure of 40% of plants in the 20-50 MW_{th} category being directly associated activities is consistent with the limited data on the subject presented in AEA (2007).

3.2 Overview of Current Regulation of Combustion Plants/Installations Less than 50 MW

3.2.1 EU legislation

The table below provides a summary of some of the key EU legislation other than IPPC/IED that could affect combustion plants less than 50MW_{th} .

Table 3.8 Summary of EU level policies other than IPPC/IED with implications for small combustion plants

| Policy | Summary | Relevant Scope | Relevant Timescales | Requirements | Implication for business as usual trends of SCPs |
|--|---|--|--|--|--|
| EU ETS Directive (2003/87/EC) as amended by Directive 2009/29/EC | GHG emissions trading scheme for the largest emitting industrial sectors. | Installations >20MW _{th} in any sector (aggregation rules exclude combustion units <3MW _{th} and units which exclusively use biomass). | Phase II currently in force. Phase III (2013-2020) will significantly restrict the allocation of free allowances. | Submit allowances to cover GHG emissions. | Increases financial incentives for installations to invest in GHG abatement measures. This will <ul style="list-style-type: none"> - Encourage more efficient SCPs; - Encourage fuel-switching to natural gas and biomass / other biofuels. |
| Renewable Energy Directive 2009/28/EC | Directive 2009/28/EC establishes a common framework for the production and promotion of energy from renewable sources. Introduces national targets for the share of energy produced from renewable sources. | Targets are set at Member State level and implicitly include combustion plants <50MW _{th} . | Targets are set for 2020. | No direct requirements for individual installations. | <ul style="list-style-type: none"> - Reduction in number of SCPs due to encouragement of generation from non-combustion renewable sources. Consequent reduction in fuel consumption and emissions. - Increase in uptake of biomass, biofuel and biogas (either for new installations or fuel switching at existing plants). The impact on emissions to air will depend on the fuel types being switched from/to. |
| Effort Sharing Decision 406/2009/EC | Establishes binding national GHG emissions targets for non-ETS sectors (relevant examples: buildings, agriculture). | Targets are set at Member State level and implicitly include combustion plants <50MW _{th} . | Targets are set for the period 2013-2020. | No direct requirements for individual installations. | <ul style="list-style-type: none"> More efficient heating systems will be encouraged. Increased uptake of renewable fuels. |
| CHP Directive 2004/8/EC (to be replaced by the Energy Efficiency Directive) | Promotes cogeneration based on useful heat demand. | All CHP plants (and all plants which could be converted to CHP). | Implemented in 2004. | Encourages the introduction of subsidies and removal of barriers for cogeneration at a Member State level. | <ul style="list-style-type: none"> Increase the number of CHP SCPs. <i>Increase combustion efficiency, reducing fuel consumption and emissions.</i> |
| Eco-Design of Energy Using Products Directive 2009/125/EC | Provides consistent EU-wide rules for improving the environmental performance of energy related products (ERPs) through ecodesign. Described in more detail following this table. | Energy-using products (EUPs), which use, generate, transfer or measure energy, such as boilers. | Preparatory studies on different product groups are produced over time. The boilers preparatory study was finalised in 2007. | Encourage the selection of more efficient EUPs. | <ul style="list-style-type: none"> Considered to be small as the largest category of boiler considered in the preparatory study (2007) was <1MW. However, the approach is being considered in this study as one option for controlling emissions from 1-5MW_{th} plants. |

The current Ecodesign Directive 2009/125/EC extends the scope of past Ecodesign Directive 2005/32/EC on energy-using products. It establishes a framework for setting product-specific requirements along with legislation on energy efficiency and other design standards using a life-cycle approach. Directive requirements are introduced on a product-by-product basis using a combination of Implementing measures (IM) to be adopted by the Commission and voluntary agreements. It is a supply side approach, to be considered alongside the Energy Labelling Directive 2010/30/EU which targets consumer demand by setting product-specific requirements for standard information on energy efficiency. Implementing measures are adopted for new products meeting the three criteria of significant environmental considerations, significant potential for improvement and significant trade and sales volume (with an indicative threshold of 200 000 units per year).

Recently adopted Regulations under the Directive have included measures for circulators, electric motors, household refrigerating appliances, televisions and fans. Other measures under preparation include commercial refrigerators, computers, pumps, room air-conditioners, domestic lighting products, other refrigerating & freezing equipment, boilers and solid fuel small combustion installations. The latter two products are perhaps of most relevance to the plants under consideration in this study:

- **Boilers (Lot 1):** Technologies covered under this lot are fossil-fuel boilers, heat pumps and micro cogeneration, with the draft Regulation establishing ecodesign requirements “for the placing on the market and/or putting into service of heaters with a rated heat output ≤ 400 kW”⁶. There are a number of proposed exclusions, for example heaters using predominantly biomass or solid fuels, those falling under the IED, or cogeneration space heaters with a maximum electrical capacity over 50kW. Draft proposed ELVs for NO_x emissions for new appliances range from 70 to 120 mg/kWh; and
- **Solid fuel small combustion installations (Lot 15):** This lot addresses energy efficiency and emissions of biomass and coal fired small combustion installations below 500 kW, including local room heaters (ovens, stoves) and central heating products. Current progress includes a completed Preparatory study and background study for the Impact Assessment. Draft proposed ELVs for particulate matter emissions range from 50 to 100 mg/m³. Other emissions to be addressed include CO, Organic Gaseous Carbon and VOCs. NO_x is not considered as it is fuel as opposed to product related.

Whilst the current Eco-Design Directive (and ongoing investigations) is unlikely to have much impact on 1-50 MW_{th} combustion plants, the overall framework could potentially be applied to the smaller sized plants under consideration in this study i.e. 1-5 MW_{th}. The relative pros and cons of considering such an approach are discussed further in Section 5.

3.2.2 Member States' national legislation

Although emissions to air from combustion installations with a rated thermal input less than 50 MW are not regulated at an EU level, some Member States are regulating this. Table 3.9 (below) summarises information received during the study on Member States' national legislation. This information has been used in this study to

⁶ http://www.eceee.org/Eco_design/products/boilers/resolveuid/b722b7a390d03a04259e5b2f3dea0f7b

help develop possible options for the control of emissions from these plants as well as to understand which plants may already be able to meet any minimum ELVs if they were to be set at an EU level.

Table 3.9 Summary of National Legislation regulating combustion plants less than 50MW_{th}

| Member State | Legislation | Covers permitting? | Includes ELVs? | Specifies monitoring requirements? |
|--------------------|---|--|--|--|
| Austria | BGBI.II Nr. 312/2011 concerning furnaces which are not steam boilers and BGBI Nr.19/1989 idf. BGBL. II Nr. 153/2011 concerning steam boilers and gas turbines <50 MW. | X | ✓ | ✓ |
| Belgium - Flanders | VLAREM II (Order of the Flemish Government of 1 June 1995 concerning General and Sectoral provisions relating to Environmental Safety). Legislative requirements for combustion installations are described in chapter 43 and for stationary engines in chapter 31 of VLAREM II. | ✓ | ✓ | ✓ |
| Belgium - Brussels | 'Ordonnance relative au permis d'environnement (1997)' | Not known (English language translation not available) | | |
| Belgium - Walloon | Unknown | Not known | ✓ | ✓ |
| Bulgaria | <i>No information received.</i> | | | |
| Cyprus | The Control of Atmospheric Pollution (Non Licensable Installations) Regulation of 2004 (P.I. 170/2004)» and «The Control of Atmospheric Pollution (Non Licensable Installations) (Amendment) Regulations of 2008 (P.I. 198/2008) | No permits are required | ✓ | ✓ |
| Czech Republic | Government Ordinance No. 146/2007 Coll. In wording No. 476/2009 Coll. (ELVs) Decree No. 205/2009 Coll. In wording No. 17/2010 Coll. (Monitoring) As part of the consultation on the final report, the Czech authorities have indicated that a new air protection act has been introduced (No. 201/2012 Coll. in force from 01/09/2012), which replaces older legislation. This is summarised in the appendices. | X | ✓ | ✓ |
| Denmark | <i>No information received.</i> | | | |
| Estonia | Välisõhu kaitse seadus, Vastu võetud 05.05.2004 RT I 2004, 43, 298 (ambient air protection act) | ✓ (indefinite permit specifying ambient air limits) | ✓ (permit specific) | ✓ (permit specific) |
| Finland | Environmental Protection Act Government Decree on environmental protection requirements for energy production installations with a total fuel capacity below 50 MW | ✓ | ✓ | Not known (English language translation not available) |
| France | Inspection des Installations Classees (Permitting – separate regimes for 2-20MW _{th} and 20-50MW _{th}) NOR: ATEP9760321A Version consolidée au 15 décembre 2008 (ELVs 2-20MW _{th}) ELVs for >20MW _{th} (various regulations, depending on age of plant) | ✓ (English language translation not available) | ✓ (English language translation not available) | ✓ (English language translation not available) |

| Member State | Legislation | Covers permitting? | Includes ELVs? | Specifies monitoring requirements? |
|--------------|---|--|---|---|
| Germany | Erste Verordnung zur Durchführung des Bundes-Immissionsschutzgesetzes (Verordnung über kleine und mittlere Feuerungsanlagen - 1. BImSchV) (ELVs). This is relevant for combustion plants firing solid fuels (<1MW) and gaseous and liquid fuels (<20MW). These plants are regularly monitored but no permitting process is applied; instead a notification procedure applies. First General Administrative Regulation Pertaining the Federal Immission Control Act (Technical Instructions on Air Quality Control – TA Luft) (24 July 2002) (Monitoring) | X (licensing is only mandatory under TA Luft) | ✓ | ✓ |
| Hungary | <i>No information received.</i> | | | |
| Ireland | Air Pollution Act 1987 (if the combustion plant is associated with an activity licensable under the Act) | No | No. May be set but site-specific. | No. May be set but site-specific. |
| Italy | <i>No information received.</i> | | | |
| Latvia | <i>No information received.</i> | | | |
| Lithuania | <i>No information received.</i> | | | |
| Luxembourg | <i>No information received.</i> | | | |
| Malta | <i>No information received.</i> | | | |
| Netherlands | BEES-B (Existing installations <50MW _{th}) BEMS (New installations; and from 2017 (2019 in some cases) will replace BEES-B in covering existing installations) | ✓ (English language translation not available) | ✓ GBR | ✓ |
| Poland | Environmental Protection Law (Permits) Emission standards regulation (ELVs for 1-50MW _{th}) ROZPORZĄDZENIE MINISTRA ŹRODOWISKA (Monitoring) | Not required | ✓(English language translation not available) | ✓(English language translation not available) |
| Portugal | Decree-Law 78/2004, April 3rd http://dre.pt/pdf1s/2004/04/080A00/21362149.pdf Ordinance 675/2009, June 23 rd http://dre.pt/pdf1sdip/2009/06/11900/0410804111.pdf | ✓ | ✓ | ✓ |
| Romania | Ministerial Order no 1798/2007 for the approval of the procedure of issuing the environmental permit ELVs in accordance with Ministerial Order no. 462/1993 – Technical conditions regarding air protection, Annex 2 | ✓ | ✓ | ✓ |
| Slovakia | Extracts provided, but not references | ✓ | ✓ | ✓ |
| Slovenia | UREDBO o emisiji snovi v zrak iz malih in srednjih kurilnih naprav (based on TA Luft) | ✓ | ✓ | ✓ |
| Sweden | Permit conditions for plants are set on a case-by-case basis. | ? | Case-by-case basis | ? |
| Spain | ELVs are set by Autonomous Communities. General binding rules do not exist. (No references provided) | X | X | X |
| UK | Environmental Permitting, England and Wales (2010) – Part B Regulations apply to boilers 20-50MW _{th} | ✓ (>20MW _{th} only) | ✓ (>20MW _{th} only) | ✓ (>20MW _{th} only) |

A compilation of the various ELVs applied by Member States in their national legislation is included in Appendix F.

3.2.3 Gothenburg Protocol and revision

The 1979 Convention on Long-Range Transboundary Air Pollution, was established within the framework of the United Nations Economic Commission for Europe (UNECE), entered force in 1983 and has since been extended by eight specific protocols. The most recent protocol⁷, is commonly referred to as the Gothenburg protocol and entered force in 2005.

In June 2012, agreement was reached in revising the Gothenburg Protocol. Certain aspects of the revision widen the Protocol's scope in relation to combustion plants less than 50MW_{th}. The elements of the newly revised protocol which are relevant to combustion plants between 1 MW_{th} and 50 MW_{th} can be summarised as follows:

- Annex II sets national SO₂, NO_x, NH₃ and VOC emissions ceilings for 2010 until 2020 and emission reduction commitments (additionally for PM_{2.5}) for 2020 and beyond for signatories to the protocol. These ceilings and reduction commitments are not sector specific but may influence the need to control emissions from combustion plants between 1 MW_{th} and 50 MW_{th}.
- Annexes IV, V, VI and X (new) specify limit values for emissions of sulphur, nitrogen oxides, volatile organic compounds and particulate matter respectively from stationary sources. For combustion plants with a rated thermal input between 1 MW_{th} and 50 MW_{th}, the following provisions are relevant:
 - Annex IV (SO₂): limit for sulphur content of gas oil at <0.1% by January 2008;
 - Annex V (NO_x): limit values for *new* stationary engines which run for more than 500 hours per year, differentiated by fuel, size and combustion type, as follows: specifically for gas engines and dual fuel engines greater than 1MW_{th}, and diesel engines greater than 5MW_{th};

| | | |
|--|--|--|
| Gas (Otto) engines | >1MW _{th} | 95-190 mg NO _x /Nm ³ |
| Dual-fuel engines (in gaseous mode) | >1MW _{th} | 190 mg NO _x /Nm ³ |
| Dual-fuel engines (liquid mode): | 1-20MW _{th} and >20MW _{th} | 225 mg NO _x /Nm ³ |
| Slow / medium speed (<1,200 rpm) diesel engines (heavy fuel oil and bio-oils) | 5-20MW _{th} | 225 mg NO _x /Nm ³ |
| | >20MW _{th} | 190 mg NO _x /Nm ³ |
| Slow / medium speed (<1,200 rpm) diesel engines (light fuel oil and natural gas) | >5MW _{th} | 190 mg NO _x /Nm ³ |
| All high speed (>1,200 rpm) diesel engines | | 190 mg NO _x /Nm ³ |

⁷ 'Protocol to the 1979 Convention on long-range transboundary air pollution to abate acidification, eutrophication and ground-level ozone'. Available from:

<http://www.unece.org/fileadmin/DAM/env/lrtap/full%20text/1999%20Multi.E.Amended.2005.pdf>

- Annex X (particulate matter): recommended but not binding dust limit values for solid and liquid fuel-fired boilers and process heaters with rated thermal input from 1 MW_{th} to 50 MW_{th}

| | | |
|---------------------------------|------------------------|---------------------------|
| New solid and liquid fired | >1-50 MW _{th} | 20 mg dust/m ³ |
| Existing solid and liquid fired | >1-5 MW _{th} | 50 mg dust/m ³ |
| | >5-50 MW _{th} | 30 mg dust/m ³ |

- In addition, these limit values are not the only option for compliance; new stationary sources may alternatively ‘*apply different emission reduction strategies that achieve equivalent overall emission levels for all source categories together*’.
- A provision to review an evaluation of mitigation measures for black carbon emissions.
- Lastly, the protocol states, ‘*Each Party should apply best available techniques (...) to each stationary source covered by annexes IV, V, VI and X, and, as it considers appropriate, measures to control black carbon as a component of particulate matter, taking into account guidance adopted by the Executive Body*’.

3.3 Overview of abatement measures typically used in combustion plants less than 50 MW_{th}

Limited data were received on the typical abatement measures that are currently used in small combustion plant. The data that were received are summarised below in Table 3.10.

Table 3.10 Summary of abatement techniques reported by Member States as being currently employed at 1-50MW_{th} combustion plants

| Pollutant | Member State | 1-5MW _{th} | 5-20MW _{th} | 20-50MW _{th} |
|-----------------|----------------|--|-----------------------|---|
| SO ₂ | Czech Republic | End-of-pipe technologies are not employed. Older boilers using solid fuels would be required to install a gas-fired boiler | | |
| | Belgium | Studies on the BAT for SCPs are available for the Flemish Region of Belgium. | | |
| | Germany | N/A | Dry sorbent injection | Dry sorbent injection (spray dryer) |
| | Poland | - | - | Dust settling chamber 30% abatement (one case) Limestone semi dry process 50% abatement (one case) |

| Pollutant | Member State | 1-5MW _{th} | 5-20MW _{th} | 20-50MW _{th} |
|---|---|--|--|--|
| NO _x | Czech Republic | End-of-pipe technologies are not employed | End-of-pipe technologies are not employed | End-of-pipe technologies are not employed |
| | Belgium | Studies on the BAT for SCPs are available for the Flemish Region of Belgium. | | |
| | Netherlands | New plants - SCR for gas engines. SNCR for wood burning. LNB for all. | New plants - As for smaller plants, but wood burning installations require SCR. | |
| | Sweden | Combustion modifications on 25% of plants. | Waste Gas Recirculation (32% plants), SNCR (30%), combustion modification (4%) and others. | Waste Gas Recirculation (13% plants), SNCR (73%), Over Fire Air (4%) and other techniques. |
| | Germany | N/A | Low-NO _x -burner | Low-NO _x -burner and SNCR |
| | Poland | - | SCR (20% abatement) | - |
| Dust/PM | Czech Republic | End-of-pipe technologies are not employed, as most are natural gas-fired. | | |
| | Belgium | Studies on the BAT for SCPs are available for the Flemish Region of Belgium. | | |
| | Estonia | ELVs and abatement techniques required are set at installation level, depending on the fuel-type; cyclones are most commonly required. | | |
| | Germany | Fabric filter (Note 1) | Fabric filter (Note 1) | Fabric filter or ESP (Note 1) |
| | Netherlands | Multicyclones | Fabric filter | Fabric filter |
| | Poland | Multicyclone, 80-95% abatement | Multicyclone, 70-98% abatement | Multicyclone, 72-98% abatement |
| | | Dry cyclone, 70-95% abatement | Dry cyclone, 72-99% abatement | Dry cyclone, 44-92% abatement |
| | | Bag filters, 85% abatement (one case) | Dry electrostatic precipitator, 90-98% abatement | Dry electrostatic precipitator, 85-98% abatement |
| Bag filters, 75-99.9% abatement | | Bag filters, 75-99.9% abatement | Bag filters, 95-99.9% abatement | |
| Dust settling chamber, 20-32% abatement | Dust settling chamber, 20% abatement (one case) | Limestone dry process, 73% abatement (one case) | | |
| Wet scrubber, 96% abatement (one case) | | | | |

Note 1: it remains unclear whether these are recommended or applied for both new and existing plants.

The information gathered on the abatement options – supplemented with information available from previous studies – has informed the abatement option matrix that has been developed for the assessment of control options in section 5.

4. Development of an EU dataset of combustion plants 1 to 50 MW_{th}

4.1 Overview

As identified in Section 2, and evident from the presentation of data in Section 3, there is a need to make adjustments and additions to the data gathered from the Member States during this study. This is in order to obtain a representative dataset of estimates of combustion plants between 1 and 50 MW_{th} (numbers, capacities and emissions) so as to be able to assess the total EU potential costs and benefits for controlling their emissions. Three main sets of amendments have been carried out:

- i. Adjustment of data gathered from Member States in instances where the data have been flagged by the Member State or AMEC as being only partially complete. These data were highlighted with the amber colour in the tables in Section 3.
- ii. Supplementing the data gathered from Member States during this study with existing data to fill in gaps.
- iii. Extrapolating the adjusted new and supplemented existing data to cover those Member States and/or capacity classes for which no data (new or existing) are available.

Each of these steps is described in turn in the following sections.

4.2 Adjusting partially complete data gathered

This step involves the use of factors to adjust the data provided by Member States for those instances in which the data have been indicated by the Member State – or identified by AMEC – as being only partially complete. Typically, partially complete has meant, for example, that the data provided cover only some of the plants within a particular capacity class. If no adjustments were made to such partially complete data, the assessment of potential costs and benefits may be inaccurate.

Each of the partially complete data has been adjusted on the basis of the specifics of the particular data gap. Appendix E documents the issues and resolutions adopted to adjust the partially complete data.

Notice in particular is drawn to the discussion around the French data which concludes to not reject the original data provided by the French authorities.

4.3 Supplementing with existing data on 20 to 50 MW_{th}

Previous work undertaken on 20-50 MW_{th} combustion installations has led to there being existing datasets which can be drawn upon to supplement the data gathered in this study in order to try to fill some of the remaining gaps.

Three sources of data on numbers / capacity / fuel consumption / emissions of combustion plants 20-50 MW_{th} have been identified:

- i. AMEC (then Entec) undertook a previous study for the Commission to gather data on combustion installations of capacities 20MW_{th} to 50MW_{th} as a support contract during the negotiation of the IE Directive (Entec, 2009)⁸. A summary of the data and information gathered from this study are included in Appendix C.
- ii. Preceding Entec (2009) was AEA (2007)⁹ which provided background material to the Commission for the proposal for the IED extending to cover 20 to 50 MW_{th} installations.
- iii. AMEC (as Entec) undertook for Defra in the UK an impact assessment for the initially proposed IED, which included an assessment of the impacts on combustion installations 20 to 50 MW_{th} (Entec 2008).

Although the distinction between combustion plants and installations has previously been recognised, due to the need to draw on additional data whilst retaining a pragmatic approach, it has been necessary to neglect the differences and utilise the data for combustion installations interchangeably with combustion plant.

The table below summarises the utilisation of existing data on 20 to 50 MW_{th} plants to supplement data gathered from the Member States.

Table 4.1 Summary of which existing data sources on 20 to 50 MW_{th} combustion plants and installations have been utilised to supplement new data gathered from Member States

| Member State | Data gap | Filled using data from Entec (2009) | Filled using data from AEA (2007) | Filled using data from Entec (2008) |
|--------------|------------------|-------------------------------------|-----------------------------------|-------------------------------------|
| AT | Fuel mix | | ✓ | |
| BE | Fuel mix | | ✓ | |
| BG | Number of plants | ✓ | | |
| | Capacity | ✓ | | |
| | Fuel consumption | ✓ | | |
| DK | Capacity | | ✓ | |
| | Fuel consumption | | ✓ | |
| | Emissions | | ✓ | |

⁸ Entec (2009) Study to inform on-going discussions on the proposal for a Directive on industrial emissions. Part 1: Combustion Activities. Final Report to the European Commission.

⁹ AEA (2007) Assessment of the benefits and costs of the potential application of the IPPC Directive (EC/96/61) to industrial combustion installations with 20-50 MW rated thermal input. Final Report to the European Commission.

| Member State | Data gap | Filled using data from Entec (2009) | Filled using data from AEA (2007) | Filled using data from Entec (2008) |
|--------------|------------------------|-------------------------------------|-----------------------------------|-------------------------------------|
| EL | Capacity | | ✓ | |
| | Fuel consumption | | ✓ | |
| | Emissions | | ✓ | |
| ES | Number of plants | ✓ (Note 1) | | |
| | Total fuel consumption | ✓ | | |
| | Fuel mix | | ✓ | |
| HU | Number of plants | ✓ | | |
| | Capacity | ✓ | | |
| | Fuel mix | ✓ | | |
| | Emissions | | ✓ | |
| IE | Capacity | | ✓ | |
| | Fuel consumption | | ✓ | |
| | Emissions | | ✓ | |
| IT | Number of plants | ✓ | | |
| | Capacity | ✓ | | |
| | Fuel consumption | | ✓ | |
| | Emissions | | ✓ | |
| LT | Capacity | | ✓ | |
| | Fuel consumption | | ✓ | |
| | Emissions | | ✓ | |
| LU | Number of plants | | Note 2 | |
| | Fuel mix | | ✓ | |
| LV | Capacity | | ✓ | |
| | Fuel consumption | | ✓ | |
| | Emissions | | ✓ | |
| MT | (all) | | Note 3 | |
| RO | Fuel mix | | ✓ | |
| SI | Fuel mix | | ✓ | |
| UK | Number of plants | | | ✓ |
| | Fuel consumption | | | ✓ |
| | Emissions | | | ✓ |

Note 1: the data from Entec (2009) have been used preferentially to those provided by the Spanish authorities to this study.

Note 2: data was missing in the AEA (2007) for LU. Data were obtained instead from 'IEEP (2006) Data gathering and impact assessment for a possible review of the IPPC Directive Fact sheet C1 Combustion Installations'.

Note 3: no data source for Malta was identified; in this absence, all Malta data has been set equal to data for Cyprus.

4.4 Extrapolating to missing Member States and capacity classes

4.4.1 Number of plants

In some cases (DK, EL, IE, LT, LV), it was necessary to estimate the number of plants in the 20 to 50 MW_{th} capacity class from data on total capacity. This was undertaken by dividing the capacity by the EU average size of plant in the category (Table 4.2). The average plant size in each capacity class was determined from complete data gathered from Member States on both numbers and capacity of plant.

Table 4.2 Assumed average capacity per plant

| Capacity class | Assumed EU average plant capacity (MW _{th}) |
|------------------------|---|
| 1-5 MW _{th} | 2.3 |
| 5-20MW _{th} | 8.9 |
| 20-50 MW _{th} | 32 |

Estimates for the number of plants in the capacity classes 1 to 5MW_{th} and 5 to 20 MW_{th} were derived from the numbers in the capacity class 20 to 50 MW_{th} by utilising average ratios between the number of plants in the smaller capacity classes and the 20-50MW_{th} category, shown below in Table 4.3. These ratios were derived from complete data provided by Member States.

Table 4.3 Ratio of numbers of plants at each capacity class

| Capacity class | Number of plants at each capacity class as a function of the number of 20-50MW _{th} plants |
|------------------------|---|
| 1-5 MW _{th} | 26 |
| 5-20MW _{th} | 7.5 |
| 20-50 MW _{th} | 1 |

4.4.2 Capacity of plants

The estimation of the total capacity of combustion plants in the 1 to 5 MW_{th} and 5 to 20 MW_{th} capacity classes has been undertaken using the average capacity per plant shown above in Table 4.2 multiplied by the numbers of plants.

As a sensitivity, it is also possible to switch the dataset to deriving capacity for the 1-5 MW_{th} and 5-20 MW_{th} categories from the capacity of plants in the 20-50 MW_{th} capacity class. This, if selected, is undertaken by utilising

average ratios of the capacity of plants in the smaller capacity classes to the capacity of plants in the 20-50 MW_{th} category, shown below in Table 4.4. These ratios were derived from complete data provided by Member States.

Table 4.4 Ratio of capacity of plants at each capacity class

| Capacity class | Capacity of plants at each capacity class as a function of the capacity of 20-50MW _{th} plants |
|------------------------|---|
| 1-5 MW _{th} | 1.7 |
| 5-20MW _{th} | 1.9 |
| 20-50 MW _{th} | 1 |

4.4.3 Fuel consumption of plants

Percentage fuel mix

For those Member States for which fuel mix data were not gathered or gap filled using existing data, additional assumptions were necessary on the average fuel mix across the five fuel types of biomass, other solid fuels, liquid fuels, natural gas and other gaseous fuels. This in-filling was necessary for the fuel mix of 1-5MW_{th} and 5-20MW_{th} capacity categories. It was assumed that the fuel mix in these smaller capacity classes was the same as that in the 20 to 50 MW_{th} capacity class.

Total fuel consumption

Where data have not already been gathered, the total fuel consumption of plants has been estimated in the central case by using average load factors together with the capacity data. The average load factors have been calculated separately for each capacity class from those data provided by Member States which were considered complete. The derived average load factors are shown below in Table 4.5. These load factors are similar to the range of load factors assumed in AEA (2007) of 1000 to 3000 annual operating hours.

Table 4.5 Average load factors for each capacity class

| Capacity class | Load factor (%) | Load factor (hours/year) |
|------------------------|-----------------|--------------------------|
| 1-5 MW _{th} | 24% | 2100 |
| 5-20MW _{th} | 35% | 3100 |
| 20-50 MW _{th} | 21% | 1850 |

As a sensitivity, it is also possible to switch the dataset to estimating fuel consumption for the 1-5MW_{th} and 5-20MW_{th} capacity classes from the fuel consumption of plants in the 20-50 MW_{th} capacity class. This, if selected, is undertaken by utilising the average ratios of the capacity of plants in the smaller capacity classes to the capacity of plants in the 20-50 MW_{th} category that were shown above in Table 4.4.

4.4.4 SO₂, NO_x and dust emissions of plants

Where no emissions data had been gathered, annual mass emissions of SO₂, NO_x and dust were estimated using the fuel consumption (FC) for each fuel type, together with the fuel-specific flue gas volume (FGV) and the estimated emission level (EL) for each fuel type *f*, according to the following equation:

$$\sum_f (FC_f \times EL_f \times FGV_f)$$

It is worth noting that throughout this report, it is assumed that no SO₂ emissions arise from natural gas or biomass combustion, and that gaseous fuels do not give rise to emissions of dust.

The fuel-specific flue gas volumes assumed in this study have been taken from AMEC (2012)¹⁰, assuming gaseous plants are primarily boilers, and are reproduced in Table 4.6.

Table 4.6 Specific flue gas volumes assumed in this study

| Fuel | Specific flue gas volume | Excess air (% oxygen) |
|---------------------|--------------------------|-----------------------|
| Biomass | 331 | 6% |
| Other solid fuels | 370 | 6% |
| Liquid fuels | 279 | 3% |
| Natural gas | 251 | 3% |
| Other gaseous fuels | 251 | 3% |

The emission levels are assumed, in the central case, to be at the same level as the identified emission limit value applied by that Member State, or in the absence of national legislation prescribing limit values for the particular capacity class in question, at the same level as a determined general EU case emission level. This aspect is described further in Section 5.

¹⁰ AMEC (2012) Analysis and summary of the Member States' emission inventories 2007-2009 and related information under the LCP Directive (2001/80/EC). Final Report for the European Commission.

4.5 Overview of resulting EU27 dataset

The table below provides an overview of the resulting EU-27 dataset with all of the amendments, additions and assumptions as described above. Member State level data underpinning this Table are presented in Appendix G.

Table 4.7 Resulting EU27 dataset

| Datum | 1-5 MW | 5-20 MW | 20-50 MW |
|--|---------|---------|----------|
| Number of plants | 107,506 | 29,958 | 5,078 |
| Capacity of plants (GW _{th}) | 251 | 273 | 165 |
| Biomass (PJ) | 200 | 280 | 148 |
| Other solid fuel (PJ) | 122 | 198 | 103 |
| Liquid fuel (PJ) | 206 | 358 | 198 |
| Natural gas (PJ) | 1,130 | 1,959 | 892 |
| Other gaseous fuel (PJ) | 20 | 31 | 26 |
| Total fuel consumption (PJ) | 1,678 | 2,826 | 1,367 |
| SO ₂ emissions (kt) | 170 | 277 | 78 |
| NO _x emissions (kt) | 179 | 268 | 110 |
| Dust emissions (kt) | 26 | 32 | 19 |

5. Options for the Possible Control of Emissions from Combustion Installations Less than 50 MW

5.1 Overview of Options

A number of options have been developed – in consultation with the Commission – for the possible control of emissions from combustion installations below 50MW_{th}. It is noted that, whilst this list of options refers to regulation through the IED, it should not be assumed that regulating through the IED would be the only mechanism to be considered for controlling emissions from these installations. Other legislative instruments could be developed in lieu of the IED with similar requirements. The different control options that have been considered are:

| | |
|---|---|
| Option 1 | No regulation. |
| Option 2a | “Full IED”. Inclusion of 1-50 MW _{th} installations as a new activity in Annex I of the IED, such that the installations would need to meet all the requirements of the IED Chapters I and II. A BAT regime and/or EU wide minimum ELVs would be in force. For the purposes of the modelling these have been set for each capacity class at the level of most stringent national MS legislation. |
| Option 2b | As per 2a, but with EU ELVs for all capacity classes set at level of ELVs for 50-100 MW _{th} in IED for existing plants. |
| Option 3 | “Light IED”. Inclusion of <50MW _{th} installations within the IED as a separate chapter but without a full permitting regime and no coverage under Chapter II (i.e. not listed as a new activity in Annex I). Installations would be subject to EU wide emission limit values for atmospheric emissions only as for option 2a. |
| Alternative approach for smaller plants | Product standards could be developed for smaller plants (1-5 MW _{th}) targeted at new units only – similar in approach to those currently being developed under the Ecodesign Directive for much smaller units. |

Option 2 of the above list would lead to combustion installations less than 50 MW_{th} not already covered as directly associated activities needing to meet all the requirements of the IED, including permitting, monitoring and BAT-based permit conditions (a BREF document would need to be developed for the sector or the existing combustion plant BREF revised). During negotiation of the IED, one of the reasons that contributed to the removal of the proposed increased coverage to include 20-50 MW_{th} combustion installations was concerns over the level of administrative burden that would be necessary to permit the high numbers of installations. This concern would presumably remain with some of the Member States at present, in particular those that either do not regulate these installations or those whose regulation of these installations is simpler.

Although the recently revised Gothenburg Protocol includes some aspects related to combustion plants smaller than 50MW_{th}, such that harmonised requirements may appear at first sensible, it may not be possible to harmonise EU controls with the Protocol because its approach for the control of dust emissions from <50MW_{th} plants is voluntary in nature. The Protocol does however include limit values for new gas and diesel stationary engines, but the definition of ‘new’ differs from that in the IED (in the Gothenburg protocol a *new stationary source* is one whose construction or major modification commenced after 17 May 2006) among other scope divergences.

The small combustion plants that would not already be covered under the IED as directly associated activities are, in many cases, relatively simple plants and whose most important environmental impact is atmospheric emissions. The data gathered in the study indicates that a large proportion are fired with natural gas so SO₂ and dust emissions are not significant for the majority of these plants. With this in mind, **Option 3** presents a simpler approach for controlling emissions from the sector whereby a separate chapter could be included in the IED setting out specific requirements (including ELVs) without needing to comply with the wider requirements of the Directive (an alternative to this would be development of a new Directive which only includes these requirements).

Alternative approach for smaller plants: Developing a different approach to controlling emissions from new combustion installations by way of product standards offers a potentially simpler option for the smallest plant without imposing any requirements on the large numbers of existing plant. However, because such an approach can only affect new installations, this option would return benefits over a longer time period. This option could be considered for the smallest plant in addition to some of the other options for larger plants (i.e. a hybrid approach).

Without any specific EU intervention in the form of regulating emissions from combustion installations less than 50 MW_{th} (**option 1**), existing national legislation of the Member States would continue to apply and the recent amendments to the Gothenburg Protocol’s requirements would come into force for parties to the convention (see section 3.2).

5.2 Assessment methodology

5.2.1 Overview

Our approach for developing the dataset used in the study was described in Section 4. The following sections describe how we have used this dataset for assessing the potential costs and benefits of different options for the control of emissions from these plants.

5.2.2 Emission levels

Emission levels – per capacity class / fuel / Member State – are assumed to be the same as the ELVs applicable to existing plants in current national legislation (as listed in Appendix F) or, in the absence of national legislative ELVs, the same as the assumed general case emission levels. A sensitivity analysis has been run with emission levels assumed to be 20% lower than the ELVs.

The general case emission levels have been set as equal to the least stringent ELVs in force in any Member State legislation at each capacity class. The general case emission levels are reproduced below in Table 5.1. It is important to note that the classification of ‘existing plant’ varies among Member States.

Table 5.1 General case emission levels (applied in the absence of Member State-specific ELVs)

| Capacity class | SO ₂ emission levels (mg/Nm ³) | | | NO _x emission levels (mg/Nm ³) | | | | | Dust emission levels (mg/Nm ³) | | |
|-----------------------|---|-------------|--------------------|---|------------------|-------------|-------------|--------------------|--|------------------|-------------|
| | Other solid fuel | liquid fuel | Other gaseous fuel | Biomass | Other solid fuel | Liquid fuel | Natural gas | Other gaseous fuel | Biomass | Other Solid Fuel | Liquid Fuel |
| 1-5MW _{th} | 2500 | 1700 | 350 | 650 | 650 | 900 | 400 | 400 | 300 | 250 | 150 |
| 5-20MW _{th} | 2500 | 1700 | 350 | 650 | 650 | 900 | 400 | 400 | 250 | 150 | 150 |
| 20-50MW _{th} | 2500 | 1700 | 800 | 650 | 650 | 600 | 400 | 300 | 300 | 150 | 150 |

Source: highest Member State specific ELVs at each capacity class identified in this study

5.2.3 EU wide limit values

EU-wide ELVs would most likely need to be set separately for different fuel and technology types, and potentially for different capacity classes, depending on what, if any, threshold would be applied. The introduction of EU-wide ELVs would increase harmonisation across the EU (allowing Member States to apply more stringent limit values) and would impact on some Member States more than others depending on the level and stringency of Member States’ existing national legislation. There would be a need for the Commission to determine what limit values would be seen as representing BAT, to be conceptually in-line with the IED e.g. via the development of a new BREF or revision of the existing combustion plant BREF. A pragmatic approach has been taken to simplify the analysis by assuming that all combustion plants are boilers (and assumptions and ELVs are appropriately selected). This simplification has been made following the data gathered from Member States indicating that the majority of plants comprised boiler combustion units. A sensitivity analysis around this assumption (focussed on engines) has been carried out (which primarily affects costs).

The EU wide ELVs are set at the level of the most stringent national legislation (at each capacity class) for existing plants (where specified). It should be noted that there may be differences between Member States in the definition of “existing” plants. A sensitivity has been run (as Option 2b) in which the EU wide ELVs are set at the level of the ELVs applied in the IED for 50 to 100 MW_{th} existing large combustion plants. The EU wide limit values are listed in Table 5.2.

Table 5.2 EU wide ELVs applied in this study

| Option | Rated thermal input capacity class | SO ₂ ELVs (mg/Nm ³) | | | NO _x ELVs (mg/Nm ³) | | | | | Dust ELVs (mg/Nm ³) | | |
|--|------------------------------------|--|-------------|--------------------|--|------------------|-------------|-------------|--------------------|---------------------------------|------------------|-------------|
| | | Other solid fuel (Note 1) | Liquid fuel | Other gaseous fuel | Biomass | Other solid fuel | Liquid fuel | Natural gas | Other gaseous fuel | Biomass | Other solid fuel | Liquid fuel |
| Option 2a: most stringent national legislation | 1-5 | 1100 | 850 | 100 | 250 | 400 | 200 | 110 | 200 | 50 | 50 | 45 |
| | 5-20 | 400 | 850 | 50 | 250 | 350 | 200 | 100 | 200 | 20 | 20 | 45 |
| | 20-50 | 400 | 500 | 50 | 250 | 350 | 200 | 100 | 200 | 20 | 20 | 40 |
| Option 2b: as per IED 50-100MW _{th} existing plants | 1-5 | 400 | 350 | 35 | 300 | 300 | 450 | 100 | 200 | 30 | 30 | 30 |
| | 5-20 | 400 | 350 | 35 | 300 | 300 | 450 | 100 | 200 | 30 | 30 | 30 |
| | 20-50 | 400 | 350 | 35 | 300 | 300 | 450 | 100 | 200 | 30 | 30 | 30 |

Note 1: This excludes biomass; combustion of biomass was assumed in this analysis to lead to zero SO₂ emissions.

The EU-wide dust ELVs applied under Option 2b are 30 mg/Nm³ for all capacity classes and fuel types. This is largely in-line with the newly adopted ‘recommendatory’ limit values of the revised Gothenburg Protocol (set out in Section 3.2.3) for solid and liquid fired boilers and process heaters of thermal input 1 MW_{th} to 50 MW_{th}: 20 mg/m³ for new plant, 50 mg/m³ for existing plant 1-5 MW_{th} and 30 mg/m³ for existing plant 5-50 MW_{th}.

It is worth noting that the application in option 2b of the ELVs from the IED for existing 50-100 MW_{th} plants does not necessarily mean that these ELVs are feasible for smaller plants 1-50 MW_{th}. There are a number of instances in the above table where the ELVs assumed in option 2b are lower (i.e. more stringent) than option 2a.

The possible techniques that could be required in order to meet the ELVs set out in Table 5.2 are identified in Table 5.3 below. A more detailed discussion of possible abatement techniques for these plants as well as details of the data sources reviewed is provided in Section 5.2.6 below.

Table 5.3 Typical techniques assumed to be applied to meet the hypothetical EU-wide ELVs for those plants / sectors modelled as having emission levels exceeding the limits

| Pollutant abatement measures | Fuel | Rated thermal input class | Option 2a: most stringent national legislation | Option 2b: as per IED 50-100MW _{th} existing plants |
|------------------------------------|---------------------|---------------------------|---|--|
| SO ₂ abatement measures | Other solid fuel | 1-5 | Co-fire with biomass, dry FGD or low sulphur coal | Dry FGD or fuel switch to natural gas |
| | | 5-20 and 20-50 | Dry FGD or fuel switch to natural gas | Dry FGD or fuel switch to natural gas |
| | Liquid fuels | 1-50 | Dry FGD | Dry FGD or low sulphur gas oil |
| | Other gaseous fuels | 1-50 | Dry FGD | Dry FGD |
| NO _x abatement measures | Biomass | 1-50 | Combustion modification, SCR or SNCR | Combustion modification, SCR or SNCR |
| | Other solid fuel | 1-50 | Combustion modification or SNCR (Note 1) | Combustion modification, SCR or SNCR (Note 1) |
| | Liquid fuels | 1-50 | SNCR or SCR | SNCR or SCR |
| | Natural gas | 1-5 | Low NO _x burner or SCR | Low NO _x burner, SNCR or SCR |
| | | 5-20 and 20-50 | Low NO _x burner, SNCR or SCR | Low NO _x burner, SNCR or SCR |
| | Other gaseous fuels | 1-50 | Low NO _x burner, SNCR or SCR | SNCR or SCR |
| Dust abatement measures | Biomass | 1-50 | Cyclone or fabric filter | Cyclone or fabric filter |
| | Other solid fuels | 1-5 | Fabric filter | Cyclone or fabric filter (Note 1) |
| | | 5-20 and 20-50 | Cyclone or fabric filter (Note 1) | Cyclone or fabric filter (Note 1) |
| | Liquid fuels | 1-50 | Cyclone or fabric filter | Cyclone or fabric filter |

Note 1: In cases where SO₂ measure of switch to natural gas is already taken up, the abatement efficiency for NO_x/dust associated with this measure is assumed, and no further NO_x/dust abatement is assumed.

5.2.4 Administrative costs

Administrative costs are estimated separately for a permitting and non permitting regime. In both cases, the number of assumed plants to which the costs apply is the total number that are not directly associated with IPPC activities. For those Member States that provided this information (Table 3.7), exact figures are utilised; for the remaining Member States the assumptions set out in Section 3.1.8 are adopted.

Cost data presented in Annex 8 of the IED impact assessment have been utilised. These costs represent the costs to operators and authorities (separately) associated with the permit application (assumed lifetime of 20 years) as well as annual on-going costs. The annual on-going costs for authorities include the costs of checking compliance, maintaining systems to make information available to the public and updating permit conditions (without amounting to a full reconsideration of the permit). The annual on-going costs for operators include providing

monitoring reports, accommodating site visits by inspectors and reporting changes in operation. The cost data presented in the IED impact assessment have been uplifted to 2011 prices from assumed 2007 price levels and are summarised below in Table 5.4. The cost of permitting is assumed to be 50% lower for those Member States already identified as permitting combustion installations 1 to 50 MW_{th} (Table 3.9). The cost data in the IED impact assessment were presented as EU average ranges from low to high costs; these EU average ranges have been retained in this analysis and no differences between Member States are assumed.

For the options assessment in which a non-permitting regime is assumed, a much lower value for administrative cost is assumed based on the results of a study by VROM which was reported in the IED impact assessment.

Table 5.4 Administrative cost data assumed in this study

| Approach | Element | Bearer | Cost per plant LOW | Cost per plant HIGH |
|---------------|-------------------------------|-------------|--------------------|---------------------|
| Permitting | One-off costs (€) | Authorities | €5,398 | €23,135 |
| | | Operators | €22,034 | €22,034 |
| | Annual costs (€/yr) | Authorities | €6,610 | €6,610 |
| | | Operators | €3,305 | €3,305 |
| | Total annualised costs (€/yr) | Authorities | €7,160 | €8,967 |
| | | Operators | €5,549 | €5,549 |
| No permitting | Total annualised costs (€/yr) | Authorities | €835 | €2,690 |
| | | Operators | €647 | €1,665 |

5.2.5 Compliance costs

To estimate the potential cost impacts of introduction of EU wide limit values, emission levels for each capacity class in each Member State are compared against the scenario limit values to determine the required emission reductions (taking into account daily ELVs being 10% higher than annual ELVs) and consequently if additional abatement measures would need to be implemented in the Member State to meet the scenario limit values. The compliance costs for implementing the abatement measures are looked up in the abatement matrices (see Section 5.2.6) and applied (per plant) utilising the numbers of plants for each fuel type. The number of plants using each fuel type in a Member State is estimated simply using the percentage fuel mix applied to the total number of plants.

5.2.6 Abatement matrix

A number of literature sources have been reviewed in order to compile information on the most pertinent and applicable abatement measures for combustion plants less than 50MW_{th} (including assessments of Best Available Techniques (BAT) for such plants) and associated pollution abatement efficiencies and costs. The following sources have been reviewed:

- JRC (2007) Small combustion installations: Techniques, emissions and measures for emission reduction. Joint Research Centre.¹¹
- AEA (2007)¹²
- (Summary of) Best Available Techniques in Small 5-50 MW Combustion Plants in Finland.¹³
- EGTEI (2010) Options for limit values for emissions of dust from small combustion installations < 50 MW_{th}.¹⁴
- VITO (2011) Beste Beschikbare Technieken (BBT) voor nieuwe, kleine en middelgrote stookinstallaties, stationaire motoren en gasturbines gestookt met fossiele brandstoffen.¹⁵
- ECN (2008) Onderbouwing actualisatie BEES B: Kosten en effecten van de voorgenomen wijziging van het besluit emissie-eisen stookinstallaties B.¹⁶
- AMEC's multi pollutant abatement measures database.¹⁷

The majority of the costs have been taken from VITO (2011) (taken as raw CAPEX and OPEX costs to allow for flexibility in annualising the data; default values of a 4% discount rate and an annualisation period of 10 years have been used in the central case) with some additional costs taken from AEA (2007) and AMEC (2009) with figures updated to 2011 prices in all cases. The abatement matrices for each of the 1-5MW_{th}, 5-20MW_{th} and 20-50MW_{th} capacity classes are included below in Table 5.5, Table 5.6 and Table 5.7 respectively. VITO (2011) includes both low and high cost scenarios, which represent the uncertainty around the cost estimates for the abatement measures, and so both the low and high costs are reproduced in this analysis. For some abatement measures the low and high costs are the same, which is assumed to reflect a single underlying cost data source, whilst for other abatement measures (SCR in particular) there is a significant difference between the low and high costs.

¹¹ <http://publications.jrc.ec.europa.eu/repository/handle/11111111/229>

¹² http://www.cafe-cba.org/assets/ippc_ec_thermal_input.pdf

¹³ Summary provided by personal communication with Competent Authority, 22.12.2008. Available in Finnish at <http://www.environment.fi/default.asp?contentid=23847&lan=fi>

¹⁴ http://www.unece.org/fileadmin/DAM/env/documents/2010/eb/wg5/wg47/Informal%20documents/Info.%20doc%209_Options%20for%20PM%20ELVs%20for%20SCI%20%20final.pdf

¹⁵ <http://www.emis.vito.be/bbt-studie-stookinstallaties-en-stationaire-motoren-nieuwe-kleine-en-middelgrote>

¹⁶ <http://www.ecn.nl/docs/library/report/2008/e08020.pdf>

¹⁷ Currently being revised. Last published version available at <http://archive.defra.gov.uk/environment/quality/air/airquality/publications/airqual-climatechange/documents/measures-database.pdf>

The cost data for fuel switching from coal to natural gas are taken from AEA (2007). The data for this abatement measure do appear to be high. No supporting information is included in AEA (2007) to describe what elements the cost data assume, but considering that almost all the total annualised cost for this measure is from the operating costs, it is assumed that the costs for this measure embody the additional commodity cost premium of natural gas over coal. The costs used may not remain representative for the EU.

The abatement measure for the reduction of SO₂ emissions from the combustion of other gaseous fuels is assumed to be as per the installation of end of pipe SO₂ treatment at liquid-firing plants (dry FGD). It is known however that some of the plants firing other gases will be at refineries and steelworks where it may be more cost effective to desulphurise fuel feedstocks rather than fit end-of-pipe SO₂ abatement. As such, for this measure, the costs that have been assumed may be an overestimate. No sensitivity analysis is undertaken on this assumption however, because the total costs for SO₂ abatement for other gaseous fuels is less than 0.5% of total compliance costs under option 2a.

Table 5.5 Abatement matrix for 1-5MW_{th} plants

| Fuel(s) | Pollutant | Measure | SO ₂ abatement (%) | NO _x abatement (%) | Dust abatement (%) | Total annual cost LOW (€/plant) | Total annual cost HIGH (€/plant) |
|--------------------------------------|-----------------|---|-------------------------------|-------------------------------|--------------------|---------------------------------|----------------------------------|
| Biomass and other solid fuels | NO _x | Combustion modification - assumed exhaust gas recirculation | 0% | 30% | 0% | € 933 | € 933 |
| Biomass and other solid fuels | NO _x | SNCR | 0% | 35% | 0% | € 2,982 | € 4,489 |
| Biomass and other solid fuels | NO _x | SCR | 0% | 80% | 0% | € 4,008 | € 19,700 |
| Biomass and other solid fuels | Dust | Cyclone | 0% | 0% | 65% | € 2,718 | € 2,898 |
| Biomass and other solid fuels | Dust | Fabric filter | 0% | 0% | 99% | € 3,697 | € 9,911 |
| Other solid fuels | SO ₂ | Co-fire biomass | 20% | 0% | 0% | € 59,493 | € 59,493 |
| Other solid fuels | SO ₂ | Fuel switch to low sulphur coal | 50% | 0% | 0% | € 5,605 | € 5,605 |
| Other solid fuels | SO ₂ | Dry FGD | 70% | 0% | 0% | € 2,074 | € 2,592 |
| Other solid fuels | SO ₂ | Fuel switch to natural gas | 100% | 50% | 99% | € 84,912 | € 84,912 |
| Liquid fuels and other gaseous fuels | SO ₂ | Dry FGD | 70% | 0% | 0% | € 1,593 | € 2,116 |
| Liquid fuels | SO ₂ | Fuel switch to 0.1% gas oil | 90% | 0% | 0% | € 37,368 | € 37,368 |
| Liquid fuels | NO _x | SNCR | 0% | 35% | 0% | € 2,874 | € 4,033 |
| Liquid fuels | NO _x | SCR | 0% | 80% | 0% | € 3,665 | € 15,124 |
| Liquid fuels | Dust | Cyclone | 0% | 0% | 65% | € 1,670 | € 2,805 |
| Liquid fuels | Dust | Fabric filter | 0% | 0% | 99% | € 3,438 | € 7,609 |
| Natural gas and other gaseous fuels | NO _x | Low NO _x burner | 0% | 30% | 0% | € 357 | € 357 |
| Natural gas and other gaseous fuels | NO _x | SNCR | 0% | 35% | 0% | € 2,873 | € 4,075 |
| Natural gas and other gaseous fuels | NO _x | SCR | 0% | 80% | 0% | € 3,688 | € 15,772 |

Table 5.6 Abatement matrix for 5-20MW_{th} plants

| Fuel(s) | Pollutant | Measure | SO ₂ abatement (%) | NO _x abatement (%) | Dust abatement (%) | Total annual cost LOW (€/plant) | Total annual cost HIGH (€/plant) |
|--------------------------------------|-----------------|---|-------------------------------|-------------------------------|--------------------|---------------------------------|----------------------------------|
| Biomass and other solid fuels | NO _x | Combustion modification - assumed exhaust gas recirculation | 0% | 30% | 0% | € 5,614 | € 5,614 |
| Biomass and other solid fuels | NO _x | SNCR | 0% | 40% | 0% | € 4,933 | € 12,476 |
| Biomass and other solid fuels | NO _x | SCR | 0% | 85% | 0% | € 10,059 | € 98,503 |
| Biomass and other solid fuels | Dust | Cyclone | 0% | 0% | 65% | € 3,604 | € 3,604 |
| Biomass and other solid fuels | Dust | Fabric filter | 0% | 0% | 99% | € 18,486 | € 44,701 |
| Other solid fuels | SO ₂ | Co-fire biomass | 20% | 0% | 0% | € 375,988 | € 375,988 |
| Other solid fuels | SO ₂ | Fuel switch to low sulphur coal | 50% | 0% | 0% | € 36,120 | € 36,120 |
| Other solid fuels | SO ₂ | Dry FGD | 75% | 0% | 0% | € 10,373 | € 13,123 |
| Other solid fuels | SO ₂ | Fuel switch to natural gas | 100% | 50% | 99% | € 545,025 | € 545,025 |
| Liquid fuels and other gaseous fuels | SO ₂ | Dry FGD | 75% | 0% | 0% | € 7,964 | € 10,747 |
| Liquid fuels | SO ₂ | Fuel switch to 0.1% gas oil | 90% | 0% | 0% | € 37,368 | € 37,368 |
| Liquid fuels | NO _x | SNCR | 0% | 40% | 0% | € 4,394 | € 10,193 |
| Liquid fuels | NO _x | SCR | 0% | 80% | 0% | € 8,323 | € 75,621 |
| Liquid fuels | Dust | Cyclone | 0% | 0% | 65% | € 3,347 | € 3,347 |
| Liquid fuels | Dust | Fabric filter | 0% | 0% | 99% | € 14,191 | € 34,317 |
| Natural gas and other gaseous fuels | NO _x | Low NO _x burner | 0% | 30% | 0% | € 1,381 | € 1,381 |
| Natural gas and other gaseous fuels | NO _x | SNCR | 0% | 40% | 0% | € 4,317 | € 10,305 |
| Natural gas and other gaseous fuels | NO _x | SCR | 0% | 80% | 0% | € 8,366 | € 78,855 |

Table 5.7 Abatement matrix for 20-50MW_{th} plants

| Fuel(s) | Pollutant | Measure | SO ₂ abatement (%) | NO _x abatement (%) | Dust abatement (%) | Total annual cost LOW (€/plant) | Total annual cost HIGH (€/plant) |
|--------------------------------------|-----------------|---|-------------------------------|-------------------------------|--------------------|---------------------------------|----------------------------------|
| Biomass and other solid fuels | NO _x | Combustion modification - assumed exhaust gas recirculation | 0% | 30% | 0% | € 14,453 | € 14,453 |
| Biomass and other solid fuels | NO _x | SNCR | 0% | 45% | 0% | € 12,335 | € 42,540 |
| Biomass and other solid fuels | NO _x | SCR | 0% | 90% | 0% | € 32,799 | € 394,013 |
| Biomass and other solid fuels | Dust | Cyclone | 0% | 0% | 65% | € 6,927 | € 6,927 |
| Biomass and other solid fuels | Dust | Fabric filter | 0% | 0% | 99% | € 44,814 | € 101,128 |
| Other solid fuels | SO ₂ | Co-fire biomass | 20% | 0% | 0% | € 922,258 | € 922,258 |
| Other solid fuels | SO ₂ | Fuel switch to low sulphur coal | 50% | 0% | 0% | € 88,599 | € 88,599 |
| Other solid fuels | SO ₂ | Dry FGD | 80% | 0% | 0% | € 41,494 | € 53,136 |
| Other solid fuels | SO ₂ | Fuel switch to natural gas | 100% | 50% | 99% | € 1,340,565 | € 1,340,565 |
| Liquid fuels and other gaseous fuels | SO ₂ | Dry FGD | 80% | 0% | 0% | € 31,855 | € 43,665 |
| Liquid fuels | SO ₂ | Fuel switch to 0.1% gas oil | 90% | 0% | 0% | € 37,368 | € 37,368 |
| Liquid fuels | NO _x | SNCR | 0% | 45% | 0% | € 10,166 | € 33,394 |
| Liquid fuels | NO _x | SCR | 0% | 85% | 0% | € 25,853 | € 302,487 |
| Liquid fuels | Dust | Cyclone | 0% | 0% | 65% | € 5,898 | € 5,898 |
| Liquid fuels | Dust | Fabric filter | 0% | 0% | 99% | € 56,766 | € 77,637 |
| Natural gas and other gaseous fuels | NO _x | Low NO _x burner | 0% | 30% | 0% | € 4,966 | € 4,966 |
| Natural gas and other gaseous fuels | NO _x | SNCR | 0% | 45% | 0% | € 9,812 | € 33,804 |
| Natural gas and other gaseous fuels | NO _x | SCR | 0% | 85% | 0% | € 26,015 | € 315,417 |

5.2.7 Emission reductions and monetised benefits

To estimate the potential emissions (benefits) impacts of introducing EU wide limit values, a first step was undertaken to split out reported total emissions (E) at each capacity class into emissions associated with each fuel combusted (E_f). This step utilises the assumed emission level associated with each fuel (EL_f) referred to in Section 5.2.2 and the fuel consumption for each fuel type (FC_f) together with the fuel-specific flue gas volumes (FGV_f , Table 4.6) according to the following equation:

$$E_f = E \times \frac{EL_f \times FC_f \times FGV_f}{\sum_f (EL_f \times FC_f \times FGV_f)}$$

The abatement efficiencies of the abatement measure selected by the model for compliance are applied to the fuel-specific emissions to estimate total emissions reduced of SO_2 , NO_x and dust. Monetisation of the emission reductions is undertaken by way of the CAFE damage cost functions.¹⁸ An additional step is necessary to estimate the $PM_{2.5}$ fraction of the dust emissions in order to utilise the CAFE damage cost function for $PM_{2.5}$ emissions; this step is undertaken by assuming the fractionation profile of $PM_{2.5}$ emissions implicit in GAINS emission projections for public power combustion.

5.3 Results

5.3.1 Main results

The main results of the modelling of the costs and benefits of meeting the options set out at the beginning of Section 5 are shown below in Table 5.8. It has not been possible to model the potential impacts of introducing product standards for the smaller plants ('alternative approach for smaller plants') due to a lack of available information such that Table 5.8 does not include a row for this alternative approach; this is discussed, however, in more detail below.

Table 5.9 shows, for the same options, the cost-benefit ratios.

¹⁸ The damage cost functions are uplifted to 2011 prices from assumed 2005 prices. Functions for Bulgaria, Cyprus and Romania are assumed to be the EU average.

Table 5.8 Summary of total additional costs and benefits (low and high)

| Option | Capacity class | Costs LOW (€m/yr) | | | Costs HIGH (€m/yr) | | | Monetised benefits LOW (€m/yr) | | | | Monetised benefits HIGH (€m/yr) | | | |
|--------|----------------|-------------------|--------------|--------------|--------------------|--------------|--------------|-------------------------------------|-------------------------------------|---------------------------------------|--------------|-------------------------------------|-------------------------------------|---------------------------------------|---------------|
| | | Compliance | Admin. | Total | Compliance | Admin. | Total | SO ₂ emission reductions | NO _x emission reductions | PM _{2.5} emission reductions | Total | SO ₂ emission reductions | NO _x emission reductions | PM _{2.5} emission reductions | Total |
| 1 | | | | 0 | | | 0 | | | | 0 | | | | 0 |
| 2a | 1-5 MW | 497 | 847 | 1,345 | 1,439 | 940 | 2,379 | 723 | 667 | 495 | 1,886 | 2076 | 1809 | 1433 | 5319 |
| | 5-20 MW | 1,187 | 227 | 1,414 | 2,471 | 252 | 2,722 | 1,573 | 985 | 567 | 3,124 | 4512 | 2666 | 1642 | 8820 |
| | 20-50 MW | 329 | 20 | 349 | 1,209 | 23 | 1,232 | 418 | 352 | 331 | 1,100 | 1203 | 957 | 960 | 3121 |
| | 1-50 MW | 2,014 | 1,095 | 3,108 | 5,119 | 1,214 | 6,333 | 2,713 | 2,004 | 1,393 | 6,110 | 7,791 | 5,432 | 4,036 | 17,260 |
| 2b | 1-5 MW | 1,355 | 847 | 2,202 | 2,208 | 940 | 3,148 | 1,063 | 642 | 518 | 2,223 | 3054 | 1740 | 1501 | 6295 |
| | 5-20 MW | 1,291 | 227 | 1,518 | 2,473 | 252 | 2,725 | 1,736 | 937 | 580 | 3,252 | 4983 | 2535 | 1682 | 9199 |
| | 20-50 MW | 335 | 20 | 355 | 1,073 | 23 | 1,096 | 419 | 327 | 346 | 1,093 | 1209 | 891 | 1004 | 3104 |
| | 1-50 MW | 2,980 | 1,095 | 4,075 | 5,754 | 1,214 | 6,968 | 3,218 | 1,906 | 1,444 | 6,568 | 9,245 | 5,166 | 4,187 | 18,598 |
| 3 | 1-5 MW | 497 | 92 | 589 | 1,439 | 262 | 1,701 | 723 | 667 | 495 | 1,886 | 2,076 | 1,809 | 1,433 | 5,319 |
| | 5-20 MW | 1,187 | 24 | 1,211 | 2,471 | 67 | 2,538 | 1,573 | 985 | 567 | 3,124 | 4,512 | 2,666 | 1,642 | 8,820 |
| | 20-50 MW | 329 | 1 | 330 | 1,209 | 4 | 1,213 | 418 | 352 | 331 | 1,100 | 1,203 | 957 | 960 | 3,121 |
| | 1-50 MW | 2,014 | 117 | 2,131 | 5,119 | 333 | 5,453 | 2,713 | 2,004 | 1,393 | 6,110 | 7,791 | 5,432 | 4,036 | 17,260 |

The results suggest that the monetised benefits outweigh the costs across all quantified options and across all capacity classes when comparing low costs with low benefits and high costs with high benefits. When comparing high costs against low benefits, the costs exceed the benefits: in option 2a for the 1-5MW_{th} and 20-50MW_{th} capacity classes; in option 2b for the 1-5 MW_{th} capacity class, and in option 3 for the 20 to 50 MW_{th} capacity class.

Option 3 can be seen to have identical benefits to option 2a but with reduced administrative burden leading to higher cost-benefit ratios.

Table 5.9 Summary of total cost-benefit ratios

| Option | Capacity class | Cost-benefit ratio | | | |
|---|----------------|-----------------------|------------|------------|------------|
| | | Low-Low | High-High | Low-High | High-Low |
| 1 | | - | - | - | - |
| 2a | 1-5 MW | 1.4 | 2.2 | 4.0 | 0.8 |
| | 5-20 MW | 2.2 | 3.2 | 6.2 | 1.1 |
| | 20-50 MW | 3.2 | 2.5 | 8.9 | 0.9 |
| | 1-50 MW | 2.0 | 2.7 | 5.6 | 1.0 |
| 2b | 1-5 MW | 1.0 | 2.0 | 2.9 | 0.7 |
| | 5-20 MW | 2.1 | 3.4 | 6.1 | 1.2 |
| | 20-50 MW | 3.1 | 2.8 | 8.7 | 1.0 |
| | 1-50 MW | 1.6 | 2.7 | 4.6 | 0.9 |
| 3 | 1-5 MW | 3.2 | 3.1 | 9.0 | 1.1 |
| | 5-20 MW | 2.6 | 3.5 | 7.3 | 1.2 |
| | 20-50 MW | 3.3 | 2.6 | 9.5 | 0.9 |
| | 1-50 MW | 2.9 | 3.2 | 8.1 | 1.1 |
| Alternative approach for smaller plants | 1-5 MW | <i>Not quantified</i> | | | |

Option 1 – Do nothing

Option 1 is to not introduce any new controls on the emissions from combustion installations less than 50MW_{th}. In the absence of introducing additional controls, Section 3.2.1 described the various EU legislation that is expected to potentially have impacts on small combustion plants. Primarily, the legislation identified may serve to (i) encourage greater efficiencies in combustion processes, and (ii) encourage switching to renewable fuels, both of which are driven by goals to reduce greenhouse gas emissions. The consequent impact on emissions of air

pollutants from the first of these two potential changes is to reduce emissions (i.e. if fuel consumption drops due to efficiency gains, total mass emissions may also reduce¹⁹). Regarding the second of the two potential changes, the fuel switching could be from a range of different fuels to a number of different biofuels (solid, liquid or gaseous), each of which potentially has different impacts on emissions of air pollutants. Existing Member State national legislation (as described in Section 3.2.2) would continue to apply.

Each of the subsequent options have been compared against this option i.e. additional costs and benefits.

Option 2a

The results for the ‘full IED’ option modelled with EU limit values set at the most stringent Member State national legislation are explored further below. As the ‘full’ IED option, this option assumes permitting: installations are assumed to fully comply with all parts of the IED, i.e. including not only aspects associated with releases to air, but also with consideration for e.g. releases to water and soil contamination. It has not been possible to assimilate costs for these wider elements within the scope of this study although these elements may be small relative to the costs of controlling emissions considering the generally relatively simple nature of installations concerned.

The ‘full IED’ option would also include a BAT regime across the EU. Due to the flexibility associated with such a BAT regime (cf. derogations under IED Article 15(4)) benefits in some Member States may be reduced if an interpretation of BAT leads to a choice of an abatement measure with less extensive emission reductions. A key driver of an alternative choice of an abatement measure may be one of cost, such that with reduced benefits there may be reduced compliance costs too. An alternative to a BAT regime would be the application of EU-wide emission limit values, which would reduce the abovementioned flexibility.

Figure 5.1 below compares the compliance and administrative costs for Option 2a across each of the capacity classes. The plot shows clearly the decreasing proportion that the administrative costs make up of the total costs with larger capacity classes. This reflects the much higher numbers of plants at lower capacity classes. For the smallest capacity class of 1-5MW_{th}, the administrative costs are modelled to comprise around half the total costs, whereas this falls to around one eighth for the 5-20MW_{th} capacity class and less than 3% for the 20 to 50MW_{th} capacity class. The percentage that the administrative costs make up of the total costs in the 20-50MW_{th} capacity class is low due to the (relatively) small number of plants in the capacity class compared to the other smaller capacity classes.

¹⁹ Total mass emissions of NO_x may not necessarily decrease depending on the measure taken.

Figure 5.1 Option 2a costs across capacity classes




Figure 5.2 plots the monetised benefits for Option 2a across the three capacity classes. The significant difference between the high and the low figures reflects the significant range in the damage cost functions for all three pollutants (SO₂, NO_x and PM_{2.5}).

Figure 5.2 Option 2a benefits across capacity classes





Figure 5.3 below compares the costs and benefits together (both plotted as positive values) across the capacity classes. The plot makes it more noticeable that the high value of costs exceeds the adjacently plotted low valuation of benefits for the 1-5MW_{th} and 20-50MW_{th} capacity classes. Only for the 5-20MW_{th} capacity class does the modelled low valuation of benefits exceed the high costs.

Figure 5.3 Option 2a costs and benefits across capacity classes




Option 2b

Option 2b is the application of alternative EU wide limit values to those applied in Option 2a. The limit values are those for existing 50-100MW_{th} plants under the IED. Table 5.2 compared the limit values applied to Option 2a and 2b; the principle differences are that the SO₂ limit values for liquid fuels are much lower under Option 2b whilst the NO_x limit values for liquid fuels are much lower for Option 2a. This principle difference is evident in the change in benefits: benefits from SO₂ emission reductions are greater for Option 2b than Option 2a but benefits from NO_x emission reductions are lower for Option 2b than Option 2a. Overall, the compliance costs under Option 2b are higher than under Option 2a.

Option 3

Option 3 is the control of emissions from the sub 50MW_{th} combustion plant sector without mandatory permitting. Therefore, whilst the compliance costs remain the same as for Option 2a (as the EU wide emission limit values are set at the same level), the administrative costs are reduced. Figure 5.4 plots the compliance and administrative costs across the three capacity classes for Option 3. By comparison of Figure 5.4 against the equivalent figure for option 2a (Figure 5.1) it is clear that by using this approach the total costs for the smallest capacity class reduce.

Figure 5.4 Option 3 costs across capacity classes



Alternative approach for smaller plants

This alternative approach for smaller plants can be considered in addition / or as an alternative to the other options considered in the study whereby product standards (essentially emission limits) could apply to new combustion plants in the lower capacity range (1-5 MW_{th}) rather than all existing plants of this size having to meet minimum ELVs. This could follow a similar framework to that already being applied under the Ecodesign Directive (see Section 3.2.1 for further details) whereby maximum emission levels are specified for different technologies and fuels. The aim of this option is to try and control emissions from these sized plants in the most cost effective manner. As the analysis presented above for the other options shows, a potentially high cost burden could be placed on these plants. In particular, under a potential permitting regime, administrative costs could make up around half of total costs for these plants.

Whilst it has not been feasible within the scope of this study to undertake a detailed assessment of the costs and benefits of this option the following points can be made:

- Product standard requirements would only apply to new units placed on the market. Therefore, the benefits of these standards would only be realised when an existing unit/plant is replaced or a new plant constructed. Estimates for the average lifetime of typical boilers in the 1-5MW_{th} capacity category range from around 20-30 years²⁰ giving an average annual turnover of around 3-5%. At an EU level, a total of around 108,000 plants (i.e. in some cases made up of more than one boiler) have been estimated in the 1-5MW_{th} capacity range which would equate to an average annual turnover of around 3,000 to 5,000 plants.

²⁰ AMEC expert estimate.

- The level at which any emission limits are set would of course influence the emission reductions that are realised. Further work would be required in order to identify the levels that would be appropriate for any standards. Under the current Ecodesign Directive, the process of design standard development includes collating preparatory studies with technical, environmental and economic analysis, reviews of product functionality, health and safety and competition assessments, followed by Impact assessment and interservice consultation, WTO notification, vote in Regulatory Committee, and further scrutiny/right of objection of the European Parliament and Council, before standards are finally adopted. A simpler framework could be established focussing solely on atmospheric emissions which should allow for a more streamlined approach. Information on current limits set by Member States and BAT definition (e.g. by Finland) provides a good starting point for considering achievable options for standards.
- Further investigations would be required to investigate the most appropriate plants to target in terms of capacity. Current discussions under the Ecodesign Directive are focussed on much smaller plants (<1MW_{th}) due to their heterogeneity in terms of design and high production volumes. Whilst there is possible scope for considering larger plants under a product standard approach, consideration would have to be given to the variation in terms of design and application (and associated emission levels) of larger plants to avoid overcomplicating matters i.e. requiring a wide range of standards to suit all designs.
- The costs of meeting a specific limit/standard should be significantly lower for new units in comparison to existing units as it allows for proper design and integration of any abatement technologies into the unit as opposed to having to retrofit technologies. In some cases, design/space constraints may even limit or prevent the retrofit of certain technologies to existing plant e.g. low NO_x burners.
- The administrative burden of such an approach would be significantly lower as the burden would rest with a small number of manufacturers/suppliers rather than each individual plant. It should be feasible for manufacturers/suppliers to pass on the additional costs of meeting any standards to operators purchasing new units.

5.3.2 Sensitivity analysis

A number of sensitivity analyses were undertaken with a view to identifying key variables among the assumptions employed in the methodology. Table 5.11 summarises the results of the sensitivity analysis. The following variables were tested as sensitivities against the main results for Option 2a:

- i. Assuming current emission levels of plants (for all three pollutants SO₂, NO_x and dust) are 20% below the applicable ELVs from the national legislation, rather than assuming as in the base case that plants operate with emissions at the level of the ELVs. The results suggest that costs drop by between 1% and 15%, whilst benefits reduce by around 20% (i.e. following the emission level reduction).
- ii. An alternative approach for some Member States / capacity classes to estimating capacity of plants was implemented. This alternative approach had no impact on the costs, but reduced benefits by 4%.

- iii. An alternative approach for some Member States / capacity classes to estimating fuel consumption of plants was implemented. This alternative approach does not impact on costs, but reduces benefits by 6%.
- iv. Capital costs of abatement measures are currently assumed to be spread over 10 years. An alternative scenario of this cost being annualised over a period 50% longer (15 years) was undertaken. This as expected reduced costs: by 4% of the low costs and by 13% of the high costs.
- v. A second demonstration of the sensitivity of results to changes in the annualisation of the capital costs was undertaken by the utilisation of a (private) discount rate of 8% rather than the (public) discount rate of 4%. This led to an increase of between 5% and 12% on costs.
- vi. Assuming 100% of plants firing liquid and gaseous fuels are engines (as opposed to 0% in option 2a). In combination with the results of option 2a, this attempts to provide an overall range rather than suggesting that all combustion plants 1MW_{th} to 50MW_{th} are engines. This sensitivity utilises cost data from VITO (2011) specific to engines as included in Table 5.10, and further assumes that the percentage emission reductions within each Member State modelled under option 2a remain.

Table 5.10 Abatement matrix for engine plants


| Fuel(s) | Pollutant | Measure | Capacity class | SO ₂ abatement (%) | NO _x abatement (%) | Dust abatement (%) | Total annual cost (€/plant) |
|---|-----------------|-----------------------------|-----------------------|-------------------------------|-------------------------------|--------------------|-----------------------------|
| Liquid fuels and gaseous fuels other than natural gas | SO ₂ | Dry FGD | 1-5MW _{th} | 70% | 0% | 0% | € 1,749 |
| | | | 5-20MW _{th} | 75% | 0% | 0% | € 8,912 |
| | | | 20-50MW _{th} | 80% | 0% | 0% | € 36,319 |
| Liquid fuels | SO ₂ | Fuel switch to 0.1% gas oil | (all) | 90% | 0% | 0% | € 37,368 |
| Liquid fuels | NO _x | SCR | 1-5MW _{th} | 0% | 90% | 0% | € 17,001 |
| | | | 5-20MW _{th} | 0% | 95% | 0% | € 69,619 |
| | | | 20-50MW _{th} | 0% | 95% | 0% | € 278,480 |
| Liquid fuels | Dust | Fabric filter | 1-5MW _{th} | 0% | 0% | 90% | € 6,837 |
| | | | 5-20MW _{th} | 0% | 0% | 90% | € 26,457 |
| | | | 20-50MW _{th} | 0% | 0% | 90% | € 95,125 |
| Natural gas and other gaseous fuels | NO _x | Advanced lean burn | 1-5MW _{th} | 0% | 50% | 0% | € 1,292 |
| | | | 5-20MW _{th} | 0% | 50% | 0% | € 6,458 |
| | | | 20-50MW _{th} | 0% | 50% | 0% | € 25,384 |
| Natural gas and other gaseous fuels | NO _x | SCR | 1-5MW _{th} | 0% | 90% | 0% | € 10,472 |
| | | | 5-20MW _{th} | 0% | 90% | 0% | € 34,947 |
| | | | 20-50MW _{th} | 0% | 90% | 0% | € 139,790 |

Table 5.11 Summary of sensitivity analyses on option 2a

| Sensitivity | Capacity class | Costs (€/yr) | | Benefits (€/yr) | |
|---|----------------|--------------|-------|-----------------|-------|
| | | Low | High | Low | High |
| Option 2a | 1-5 MW | 1,345 | 2,379 | 1,886 | 5,319 |
| | 5-20 MW | 1,414 | 2,722 | 3,124 | 8,820 |
| | 20-50 MW | 349 | 1,232 | 1,100 | 3,121 |
| i. Emission levels -20% below ELVs for all capacity classes | 1-5 MW | 1,247 | 2,024 | 1,302 | 3,672 |
| | 5-20 MW | 1,365 | 2,434 | 2,421 | 6,834 |
| | 20-50 MW | 325 | 886 | 967 | 2,748 |
| ii. Capacity estimated from ratios of capacity classes | 1-5 MW | 1,345 | 2,379 | 1,773 | 5,003 |
| | 5-20 MW | 1,414 | 2,722 | 2,976 | 8,403 |
| | 20-50 MW | 349 | 1,232 | 1,100 | 3,121 |
| iii. Fuel consumption estimated from ratios of capacity data rather than using average load factors | 1-5 MW | 1,345 | 2,379 | 2,200 | 6,205 |
| | 5-20 MW | 1,414 | 2,722 | 2,435 | 6,874 |
| | 20-50 MW | 349 | 1,232 | 1,100 | 3,121 |
| iv. Abatement measures annualised over 15 rather than 10 years | 1-5 MW | 1,305 | 2,093 | 1,886 | 5,319 |
| | 5-20 MW | 1,372 | 2,397 | 3,124 | 8,820 |
| | 20-50 MW | 318 | 1,013 | 1,100 | 3,121 |
| v. Costs discounted at 8% rather than annualised using 4% | 1-5 MW | 1,431 | 2,691 | 1,886 | 5,319 |
| | 5-20 MW | 1,462 | 2,998 | 3,124 | 8,820 |
| | 20-50 MW | 374 | 1,402 | 1,100 | 3,121 |
| vi. Liquid and gas-fired plants are engines rather than boilers | 1-5 MW | 1,817 | 2,083 | 1,888 | 5,328 |
| | 5-20 MW | 2,090 | 2,263 | 3,231 | 9,117 |
| | 20-50 MW | 854 | 1,015 | 1,154 | 3,271 |

The data presented in Table 5.11 are plotted below in Figure 5.5.

Figure 5.5 Comparison of sensitivity analyses on option 2a



6. Conclusions

6.1 Overall conclusions

The study aimed to gather additional new data on combustion installations less than 50MW_{th} to help the Commission decide whether there is a need to control emissions from these installations at an EU level.

In this study we have gathered new data from Member States on numbers, capacity, fuel consumption and emissions of combustion plants between 1MW_{th} and 50MW_{th}, and where necessary supplemented with existing data and further extrapolated from the new and existing data in order to compile a sufficiently complete dataset with which to assess possible control options. A number of assumptions were made in extrapolating data to be considered representative of the EU27; this process has led to a number of uncertainties and limitations in the underlying dataset which must be considered when assessing the results of the assessment of control options. The limitations and uncertainties are described below in Section 6.2.

Of the data received (which may not be fully representative of the EU due to the limited data gathered) the sectors in which the 1-50MW_{th} combustion plants operate are disparate, with the largest share of plants (22%) being 'other sector', followed by greenhouses (21%), public heat and electricity generation (including district heating) (18%), hospitals and universities (16%), industrial (other than food) (13%) and food industry (excluding greenhouses) (9%). For the largest capacity plants, the share for the public heat and electricity generation sector increases, whilst at smaller capacities, the share for hospitals and universities increases.

The current national legislation in place in the Member States for regulating combustion plants 1 to 50MW_{th} has been reviewed. This review has highlighted that many Member States already regulate these plants to some extent, and that many of the various pieces of legislation adopt similar approaches, i.e. setting ELVs for different fuel and capacity combinations, with some adopting a permitting approach and others adopting a general binding rules (without mandatory permits) approach. The legislative review has provided a consideration of the likely emission levels of plants operating in Member States which has helped to identify where there may be high or low impacts as a result of implementing EU wide minimum ELVs. The analysis also takes into account reductions in administrative costs for those Member States that already have a permitting regime in place.

The options for control of emissions from these combustion installations have been set in the context of the IED, but it is recognised that Article 73(2)(a) of the IED does not restrict the scope of this review in terms of the instrument through which emissions from this activity may be controlled, i.e. options for control could include regulation through IED or other legislative instruments, as well as non-legislative instruments. The control options that have been assessed are: do nothing (option 1); inclusion of 1-50MW_{th} installations as a new activity in Annex I of the IED with EU wide ELVs for emissions to air (option 2a); a variation of option 2a with alternative ELVs (option 2b); inclusion of 1-50MW_{th} installations within the IED as a separate chapter but without a full permitting regime (option 3); and an assessment of the feasibility for developing product standards for new combustion plants in line with the EcoDesign Directive as an alternative approach for smaller (1-5MW_{th}) plants. This latter alternative approach has not been assessed quantitatively in the same manner as options 2 and 3.

From the options assessment, the following key points are made:

- For the ‘full IED’ option 2, estimated average annual benefits exceed estimated average annual costs for all capacity classes investigated, with highest cost-benefit ratios for the largest capacity class (20-50 MW_{th}). For the largest and smallest capacity classes, the high end estimate of costs slightly exceeds the low valuation of benefits;
- The modelled benefits from the reduction of emissions from the 5 to 20MW_{th} capacity class are nearly three times as high as the modelled benefits from controlling emissions from the 20-50MW_{th} capacity class;
- The level at which EU wide ELVs are set affects both the compliance costs and potential benefits in particular for the smallest capacity class, but does not markedly change the benefit-cost ratio. Further sensitivity analyses on a number of the assumptions made in the modelling showed that these assumptions did not change the outcome of the benefits exceeding costs but did lead to variations in the cost-benefit ratio;
- The administrative costs associated with a permitting regime form an increasingly large component of total costs for the smaller capacity classes (around half of total costs for the 1-5MW_{th} capacity class for option 2a);
- The assessment of option 3 in which permitting of the combustion installations is dropped in favour of implementing a non-permitting approach suggests that the large administrative cost element associated with permitting a large number of smaller installations could be significantly reduced (improving the cost-benefit ratio); and
- In response to anticipated concerns over controlling emissions from a very large number of small sources in the 1 to 5 MW_{th} capacity class, an alternative (or additional) approach for these smaller plants could be the potential development of product standards that could apply to new plants in this category.

6.2 Uncertainties and Limitations

Inevitably, the development of a dataset on combustion plants 1-50MW_{th} that is based only partially on data provided by Member States and has necessarily relied on extrapolation to cover missing Member States and other data points has a number of uncertainties and limitations associated with it. The principle points to note which should be considered when reviewing the results of the assessment of control options are:

- Greater uncertainty is associated with the data and results for smaller capacity classes due to their reliance on a greater proportion of extrapolation;
- Some Member States provided data that was marked as being rough or approximate and in some cases is questionable over the realism of the figures. Gross estimates for some of the larger Member States of the EU could have a disproportionate effect on the overall figures (which are presented at EU level), and may unfortunately mask figures that may be more robust for some of the EU’s smaller Member States;

- In some cases a pragmatic approach was adopted in order to be able to produce estimates which would otherwise place unrealistic demands on data gathering. For example, although it is recognised that a number of other combustion techniques aside from boilers are used in combustion plants less than 50MW_{th}, for the purposes of the main analysis all plants were assumed to be based on boiler technologies. This assumption was made following indications from information returned from the Member States that the primary technique used is boilers (but uptake of other techniques was not negligible). This assumption has implications in:
 - Gathering of Member State ELVs: different ELVs are often set for different combustion techniques due both to their technical and emission characteristics as well as the different oxygen content of flue gases from each fuel/technique.
 - Estimating emissions: both as emission levels which have been based on ELVs, as well as annual mass emissions which have been split into those arising from each principle fuel type assumed using specific flue gas volumes, which, again vary depending on the combustion technique.

Clearly, the simplification for modelling purposes that all plants 1-50 MW_{th} are boilers is inaccurate; as such a sensitivity analysis that assumes all liquid and gas fired plants are engines has been assessed.

- The estimated costs and benefits identified in section 5 are presented as indicative figures but which are known to not take all possible costs and benefits into account. For example, the assessment of Option 2 does not consider the additional costs to installations of meeting IED requirements wider than those associated with emissions to air (e.g. emissions to water, soil contamination). However, it is considered that the primary costs for the installations considered will be associated with the regulation of emissions to air.
- Applying the CAFE damage cost functions to estimate benefits is only intended to provide an indication of the likely benefits associated with each option. There are a number of uncertainties associated with the use of the functions e.g. they do not take into account the geographical location where these reductions are taking place (for example, reductions in emissions from a plant close to a highly populated area will result in greater health benefits than a plant located further away).

6.3 Further work

Considering the limitations of the data gathered, an improved analysis of control options would result from decreasing the proportion of the EU dataset that has been extrapolated; i.e. increase the amount of raw data on the combustion plants, in particular for the smallest capacity class for which the least amount of robust data was available. Primary data gaps to fill in this regard are numbers of plants, fuel types, total emissions, and typical emission levels.

Further work should also be undertaken to investigate the alternative product standard approach that could be applied for the smallest plants in more detail in terms of the emission standards that could be set, the plant sizes that could be covered and whether or not it should take place within the framework of the Ecodesign Directive and associated process.

Appendix A

Proforma

| Category of data | | Rated thermal input category | | |
|---|---|------------------------------|----------|-----------|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | | | |
| | Public heat generation (including district heating) | | | |
| | Combined heat and power generation | | | |
| | Hospitals and universities | | | |
| | Greenhouses | | | |
| | Food industry (excluding greenhouses) | | | |
| | Industrial (please specify particular sectors) | | | |
| | Other (please specify) | | | |
| TOTAL all sectors | | | | |
| Capacity of combustion plants | MW _{th} | | | |
| Typical combustion techniques | e.g. boilers, turbines, furnaces, engines | | | |
| Total fuel consumption split by fuel type | Biomass (please specify type(s) and units) | | | |
| | Other solid fuels (coal, lignite, etc.: please specify type(s) and units) | | | |
| | Liquid (please specify type(s) and units) | | | |
| | Natural gas (please specify units) | | | |
| | Other gases (please specify type(s) and units) | | | |
| Emissions of key pollutants – annual quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | Dust or PM ₁₀ (please specify) | | | |
| | SO ₂ | | | |
| | NOx | | | |
| | HCl | | | |
| | Heavy metals | | | |
| Emissions of key pollutants – contribution to total national emissions | Expressed as a percentage | | | |
| | How do you expect this % contribution to change by 2015, 2020, 2025? | | | |
| How many plants would already be covered by the IED as 'directly associated activities'? | | | | |
| Legislative requirements. Please provide copies of the legislation or weblinks. | What is the permitting regime? | | | |
| | What ELVs are applied? | | | |
| | What are the monitoring requirements? | | | |
| | What other requirements are made? | | | |
| Current/future abatement measures | Type, costs, effectiveness | | | |

Appendix B

Summary of existing data on 20 to 50 MW_{th} combustion installations

Table B1 Summary of existing data available on the <50MW_{th} sector, which is primarily drawn from Entec (2009) which focussed on 20-50MW_{th} installations

| Data to be gathered from EU-27 | Data already available |
|---|--|
| Number of installations | <p>Entec (2009) included information on 20-50MW_{th} MCIs from 13 Member States:</p> <ul style="list-style-type: none"> ▪ BG:73 installations ▪ CZ: 136 installations (aggregation rules applied) ▪ FI: 204 boilers 20-50MW_{th} ▪ DE: 11 installations in hospitals, 15 in universities, 12 in other public institutions ▪ IT: 274 plants (unclear if installation, stack or unit level) ▪ HU: 86 installations ▪ NL: 200-400 installations ▪ PL: 360 boilers exhausting to 20-50MW_{th} stacks ▪ RO: 71 installations ▪ SK: approximately 100 installations ▪ ES: 254 installations 20-50MW_{th} ▪ SE: approximately 140 installations (de minimis not applied) ▪ UK: 451 installations <p>Ecofys (2006) had some information for (in addition to above Member States) PT, SI, IE</p> |
| Capacity (including aggregation rules) of installations | <p>Entec (2009) summarised some information on 20-50MW_{th} MCIs from selected Member States:</p> <ul style="list-style-type: none"> ▪ BG:2.3 GW_{th} ▪ CZ: 3.99 GW_{th} (taking into account aggregation rules) ▪ FI: 7 GW_{th} ▪ IT: 9.3 GW_{th} (takes into account de minimis rule) ▪ HU: 3.8GW_{th} ▪ PL: 4.8Gw_{th} ▪ UK <p>Ecofys (2006) had some information for (in addition to above Member States) PT, SI, IE</p> |
| Technology type (e.g. boiler, turbine, engine, furnace) | <p>Very little information on this. Information available:</p> <ul style="list-style-type: none"> ▪ SE: hospitals use diesel engines as backup <350h/year ▪ FI refers to boilers as comprising its installations |
| Sector in which installations operate | <p>Entec (2009) summarised some information on 20-50MW_{th} MCIs from selected Member States:</p> <ul style="list-style-type: none"> ▪ BG: split into 14 sectors (most significant are greenhouses, gas transport and district heating) ▪ FI: according to IPCC source categories (three quarters public electricity/heat production; 10% pulp/paper) |

| Data to be gathered from EU-27 | Data already available |
|---|---|
| | <ul style="list-style-type: none"> ▪ IT:8 sectors (most significant are heat production, electricity production and food)NL: 60-100 greenhouse installations ▪ SE: almost all are district heating ▪ UK <p>But this coverage is still sparse.</p> |
| Fuel use | <p>Entec (2009) summarised some information on 20-50MWth MCIs from selected Member States:</p> <ul style="list-style-type: none"> ▪ BG: (by energy, GJ): 69% nat gas, 23% HFO, 7.5% biomass, <0.5% coal ▪ CZ (by capacity, MW_{th}): approximately 66% nat gas, 26% coal/lignite, 5% liquid, 2% biomass, 1% other gas ▪ FI: (by energy) : approximately one third biomass, one third natural gas, one quarter coal and HFO, 10% other ▪ HU: primarily natural gas, secondarily oil ▪ SE: mostly biomass <p>CITL²¹ reports country level data on CO₂ emissions from combustion installations. If CO₂ emissions from >50MW combustion installations (EPRTR) were subtracted from these, we'd presumably have <50MW combustion installation CO₂ emissions, from which we may be able to estimate fuel consumption.</p> |
| Importance in the overall emissions of the key pollutants (dust, SO ₂ , NO _x , HCl, heavy metals) within the Member State and EU, as well as the projected evolution of their share | <p>Entec (2009) gathered little on this:</p> <ul style="list-style-type: none"> ▪ SE: only have typical emission concentrations in flue gases ▪ PL: emissions compared to LCPs <p>LCP inventory cumulative SO₂ NO_x and dust emissions by MW_{th} category could provide context</p> |
| Coverage under the current IPPC Directive (e.g. as directly associated activities); | <p>Only available for CZ in Entec (2009):</p> <ul style="list-style-type: none"> ▪ CZ: 32 of 136 plants already covered as DAAs |
| Permit regime, ELVs and monitoring requirements applicable for such installations under current Member State environmental legislation; | <p>Entec (2009) gathered this for some Member States:</p> <ul style="list-style-type: none"> ▪ Yes in detail for FI, DE, HU, SK, UK, FR, NL (NB: late 2008 proposed tightening of legislation may now be in force) ▪ Some limit value information in addition for BE, IT, LV, PO, PT, SI |
| Emission prevention and abatement techniques currently applied and applicable in the future, their costs and emission reduction potential; | <p>Limited information provided on current and future abatement measures. Some data provided on measures for greenhouses and small scale CHP. Specifically:</p> <ul style="list-style-type: none"> ▪ FI interpretation of BAT for MCIs. ▪ NL – general techniques used ▪ UK: IA covered total compliance costs and monetised benefits |
| Particular socio-economic situation and context in which the particular sectors operate. | <p>Some information provided for hospitals, greenhouses and district heating.</p> |

²¹ <http://dataservice.eea.europa.eu/PivotApp/pivot.aspx?pivotid=473>

Appendix C

Member State profiles

Austria

New data has been received from the authorities.

New quantitative data

The competent authority has not provided a completed proforma document, but has instead provided information on the number of **steam** boilers at a plant level; no information was provided on the number of furnaces, engines, or gas turbines. This information is taken from a database on emissions from steam boilers which meet any one of the following criteria:

- Any steam boiler >10MW;
- Any solid-fuelled (all types of solid fuel) steam boiler >2MW.
- Therefore gas and liquid-fuelled boilers <10MW and any boilers <1MW are not accounted for in the figures. It should be noted that the reporting unit varies between installations, but is generally defined by the number of stacks. Information on emissions from these plants and the split by fuel and sector were not provided. The data provided can be summarised as:

| Capacity class | Summary of data provided | Additional Comments |
|-----------------------|--|---|
| 20-50MW _{th} | Number of installations: 116 Rated thermal input: 3,711 (MW _{th}) | The estimate of the total number of plants in this size category is expected to reflect the true number. |
| 5-20MW _{th} | Number of installations: 190 Rated thermal input: 2,213 (MW _{th}) | The estimate of the total number of plants in this size category is expected to be an underestimate of the true number due to the reporting criteria (see above). The true number of plants is expected to be 2 or 3 times this figure. |

Current regulatory regime for combustion installations <50MW_{th}

Small combustion plants <50MW_{th} are regulated through two pieces of legislation²², referred to as ‘general binding rules’ which came into force in 2011. The legislation introduces limit values which apply to new plants immediately, but existing furnaces have until 2013 to apply. The pollutants regulated vary according to plant and fuel type and the ELVs are differentiated by size.

²² BGBl.II Nr. 312/2011 concerning furnaces which are not steam boilers and BGBl.Nr.19/1989 idf. BGBl. II Nr. 153/2011 concerning steam boilers and gas turbines <50 MW.

Measures and techniques for suggested for reduction of emissions from combustion installations <50MW_{th}

None received from competent authority.

Socio-economic situations or contexts

None received from competent authority.

Belgium

The competent authorities have provided a completed proforma document pertaining to the Flemish area of Belgium and two spreadsheets detailing the situation in the Brussels and Walloon regions; this information is summarised below.

New quantitative data

The competent authority has provided estimates of the number and capacity of SCPs present within Belgium, which is summarised in the table below:

| Data | Region | Reporting level | 1-5MW _{th} | 5-20MW _{th} | 20-50MW _{th} |
|--|--------------|-----------------|---------------------|----------------------|-----------------------|
| Number of plants | Brussels | Boilers | 581 | 50 | 0 |
| | Flanders | Unknown | 2,180 | 700 | 113 |
| | Wallonia | Installations | 119 | 140 | 31 |
| | Total | | 2,880 | 890 | 144 |
| Total capacity of plants (MW _{th}) | Brussels | | 1156 | 433 | 0 |
| | Flanders | | 5080 | 6630 | 3688 |
| | Wallonia | | 319 | 1478 | 956 |
| | Total | | 6,555 | 8,541 | 4,644 |

Note: When summarising the data it was assumed that all CHP plants within the Brussels region (9 plants) had a rated thermal input of 20-50MW_{th}. Information on the fuel consumption of the SCPs was not provided for the Flemish or Walloon regions. Information on the emissions from SCPs was not provided for the Flemish or Brussels regions.

Data on the emissions from SCPs <50MW_{th} in the Walloon region in 2009 were provided: PM₁₀ (393 t), Dust (487 t) SO_x (1,726 t), NO_x (5,176 t).

Current regulatory regime for combustion installations <50MW_{th}

Flanders

Legislative requirements for stationary engines are described in chapter 31 of VLAREM II (Order of the Flemish Government of 1 June 1995 concerning General and Sectoral provisions relating to Environmental Safety). Legislative requirements for combustion installations are described in chapter 43 of VLAREM II²³.

Brussels

Legislative requirements for stationary engines are described in, 'Ordonnance relative au permis d'environnement (1997)',²⁴.

²³<http://navigator.emis.vito.be> (English language translations of the relevant sections are not available).

Walloonia

A reference to the relevant legislation was not provided by the competent authority, but a summary table of the relevant ELVs was included.

Measures and techniques for suggested for reduction of emissions from combustion installations <50MW_{th}

Flemish BAT-studies (Combustion installations and stationary engines (2002) and New, small and medium combustion installations, stationary engines and gas turbines on fossil fuels (2011))²⁵, describe BAT for SCPs. No information was received concerning the Brussels and Flemish regions.

Socio-economic situations or contexts

None received from competent authority.

Bulgaria

No information has been received from the competent authority to date.

²⁴ http://www.ejustice.just.fgov.be/cgi_loi/change_lg.pl?language=fr&la=F&cn=1997060533&table_name=loi (English language translations of the relevant sections are not available).

²⁵ www.emis.vito.be/vlaamse-bbt-studies (English language translations of the relevant sections are not available).

Cyprus

The competent authority has provided a completed proforma document; the information relates to the year 2009. The proforma is included below without amendment.

| Category of data | | Rated thermal input category | | |
|--|---|--|---------------------------|---|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | | | 3 Internal Combustion Engines 38MWth each installed to cover peak demand |
| | Public heat generation (including district heating) | -- | -- | -- |
| | Combined heat and power generation | -- | -- | -- |
| | Hospitals and universities | 2 (1-2.5MWth) | 11 | -- |
| | Greenhouses | | | |
| | Food industry (excluding greenhouses) | 29 (2.5-5MWth) + 53 (1-2.5MWth) = 82 | 15 | -- |
| | Industrial (please specify particular sectors) (Pharmaceutical Ind., Rendering Plants, Laundries, Carton industries, Production of Paints & Varnishes, Cement Plants etc) | 26 (2.5 - 5 MWth) + 62 (1 - 2.5MWth) = 88 | 10 | -- |
| | Other (please specify) | | | |
| TOTAL all sectors | | 170 | 36 | 3 |
| Total capacity of combustion plants | MW _{th} | 195MW _{th} (2.5 - 5 MWth) + 175MW _{th} Plants (1 - 2.5MWth) = Total 370MW _{th} | Total 260MW _{th} | Total 114MW _{th} |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | Boilers | Boilers | Internal Combustion Engines |
| Total fuel consumption split by fuel type | Biomass (please specify type(s) and units) | 2580tn | | NA |
| | Other solid fuels (coal, lignite, etc.: please specify type(s) and units) | -- | | NA |
| | Liquid (please specify type(s) and units) | Gasoil: 11830tn Fuel Oil: 23330tn | | Fuel Oil: 30100tn |
| | Natural gas (please specify units) | NA | | NA |
| | Other gases (please specify type(s) and units) | Liquefied Petroleum Gas (LPG): 5160tn | | NA |
| Emissions of key pollutants – annual | Dust or PM ₁₀ (please specify) | 65tn (Total Suspended Particulates) (reference CLRTAP 2009 data) | | 44tn |

| | | | |
|--|--------------------------------|---|--|
| quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | SO ₂ | 972tn (reference CLRTAP 2009 data) | 494tn |
| | NOx | 212tn (reference CLRTAP 2009 data) | 1959tn |
| | HCl | No available data | |
| | Heavy metals | Pb Emissions (tn) 0.034 Cd Emissions (tn) 0.001 Hg Emissions (tn) 0.00024 As Emissions (tn) 0.002 Cr Emissions (tn) 0.026 Cu Emissions (tn) 0.015 Ni Emissions (tn) 0.528 Se Emissions (tn) 0.000028 Zn Emissions (tn) 0.023 (reference CLRTAP 2009 data) | 0,006 0,001 0,00037 0,005 0,003 0,007 0,313 0,003 0,108 |
| Emissions of key pollutants – contribution to total national emissions | Expressed as a percentage | Total Suspended Particulates 1.14% SO ₂ 5.4% NOx 1.1% Pb 1.26% Cd 1.2% Hg 0.16% As 0.95% Cr 6.19% Cu 0.4% Ni 4.2% Se 0.02% Zn 0.4% | Total Suspended Particulates 0.77% SO ₂ 2.8% NOx 10% Pb 0.22% Cd 1.25% Hg 0.24% As 2.4% Cr 0.71 % Cu 0.18 % Ni 2.5% Se 2.3% Zn 1.86% |
| How do you expect this % contribution to change by 2015, 2020, 2025? | | Not estimated | The 3 Internal Combustion Engines will not be in operation in 2015. |
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | | 39 | 7 3 |
| Legislative requirements. Please provide copies of the legislation or weblinks. | What is the permitting regime? | According to the Legislation in Cyprus and specifically «The Control of Atmospheric Pollution (Non Licensable Installations) Regulation of 2004 (P.I. 170/2004)» and «The Control of Atmospheric Pollution (Non Licensable Installations) (Amendment) Regulations of 2008 (P.I. 198/2008)» (web link http://www.mlsi.gov.cy/dli) no Air Emission Permit is Required for combustion installations with a total rated thermal input below 50MW. Operators of these combustion installations are obliged to | |
| | | comply with certain emission limit values and associated operating conditions set in the relevant legislation mentioned above. The 3 Internal Combustion Engines (ICE Engines) 38MWth each are installed within an IPPC installation. Therefore a permit was granted for these 3 ICE Engines. | |

| | | |
|--|--|---|
| | <p>What ELVs are applied?</p> | <p>For combustion installations with a total rated thermal input between 5-50MWth the following ELVs are applied:</p> <p><u>For the use of liquid fuels</u></p> <ul style="list-style-type: none"> • Bacharach smoke scale 3 (at the same time the CO₂ content in air emissions should be greater than 10% v/v and the O₂ content less than 7,5% v/v) • Total Dust 100mg/Nm³ (O₂ reference value 3%) • CO 100mg/Nm³ (O₂ reference value 3%) <p><u>For the use of coal or wood or olive seeds</u></p> <ul style="list-style-type: none"> • Total Dust 100mg/Nm³ (O₂ reference value 7% for coal and 11% for wood or olive seeds) • CO 200mg/Nm³ (O₂ reference value 7% or coal and 11% for wood or olive seeds) <p>For combustion installations with a total rated thermal input less than 5MWth the following ELVs are applied:</p> <p><u>For the use of liquid fuels</u></p> <ul style="list-style-type: none"> • Bacharach smoke scale 3 (at the same time the CO₂ content in air emissions should be greater than 10% v/v and the O₂ content less than 7,5% v/v) <p><u>For the use of coal or wood or paper or olive seeds</u></p> <ul style="list-style-type: none"> • Total Dust 150mg/Nm³ (O₂ reference value 7% for coal, 11% for wood or olive seeds and 12% for paper) • CO 200mg/Nm³ (O₂ reference value 7% or coal and 11% for wood or olive seeds) <p>For the 3 ICE Engines an Air Emission Permit was granted since these engines are installed within an IPPC installation. These ICE Engines were permitted to operate for a limited time every year in order to cover peak demand. The operation of these 3 ICE Engines is expected to be terminated in 2015.</p> <p>The ELVs included in the Air Emission Permit are the following (O₂ reference value 15%):</p> <p>Dust: 50mg/Nm³ NOx: 1800 mg/Nm³ SO₂: 565mg/Nm³ CO: 120 mg/Nm³</p> |
| | <p>What are the monitoring requirements?</p> | <p>a) For the 3 Internal Combustion Engines operator is obliged to perform continuous emission monitoring for NOx and SO₂ and spot measurement for dust every 3 months.</p> <p>b) For combustion installations < 5MWth, operators are obliged to monitor at least once/year after maintenance</p> <p>c) For combustion installations >5MWth, monitoring is carried out by the Competent Authority in Cyprus.</p> |
| | <p>What other requirements are made?</p> | |
| <p>Abatement measures – current and future</p> | <p>Type, costs, effectiveness</p> | |

Czech Republic

The competent authority has provided a completed proforma document which is included below without amendment.

| Category of data | | Rated thermal input category ²⁶ | | |
|--|--|--|---------------------------|--|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation / Public heat generation (including district heating) / Combined heat and power generation | 708 | 213 | 65 |
| | Hospitals and universities (and administrative institutions and office buildings) | 1263 | 159 | 32 |
| | Greenhouses | 0 | 0 | 0 |
| | Food industry (excluding greenhouses) | 369 | 98 | 22 |
| | Mineral oil refineries | 1 | 0 | 1 |
| | Coal processing | 3 | 2 | 0 |
| | Production and processing of iron and steel | 33 | 7 | 2 |
| | Production and processing of non-ferrous metals | 11 | 3 | 2 |
| | Chemical industry | 30 | 21 | 6 |
| | Pulp, paper and printing | 43 | 9 | 5 |
| | Agriculture, silviculture and aquaculture | 445 | 10 | 1 |
| | Other industry | 1162 | 226 | 39 |
| TOTAL all sectors | | 4068 | 748 | 175 |
| Total capacity of combustion plants | MW _{th} | 8492 | 7166 | 5247 |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | Mostly gas furnaces (80%) | Mostly gas furnaces (80%) | Mostly gas furnaces (60%) and coal boilers (20%) |
| Total fuel consumption split by fuel type | Biomass (TJ) | 1 783 | 1 784 | 2 945 |
| | Other solid fuels, mostly brown coal (TJ) | 1 777 | 1 146 | 6 012 |
| | Liquid, mostly heating oil (TJ) | 676 | 439 | 2 035 |
| | Gas, mostly natural gas (TJ) | 74 552 | 213 958 | 18 710 |
| Emissions of key pollutants – annual quantities emitted to air | Dust (t.p.a.) | 321.08 | 307.54 | 223.37 |
| | SO ₂ (t.p.a.) | 1806.8 | 1248.28 | 4080.44 |

²⁶ Based on processed raw data from national database Register of Emissions and Air Pollution Sources (REZZO – REAPS)

| | | | | |
|--|--|--|---------|---------|
| (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) Emissions of key pollutants – contribution to total national emissions | NOx (t.p.a.) | 1941.45 | 1958.28 | 2235.54 |
| | HCl (kt.p.a.) | | | |
| | Heavy metals | | | |
| | Dust (%) | 0,5 | 0,49 | 0,36 |
| | SO2 (%) | 1,04 | 0,72 | 2,35 |
| | NOx (%) | 0,77 | 0,78 | 0,89 |
| | How do you expect this % contribution to change by 2015, 2020, 2025? | Predictions focused on these particulars combustion plants are not available. | | |
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | | 20 – 30% (estimate) | | |
| Legislative requirements. Please provide copies of the legislation or weblinks. | What is the permitting regime? | General requirements in the Act. No. 86/2002 Coll., on air protection. Links: http://www.mzp.cz/www/platnalegislativa.nsf/d79c09c54250df0dc1256e8900296e32/ed2986242760af40c125754b003bb44a?OpenDocument | | |
| | What ELVs are applied? | ELVs and other requirements are included at Government Ordinance No. 146/2007 Coll. In wording No. 476/2009 Coll. http://www.mzp.cz/www/platnalegislativa.nsf/d79c09c54250df0dc1256e8900296e32/362eb9e24eac4fe5c1257313003fcf03?OpenDocument | | |
| | What are the monitoring requirements? | Monitoring requirements are included at Decree No. 205/2009 Coll. In wording No. 17/2010 Coll. http://www.mzp.cz/www/platnalegislativa.nsf/d79c09c54250df0dc1256e8900296e32/f91856a80bc1a55bc12576270027caf2?OpenDocument | | |
| | What other requirements are made? | Pollutant emission (NOx, CO, SO2, dust) are due to charge (see The Act on air protection) | | |
| Abatement measures – current and future | Type, costs, effectiveness | Reduction of Dust – End-of-pipe-techniques are not applied (mostly natural gas as fuel). Reduction of SO2 – End-of-pipe-techniques are not applied (in case of new requirement existing older boiler using solid fuels would be change to gas boilers). Reduction ox NOx – End-of-pipe-techniques are not applied. General requirements on boilers and also fuel quality (Decree No. 13/2009 Coll.) Links http://www.mzp.cz/www/platnalegislativa.nsf/d79c09c54250df0dc1256e8900296e32/2a03bd8dfcc00b90c12576420036c832?OpenDocument | | |

As part of the consultation on the final report, the Czech authorities have provided details of new legislation that has been introduced for small combustion plants. The information provided is presented below:

“There is a new air protection act No. 201/2012 Coll. (in force from 01/09/2012), which replaces older legislation. According to new air protection act (§ 11) the regional authority is permitting stationary sources of air emission over 0,3 MW. Studies of dispersion, expert evaluation, rules for operation and compensation measures are required for this sources (all as a part of operation permit).

Expert evaluations are not applied on

- *sources under codes 1.1 – 1.4 of the annex 2 of the air protection act, which uses natural gas as the only fuel and is below 5 MW.*
- *cases of permit changes without changes of output, capacity and emissions (but they are applicable if emission limit is replaced by technical condition replacing emission limit).*

Studies of dispersion are not required

- *for sources under codes 1.1 – 1.4 of the annex 2 of the air protection act if natural gas is used in sources bellow 5 MW.*
- *for sources under codes 3.1 of the annex 2 of the air protection act if natural gas is used in sources bellow 1 MW.*
- *in cases of permit changes without impact on pollution (decision on impact of changes is on permitting authority – if there are any doubts on this issue).*

Compensation measures are not applied

- *if natural gas is used in sources 0,3 – 5 MW.*
- *if the type of source has not specific emission limit for particular pollutant in legislation*
- *if the contribution of the source to the level of pollution is bellow the value in legislation”*

Denmark

No information has been received from the competent authority to date.

Estonia

The competent authority has provided a completed proforma document which is included below without amendment.

| Category of data | | Rated thermal input category | | |
|---|---|------------------------------|----------|-----------|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | 4 | 2 | |
| | Public heat generation (including district heating) | 172 | 55 | 14 |
| | Combined heat and power generation | | | |
| | Hospitals and universities | 5 | 2 | |
| | Greenhouses | | | - |
| | Food industry (excluding greenhouses) | 34 | 19 | 1 |
| | Industrial (Textiles-, wood-, chemicals- , metal products-, furniture-, etc industry) | 127 | 34 | 6 |
| | Other (oil terminals, asphalt concrete plants, farms, heating in service sector etc) | 195 | 62 | 8 |
| TOTAL all sectors | | 537 | 174 | 29 |
| Total capacity of combustion plants | MW _{th} | 1 202,6 | 1 793,7 | 1 024,5 |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | boilers | boilers | boilers |
| Total fuel consumption split by fuel type (liquid and solid fuels are in tonnes; gaseous fuels are in thousand cubic meter) | Biomass (firewood, wood waste) | 173391.9 | 205 847 | 232 227.2 |
| | Other solid fuels (coal, peat, oil shale etc) | 14486.3 | 12 445.8 | 43 173.9 |
| | Liquid (light heating oil, shale oil, waste oil, diesel fuel) | 28376.4 | 33 471.2 | 15 196 |
| | Natural gas | 70193.3 | 132 500 | 62 783.2 |
| | Other gases (pyrolysis process gases, biogas) | 7432.2 | 4 474.5 | 1 96341 |
| Emissions of key pollutants – annual quantities emitted to air (tonnes). Please provide the reference (OSIS- air emissions data system for the point sources) | TSP (tonnes) | 1141.5 | 1014.6 | 1386.6 |
| | SO ₂ (tonnes) | 4431.2 | 648 | 3990.7 |
| | NO _x (tonnes) | 552.5 | 754.6 | 529.4 |
| | HCl (tonnes) | 0.86 | 0.038 | - |
| | Heavy metals: | | | |
| | Pb (kg) | 206.4 | 252.8 | 345.3 |
| | Hg(kg) | 1.4 | 1.9 | 2.8 |
| | Ni (kg) | 71.1 | 32.4 | 96.7 |
| | As (kg) | 30.3 | 29.6 | 39.7 |
| | Cd (kg) | 5.2 | 4.8 | 6 |
| | Cr (kg) | 40.7 | 90.1 | 47.2 |
| | Cu (kg) | 22.3 | 19.2 | 27.7 |
| Zn (kg) | 403.1 | 441.8 | 363.1 | |
| Emissions of key pollutants – contribution to total | Expressed as a percentage | | | |
| | TSP (%) | 4.1 | 3.6 | 4.9 |

| | | | | |
|--|--|---|---|--|
| national emissions | SO ₂ (%) | 8.1 | 1.2 | 7.3 |
| | NO _x (%) | 1.9 | 2.6 | 1.8 |
| | HCl | - | - | - |
| | Heavy metals: | - | - | - |
| | Pb | 0.7 | 0.9 | 1.2 |
| | Hg(%) | 0.0 | 0.0 | 0.0 |
| | Ni (%) | 1.4 | 0.7 | 2.0 |
| | As (%) | 0.4 | 0.4 | 0.5 |
| | Cd (%) | 1.1 | 1.0 | 1.3 |
| | Cr (%) | 0.6 | 1.2 | 0.7 |
| | Cu (%) | 0.4 | 0.4 | 0.5 |
| | Zn (%) | 1.0 | 1.1 | 0.9 |
| | How do you expect this % contribution to change by 2015, 2020, 2025? Preliminary prognosis for NECD 100% - 2005 level. Prognosis done as % from total emissions is not best measure. Prognose in actual data (m3, kg, t etc) are much better. | 2015 – 2009 level 2020 - % will rise, because total emissions should be reduced 2025 - % will rise, because total emissions should be reduced | 2015 – 2009 level 2020 - % will rise, because total emissions should be reduced 2025 - % will rise, because total emissions should be reduced | 2015 + all substances (new pyrolysis plant launched 2011) 2020 - 29% SO₂; +4,8% NO_x, PM_{2,5} - 26% 2025 – 2020 level |
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | NA, but if small CP operates inside IED annex 1 categories (except 1.1) it is included into integrated permit | NA, but if small CP operates inside IED annex 1 categories (except 1.1) it is included into integrated permit | NA, but if small CP operates inside IED annex 1 categories (except 1.1) it is included into integrated permit | |
| Legislative requirements. Please provide copies of the legislation or weblinks. https://www.riiqiteataja.ee/a/kt/105072011026 | What is the permitting regime? | Ambient air pollution permit without time limit, but regular overview required | Ambient air pollution permit without time limit, but regular overview required | Ambient air pollution permit without time limit, but regular overview required |
| | What ELVs are applied? | Set into individual permit | Set into individual permit | Set into individual permit |
| | What are the monitoring requirements? | Regular measurements (substances, frequency etc) set into individual | Regular measurements (substances, frequency etc) set into individual | Regular measurements (substances, frequency etc) set into individual permit. |

| What other requirements are made? | permit. Commonly no need | permit. Commonly no need | Commonly no need |
|--|--|--|---|
| Abatement measures – current and future Type, costs, effectiveness | Set into individual permit application and in the permit. Depending of fuel type. Mainly dedusting precipitators (cyclons) Cost - NA | Set into individual permit application and in the permit. Depending of fuel type. Mainly dedusting precipitators (cyclons) Cost - NA | Set into individual permit application and in the permit. Chem pyrolysis of oil shales also scubbers (for SO2) Cost - NA |

Finland

The competent authority has provided a completed proforma document which is included below without amendment. Data is taken from the Finnish national emission register VAHTI for the year 2010 which records fuel consumption and emissions at the boiler level. The underpinning boiler-level dataset has also been provided which also includes (x,y,z) coordinates for each emission source, which allows an estimation of the number of combustion **plants**. It should be noted that data concerning larger units (20 - 50 MW) is more accurate than data concerning smaller units.

| Category of data | | 1-5MWth | 5-20MWth | 20-50MWth |
|--|--|--------------------|-----------|------------|
| Number of combustion plants in each sector | Public electricity generation + Public heat generation (including district heating) + Combined heat and power generation | 127 | 157 | 158 |
| | Hospitals and universities | data not available | | |
| | Greenhouses + Food industry (incl. fodder production) | 10 | 5 | 1 |
| | Industrial: | | | |
| | Mining industry | 3 | | 1 |
| | Chemical industry | 13 | 11 | 2 |
| | Metal industry | 5 | 3 | 5 |
| | Pulp and paper manufacturing | 3 | 7 | 9 |
| | Mechanical forest industry | 11 | 9 | 1 |
| | Construction industry | 4 | 2 | |
| | Other industry | 13 | 7 | 3 |
| | Other (waste incineration, wastewater treatment plants, fuel storage) | 7 | 4 | 1 |
| | TOTAL all sectors | 196 | 205 | 181 |
| Total capacity of combustion plants | MWth | 550 | 2,100 | 6,430 |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | boilers | boilers | boilers |
| Total fuel consumption split by fuel type | Biomass (typically wood- based) (GJ) | 3,787,000 | 4,403,000 | 9,018,000 |
| | Other solid fuels (typically peat, some coal in larger units) (GJ) | 1,225,000 | 1,493,000 | 8,044,000 |
| | Liquid (typically heavy oil, | 1,242,000 | 5,489,000 | 10,173,000 |

| | | | | |
|---|--|--|-----------|-----------|
| | some light oil) (GJ) | | | |
| | Natural gas (GJ) | 2,140,000 | 4,024,000 | 8,932,000 |
| | Other gases (biogas, waste gas, liquid gas) (GJ) | 457,000 | 550,000 | 1,107,000 |
| Emissions of key pollutants – annual quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | Dust | 220 | 320 | 320 |
| | SO ₂ | 560 | 1800 | 3680 |
| | NO _x | 1680 | 1940 | 4420 |
| | HCl | data not available | | |
| | Heavy metals | detailed data not available | | |
| Emissions of key pollutants – contribution to total national emissions | Expressed as a percentage | | | |
| | How do you expect this % contribution to change by 2015, 2020, 2025? | | | |
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | | 0 | 2 | 140 |
| Legislative requirements. Please provide copies of the legislation or weblinks. | What is the permitting regime? | Please refer to links to legislation ²⁷ | | |
| | What ELVs are applied? | | | |
| | What are the monitoring requirements? | | | |
| | What other requirements are made? | | | |
| Abatement measures – current and future | Type, costs, effectiveness | Implementation of the IED | | |

²⁷ Environmental Protection Act (English translation): <http://www.finlex.fi/en/laki/kaannokset/2000/en20000086.pdf>

Government Decree on environmental protection requirements for energy production installations with a total fuel capacity below 50 MW (in Finnish): <http://www.finlex.fi/fi/laki/alkup/2010/20100445>

Appendix 1 (in Finnish) Liite 1: <http://www.finlex.fi/data/sdliite/liite/5794.pdf>

France

The competent authority has provided a completed proforma document which is included below without amendment. The data has been estimated from the national emission inventory using a specific methodology to distinguish emissions from SCPs in the rated thermal input categories. It should be noted that no data is available for plants 2MW_{th}.

| Category of data | | Rated thermal input category | | |
|--|--|---|---|-----------|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation Public heat generation (including district heating) Combined heat and power generation Hospitals and universities Greenhouses Food industry (excluding greenhouses) Industrial (please specify particular sectors) Other (please specify) | No data available for each sector Estimated 20 000 combustion plants for all sectors from 2MWth to 20 MWth Roughly 1500 combustion plants from 20MWth and 50MWth | | |
| | TOTAL all sectors | | | |
| Total capacity of combustion plants | MW _{th} | No data available but if we apply the maximum thermal input of the range, we have roughly 20 000 x 20MWth = 400 000 MWth and 1500 x 50MWth = 75 000 MWth the maximum capacity can be estimated to 475 000MWth | | |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | No data available. | | |
| Total fuel consumption split by fuel type | Biomass (please specify type(s) and units) Other solid fuels (coal, lignite, etc.: please specify type(s) and units) Liquid (please specify type(s) and units) Natural gas (please specify units) Other gases (please specify type(s) and units) | Only data of the distribution between fuel are available (this data includes domestic plants) : biomass : 15% charbon : 2% liquified gas :4% natural gas :56% heavy fuel oil : 1% domestic heating fuel oil : 20% | | |
| Emissions of key pollutants – annual | Dust or PM ₁₀ (please specify) SO ₂ | 2-20MWth : 3739 t (dust) (3% to the total national emission) 2-20MWth : 18480 t (36% to the total national | 2479 t (dust) (0,2% to the total national emission) | |

| | | | |
|--|--|--|---|
| quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | NOx | emission) 2-20MWth : 36242 t (3% to the total national emission) | 8034 t (2% to the total national emission) 10284 t (0,9% to the total national emission) |
| | HCl | No data available | |
| | Heavy metals | No data available | |
| | Emissions of key pollutants – contribution to total national emissions | Expressed as a percentage | - |
| | How do you expect this % contribution to change by 2015, 2020, 2025? | - | |
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | | We estimate that 15% of the combustion plants between 2 and 20MWth are in a IPPC site. No data can be given for the range of 20 to 50MWth (we only estimate than 46% of the combustion plants above 20MWth are in a IPPC site). | |
| Legislative requirements. Please provide copies of the legislation or weblinks. | What is the permitting regime? | Below 2MWth : no permitting regime From 2 to 20MWth : declaration regime (for more information about this system, see : http://www.installationsclassees.developpementdurable.gouv.fr/-Declaration-system-.html) Above 20MWth : permit system with authorization (see http://www.installationsclassees.developpement-durable.gouv.fr/-Permitsystem-.html), except for combustion plants using non conventional fuels (ie other than natural gas, domestic fuel oil, heavy fuel oil, liquified gas, peat or biomass) for which the authorization system begins at 0,1 MWth Note that for combustion plants using specific biogas, there is a specific regimes from 0,1MWth (Declaration, registration, Authorization) – ELV in progress | |
| | What ELVs are applied? | <p>Below 2MWth : no ELV but reference values given during the emission measurement (from 400 kW to 2MW) or the emission evaluation (from 4 kW to 400kW) :</p> <p>from 400kW to 2MW : http://www.legifrance.gouv.fr/affichTexte.do?cidTexte=JORFTEXT000021217870&fastPos=4&fastReqId=35865877&categorieLien=cid&oldAction=rechTexte</p> <p>from 4 kW to 400 kW : http://www.legifrance.gouv.fr/affichTexte.do?cidTexte=JORFTEXT000021217854&fastPos=3&fastReqId=1770373592&categorieLien=cid&oldAction=rechTexte</p> <p>From 2 to 20MWth, ELV are given in the following text : http://www.legifrance.gouv.fr/affichTexte.do?cidTexte=JORFTEXT00000202304&fastPos=1&fastReqId=365744241&categorieLien=cid&oldAction=rechTexte</p> <p>Above 20MWth, ELV are given in differents texts, depending on the date of the first permit and of the type of combustion technique : boiler, before 2002 : http://www.legifrance.gouv.fr/affichTexte.do;jsessionid=B94586878FD81FCD5676DD728CF0426D.tpdjo10v_2?cidTexte=JORFTEXT000000248169&dateTexte=20111125</p> <p>boiler, after 2002 : http://www.legifrance.gouv.fr/affichTexte.do?cidTexte=JORFTEXT000000779198&fastPos=2&fastReqId=1937199808&categorieLien=cid&oldAction=rechTexte</p> <p>boiler, after 2010 : http://www.legifrance.gouv.fr/affichTexte.do?cidTexte=JORFTEXT000022818485&fastPos=10&fastReqId=1398058617&ategieLien=cid&oldAction=rechTexte turbines and engines : http://www.ineris.fr/aida/?q=consult_doc/navigation/2.250.190.28.8.2179/4/2.250.190.28.6.13</p> | |
| | What are the monitoring requirements? | Cf weblinks below :the monitoring requirements mainly depends on the type of fuel and of the total rated thermal input | |

| | | |
|---|-----------------------------------|---|
| | What other requirements are made? | Cf weblinks below : national legislation set provisions regarding air emission, water emission, risk, waste,... |
| Abatement measures – current and future | Type, costs, effectiveness | - |

Germany

New data has been received from the authorities.

New quantitative data

The competent authority has provided a completed proforma document. This has been filled out using three data sources: fuel consumption and emissions data from the national emission inventory for 1-50MW_{th} plants; numbers of combustion plants and their fuel consumption for 20-50 MW_{th} plants derived from ETS data; numbers of solid biomass plants in public electricity and/or heat production each in 1-5MW_{th} and 5-20MW_{th} capacity classes, derived from statistical data on renewable energy plant data; and approximate aggregate number, capacity and fuel consumption of biogas plants. The authorities have noted that the data provided exclude estimates of numbers of plants in the sub 20MW_{th} classes firing fuels other than solid biomass. The data provided can be summarised as:

| Capacity class | Summary of data provided |
|-----------------------|---|
| 1-50MW _{th} | Total fuel consumption of 755,000 TJ, split into five categories: natural gas (56%), biomass (23%), liquid fuels (11%), other solid fuels (7%) and other gases (3%). Emissions of SO ₂ : 30kt; NO _x : 63kt; PM ₁₀ : 3.8kt; mercury: 130kg |
| 20-50MW _{th} | 658 installations, split into sectors as: public heat generation (38%), industrial (29%), public electricity generation (19%), food industry excluding greenhouses (7%), other (4%), hospitals/universities (3%), CHP (2%). Total capacity of 22.5 GW _{th} Total fuel consumption of 151,000 TJ, split into five categories: natural gas (77%), other solid fuels (9%), biomass (7%), liquid fuels (4%), and other gases (3%). |
| 5-20MW _{th} | 118 solid biomass fired plants, 55% of which are for public electricity generation, and the rest for public heat generation. |
| 1-5MW _{th} | 400 solid biomass fired plants, 90% of which are for public heat generation, and the rest for public electricity generation |
| 0-5MW _{th} | 6,000 biogas engine plants (mostly less than 1MW _e or 3MW _{th}) of aggregate capacity more than 2.3 GW _e (~ 6.6GW _{th} if assume 35% efficient), and which consumes around 130,000 TJ/yr. |

Current regulatory regime for combustion installations <50MW_{th}

Revised legislation²⁸ covering small combustion plants firing solid fuels including biomass came into force in 2010. The legislation introduces limit values (including for existing plants) and makes the use of best available technology mandatory. The TA Luft²⁹ also sets out monitoring requirements.

²⁸ Erste Verordnung zur Durchführung des Bundes-Immissionsschutzgesetzes (Verordnung über kleine und mittlere Feuerungsanlagen - 1. BImSchV) , which came into force on 22 March 2011

²⁹ First General Administrative Regulation Pertaining the Federal Immission Control Act (Technical Instructions on Air Quality Control – TA Luft) (24 July 2002)

Measures and techniques for suggested for reduction of emissions from combustion installations <50MW_{th}

For the smallest plants (1-5MW_{th}) the use of fabric filters is suggested for dust abatement. For 5-20MW_{th} plants, the abatement options suggested for smaller plants are also valid, as well as dry sorbent injection for SO₂ emissions and low NO_x burners for NO_x emissions. For 20-50MW_{th} plants, in addition to the abatement options suggested for smaller plants, electrostatic precipitators (ESPs) are also suggested for dust abatement, as well as spray dryers for SO₂ abatement and Selective Non-Catalytic Reduction (SNCR) for NO_x abatement.

Socio-economic situations or contexts

None received from competent authority.

Hungary

No information has been received from the competent authority to date.

Ireland

The competent authority responded on the current regulation of SCPs:

‘Such plant may be regulated as an associated activity if on an IPPC/IED installation, or is associated with an activity licensable under the Air Pollution Act 1987, or may otherwise be regulated under planning legislation. Under IPPC ELVs and monitoring requirements will be set in accordance with BAT and to prevent breaches of EQS. For other regimes, it is not possible to specify how ELVs or monitoring requirements might be set.’

No other data or comments have been provided.

Italy

The only information received from the competent authority relates to current legislation relevant for these plants. Since permits for such installation are issued at Regional and Provincial level, according to art. 269 of Decree n. 152 of the 3rd of April 2006 (<http://www.camera.it/parlam/leggi/deleghe/06152dl.htm>), as amended by the Decree n. 128 of the 29th of June 2010 (<http://www.camera.it/parlam/leggi/deleghe/testi/10128dl.htm>), data are not collected at central level (ELVs to be applied are reported in Annex I and IX to part V of the above mentioned Decree, depending on type and size of the installations), although many competent authorities constantly update their websites with the permits issued.

Latvia

No information has been received from the competent authority to date.

Lithuania

No information has been received from the competent authority to date.

Luxembourg

No information has been received from the competent authority to date.

Malta

No information has been received from the competent authority to date.

Netherlands

The competent authority has provided a completed proforma document which is included below without amendment. The figures presented are a rough estimate, based on several sources. The data are aggregated at the plant (stack) level, in line with the 'common stack' approach under the LCP Directive.

| Category of data | | Rated thermal input category | | |
|--|---|--------------------------------------|--------------------------------------|--------------------------------------|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | 5 | 5 | - |
| | Public heat generation (including district heating) | - | - | - |
| | Combined heat and power generation (excl. decentral CHP in other sectors) | 90 | 5 | - |
| | Hospitals and universities | 1800 | 30 | |
| | Greenhouses | 2400 | 2000 | 60 |
| | Food industry (excluding greenhouses) | 300 | 40 | 10 |
| | Industrial (excl. food industry, incl. oil and gas) | 700 | 120 | 40 |
| | Other services sectors | 1700 | 50 | |
| TOTAL all sectors | | 6995 | 2250 | 110 |
| Total capacity of combustion plants | MWth | 21000 | 23000 | 3700 |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | boilers, engines, turbines, furnaces | boilers, engines, turbines, furnaces | boilers, engines, turbines, furnaces |
| Total fuel consumption split by fuel type | Total [PJ] | 132 | 160 | 40 |
| | Wood [PJ] | 1 | | |
| | Coal [PJ] | 0 | | |
| | Oil [PJ] | 0 | | |
| | Natural gas (please specify units) | 130 | 160 | 40 |
| | Waste [PJ] | 1 | 0 | |
| Emissions of key pollutants – annual quantities emitted to | Other gases (please specify type(s) and units) | | | |
| | Dust or PM10 (please specify) | | | |

| | | | | |
|---|--|--|--|--|
| air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | SO2 NOx [kton] HCl Heavy metals | 8.6 | 11.7 | 1.6 |
| Emissions of key pollutants – contribution to total national emissions | Expressed as a percentage How do you expect this % contribution to change by 2015, 2020, 2025? | 3% NOx emission of gas engines will go down. Share in total NOx emissions will increase due to NOx emission reduction in transport. | 4% NOx emission of gas engines will go down. Share in total NOx emissions will increase due to NOx emission reduction in transport. | 1% NOx emission of gas engines will go down. Share in total NOx emissions will increase due to NOx emission reduction in transport. |
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | | Limited number, only in industry | Limited number, only in industry | Limited number, only in industry |
| Legislative requirements. Please provide copies of the legislation or weblinks. | What is the permitting regime? What ELVs are applied? What are the monitoring requirements? What other requirements are made? | See document 'Legislative requirements' | | |
| Abatement measures – current and future | Type, costs, effectiveness | SCR on gas engines, NSCR on wood, Low NOx burners | SCR on gas engines, SCR on wood, Low NOx burners | SCR on gas engines, SCR on wood, Low NOx burners |

New quantitative data

The competent authority has provided a completed proforma document. This has been filled out using rough estimates from several sources that were not specified; the data was aggregated in line with the 'common stack' approach under LCP directive. The data provided can be summarised as³⁰:

| Capacity class | Summary of data provided |
|-----------------------|--|
| 20-50MW _{th} | 110 installations split into sectors as: CHP (1%) Hospitals and universities (26%) food industry (excl greenhouses) (4%), greenhouses (34%), Industrial (excluding food industry, but including oil and gas) (10%), Other sectors (24%) Total capacity of 21 GW _{th} Total fuel consumption of 132,000 TJ, split between 3 categories: natural gas (98%), Wood (1%), Waste (1%) |
| 5-20MW _{th} | 2250 installations, split into sectors as: Hospitals and universities (1%) food industry (excl greenhouses) (2%), greenhouses (89%), Industrial (excluding food industry, but including oil and gas) (5%), Other sectors (2%) Total capacity of 23 GW _{th} Total fuel consumption of 160, 000 TJ all natural gas |

³⁰ Of these installations 27 are already covered by IPPC as directly associated activities.

| Capacity class | Summary of data provided |
|---------------------|--|
| 1-5MW _{th} | <p>6995 installations, split into sectors as: food industry (9%), greenhouses (55%), Industrial (excluding food industry, including oil and gas) (36%)</p> <p>Total capacity of 3.7 GWth</p> <p>Total fuel consumption of 40,000 TJ, all natural gas</p> |

Current regulatory regime for combustion installations <50MW_{th}

Emission-regulations for boilers, stationary engines and turbines under 50 MW_{th} have been in force since April 1st 2010. The legislation introduces emissions limit values (ELVs) dependent upon installation type and fuel input, it does not make the use of best available technology mandatory. There are two regimes, summarised as;

- BEES A and B (for existing installations)
- BEMS³¹ (for installations installed after April 1st 2010)

Measures and techniques for suggested for reduction of emissions from combustion installations <50MW_{th}

For the smallest plants (1-5MW_{th}) the use of Selective Catalytic Reduction (SCR) on gas engines, Non-Selective Catalytic Reduction (NSCR) for wood burning installations and Low NO_x burners for NO_x emissions. For 5-20MW_{th} plants and 20-50MW_{th} plants, the abatement options suggested for smaller plants are also used, except SCR is used for wood burning installations.

Socio-economic situations or contexts

None received from competent authority.

³¹ <http://www.infomil.nl/english/subjects/air/combustion-plants/bems-sets-new/>

Poland

The competent authority has provided a completed proforma document which is included below without amendment. The national inventory was used as the primary data source for completing the proforma. It should be noted that plants < 20MWth are in the most part not included as these plants are not regulated under national legislation.

| Category of data | | Rated thermal input category | | |
|--|--|------------------------------|----------|---|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | | | |
| | Public heat generation (including district heating) | | | |
| | Combined heat and power generation | | | |
| | Hospitals and universities | | | |
| | Greenhouses | | | |
| | Food industry (excluding greenhouses) | | | |
| | Industrial (please specify particular sectors) | | | |
| | Other (please specify) | | | |
| | TOTAL all sectors | | | 241 |
| Total capacity of combustion plants | MW _{th} | | | 8135 |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | | | Boilers mostly |
| Total fuel consumption split by fuel type | *Biomass (please specify type(s) and units) * biomass definition comply with ETS definition so it's different than definition used in directives 2001/80/WE and 2010/75/UE. | | | 198942,87 m3 742,55 Mg Biomass as waste (code: 030105) 17288,73 Mg |
| | Other solid fuels (coal, lignite, etc.: please specify type(s) and units) | | | Black coal – 1635657,77 Mg Sub-bituminous coal – 4156,94 |
| | Liquid (please specify type(s) and units) | | | Diesel oil – 1,8 Mg Furnace oil – 2713,29 Mg Heavy oil – 1489,77 Mg Light oil – 1266,42 Mg |
| | Natural gas (please specify units) | | | Natural gas – 110394793,00 m3 Natural gas with high methane concentration – 169357962,58 m3 Nitrogen-rich natural gas – 29646907,00 |
| | Other gases (please specify type(s) and units) | | | Coke-oven gas – |

| | | | |
|---|---|--|--|
| | | | 78186400,00 m3 Mine gas – 3640060,00 Biogas – 3518776,00 |
| Emissions of key pollutants – annual quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | Dust or PM ₁₀ (please specify) | | Dust – 3832 t |
| | SO ₂ | | 11866 t |
| | NOx | | 5629 t |
| | HCl | | - |
| | Heavy metals | | - |
| Emissions of key pollutants – contribution to total national emissions | Expressed as a percentage | | |
| | How do you expect this % contribution to change by 2015, 2020, 2025? | | |
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | | | |
| Legislative requirements. Please provide copies of the legislation or weblinks. | <p>What is the permitting regime?</p> <p>What ELVs are applied?</p> <p>What are the monitoring requirements?</p> <p>What other requirements are made?</p> | <p>Environmental Protection Law³² in art. 180 states that emission to air from the installation should be regulated in appropriate permit (single media or integrated permit). ELVs for combustion plants are set according to Emission standards regulation³³ and in case of installation with rated thermal capacity > 50 MW also BAT requirements are taken into account. Regulation concerning emission standards from installation covers combustion plants with rated thermal capacity > 1 MW and following pollutants (dust, SO₂, NOx) with consideration of age and thermal capacity of installation.</p> <p>Cases when permit for emission to air is not required are listed in relevant regulation³⁴. Operators of some installations for which permit is not required are obliged to make a notification to the competent authority. Such a cases are also listed in relevant regulation³⁵.</p> <p>Operators of combustion plants for witch permit for emission to air is required should monitor emission of following pollutants SO₂, NO₂, dust and CO. Continuous monitoring is required for installations with rated thermal capacity > 100 MW. Periodical monitoring should be conducted at least twice a year (one in winter season and another in summer season). In case of installations working temporary in 6 months period one measurement (during the period when installation is operated) in a year is required. Detailed provisions concerning monitoring requirements are set in relevant regulation³⁶.</p> | |
| Abatement measures – current and future | Type, costs, effectiveness | Answers presented in tables below | |

³² <http://isap.sejm.gov.pl/DetailsServlet?id=WDU20080250150>

³³ <http://isap.sejm.gov.pl/RelatedServlet?id=WDU20052602181&type=13&isNew=true>

³⁴ <http://isap.sejm.gov.pl/DetailsServlet?id=WDU20101300881>

³⁵ <http://isap.sejm.gov.pl/DetailsServlet?id=WDU20101300880>

³⁶ <http://isap.sejm.gov.pl/DetailsServlet?id=WDU20082061291>

1 – 5 MW

| | Abatement equipment | Abatement efficiency % | Pollutant |
|---|-----------------------|------------------------|-----------|
| 1 | Multicyclone | 80 - 95 | dust |
| 2 | Dry cyclone | 70 - 95 | dust |
| 3 | Bag filters | 85 (one case) | dust |
| 4 | Dust settling chamber | 20 - 32 | dust |
| 5 | Wet scrubber | 96,36 (one case) | dust |

5 – 20 MW

| | Abatement equipment | Abatement efficiency % | Pollutant |
|---|--------------------------------|------------------------|-----------|
| 1 | Multicyclone | 70 - 98 | dust |
| 2 | Dry cyclone | 72,3 – 99,2 | dust |
| 3 | Dry electrostatic participator | 90 – 98,3 | dust |
| 4 | Bag filters | 75 – 99,9 | dust |
| 5 | Dust settling chamber | 20 (one case) | dust |
| 6 | SCR | 20 | NOx |

20 – 50 MW

| | Abatement equipment | Abatement efficiency % | Pollutant |
|---|--------------------------------|------------------------|-----------------|
| 1 | Multicyclone | 72 – 97,7 | dust |
| 2 | Dry cyclone | 44 – 92 | dust |
| 3 | Dry electrostatic participator | 85 – 98 | dust |
| 4 | Bag filters | 95 – 99,9 | dust |
| 5 | Dust settling chamber | 30 (one case) | SO ₂ |
| 6 | Limestone semi dry process | 50 (one case) | SO ₂ |
| 7 | Limestone dry process | 73 (one case) | dust |

Please find below information concerning two sources provided by Economic Society Polish Power Plants.

| Category of data | | Rated thermal input category | | |
|---|--|------------------------------|--|-----------|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | | | |
| | Public heat generation (including district heating) | | | |
| | Combined heat and power generation | | | |
| | Hospitals and universities | | | |
| | Greenhouses | | | |
| | Food industry (excluding greenhouses) | | | |
| | Industrial (please specify particular sectors) | | | |
| | Other (please specify) | | Ignition boiler (working less than 160h/a) | |
| | TOTAL all sectors | | 1 | |
| Total capacity of combustion plants | MW _{th} | | 6,7 | |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | | boiler | |
| Total fuel consumption split by fuel type | *Biomass (please specify type(s) and units) * biomass definition comply with ETS definition so it's different than definition used in directives 2001/80/WE and 2010/75/UE. | | | |
| | Other solid fuels (coal, lignite, etc.: please specify type(s) and units) | | | |
| | Liquid (please specify type(s) and units) | | Light oil – 30228 Mg | |
| | Natural gas (please specify units) | | | |
| | Other gases (please specify type(s) and units) | | | |
| Emissions of key pollutants – annual quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | Dust or PM ₁₀ (please specify) | | 0 Mg | |
| | SO ₂ | | 0,023 Mg | |
| | NOx | | 0,207 Mg | |
| | HCl | | | |
| | Heavy metals | | | |

| Category of data | | Rated thermal input category | | |
|--|---|------------------------------|----------|-----------|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | | | |
| | Public heat generation (including district heating) | | | |
| | Combined heat and power generation | | | |

| | | | | |
|---|--|--|--|--|
| | Hospitals and universities | | | |
| | Greenhouses | | | |
| | Food industry (excluding greenhouses) | | | |
| | Industrial (please specify particular sectors) | | | |
| | Other (please specify) | | Donkey boiler | |
| | TOTAL all sectors | | 1 | |
| Total capacity of combustion plants | MW _{th} | | 6,7 | |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | | Boiler OR-35 | |
| Total fuel consumption split by fuel type | <p>*Biomass (please specify type(s) and units) * biomass definition comply with ETS definition so it's different than definition used in directives 2001/80/WE and 2010/75/UE.</p> <p>Other solid fuels (coal, lignite, etc.: please specify type(s) and units)</p> <p>Liquid (please specify type(s) and units)</p> <p>Natural gas (please specify units)</p> <p>Other gases (please specify type(s) and units)</p> | | Black coal – 312,7 Mg | |
| Emissions of key pollutants – annual quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | <p>Dust or PM₁₀ (please specify)</p> <p>SO₂</p> <p>NO_x</p> <p>HCl</p> <p>Heavy metals</p> | | <p>2,360 Mg</p> <p>2,652 Mg</p> <p>1,250 Mg</p> | |
| Emissions of key pollutants – contribution to total national emissions | <p>Expressed as a percentage</p> <p>How do you expect this % contribution to change by 2015, 2020, 2025?</p> | | | |
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | | | Directly connected with installation covered by IED | |
| Legislative requirements. Please provide copies of the legislation or weblinks. | <p>What is the permitting regime?</p> <p>What ELVs are applied?</p> <p>What are the monitoring requirements?</p> <p>What other requirements are made?</p> | | <p>NO₂ – 400 mg/Nm³</p> <p>SO₂ – 1300 mg/Nm³</p> <p>Dust – 400 mg/Nm³</p> <p>Once a year , boiler was operated 83,6 h in 2010</p> | |
| Abatement measures – current and future | Type, costs, effectiveness | | | |

Portugal

No information has been received from the competent authority.

Romania

No information has been received from the competent authority.

Slovakia

New data has been received from the authorities.

New quantitative data

The competent authority has provided a database of SCPs in Slovakia which shows the number of SCPs disaggregated by capacity class and NACE code for the year 2010. The combined fuel consumption and combined emissions of air pollutants for all SCPs is also provided. This information can be summarised as follows:

| Capacity class | Summary of data provided |
|-----------------------|---|
| 1-5MW _{th} | <p>2,023 plants (boilers) in total: Electricity and heat supply (20%), Education and health facilities (17%), crop and animal production (2%), Manufacture of food products (3%), Other manufacturing (industrial) (23%) and other (35%). Total capacity of installations: 4,334 MW_{th}.</p> <p>Main fuels combusted: 89% natural gas, 5% biomass, 1% brown coal, 1% biogas, 1% paper based waste, 1% agricultural/food waste.</p> <p>Emissions of – Dust: 269t, SO₂: 161t, NO_x: 699t, Heavy metals: 1.15t. It has not been possible to express these figures as a proportion of the total emissions in Slovakia.</p> |
| 5-20MW _{th} | <p>600 plants (boilers) in total: Electricity and heat supply (52%), Education and health facilities (9%), crop and animal production (1%), Manufacture of food products (5%), Other manufacturing (industrial) (22%) and other (11%). Total capacity of installations: 5,393 MW_{th}.</p> <p>Main fuels combusted: 85% natural gas, 9% biomass, 3% hard coal, 2% paper based waste.</p> <p>Emissions of – Dust: 269t, SO₂: 192t, NO_x: 1,185t, Heavy metals: 2.42t. It has not been possible to express these figures as a proportion of the total emissions in Slovakia.</p> |
| 20-50MW _{th} | <p>93 plants (boilers) in total: Electricity and heat supply (49%), Education and health facilities (9%), crop and animal production (1%), Manufacture of food products (8%), Other manufacturing (industrial) (32%) and other (1%). Total capacity of installations: 2,815 MW_{th}.</p> <p>Main fuels combusted: 60% natural gas, 25% biomass, 10% paper based waste, 2% brown coal, 2% other solid fuels, 1% agricultural/food waste.</p> <p>Emissions of – Dust: 112t, SO₂: 223t, NO_x: 845t, Heavy metals: 4.585t. It has not been possible to express these figures as a proportion of the total emissions in Slovakia.</p> |

Note: Numbers of installations in each sector were aggregated on the basis of NACE codes.

Current regulatory regime for combustion installations <50MW_{th}

The competent authority has indicated that existing legislation exists which included ELVs for SCPs 1-50MW_{th}, although a reference to the legislation has not been provided. The ELVs are differentiated by fuel type, size of plant, age of plant and combustion technique. The legislation also sets out monitoring requirements.

Measures and techniques for suggested for reduction of emissions from combustion installations <50MW_{th}

No information has been received from the competent authority.

Socio-economic situations or contexts

No information has been received from the competent authority.

Slovenia

The competent authority has provided a completed proforma document which is included below without amendment. In addition, the competent authority stated that SCPs are not currently required to hold a permit, but that ELVs and other requirements have been taken from TA Luft and entered into national legislation in 2009³⁷.

| Category of data | | Rated thermal input category | | |
|---|---|---|---|---|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | | | |
| | Public heat generation (including district heating) | | | |
| | Combined heat and power generation | | | |
| | Hospitals and universities | | | |
| | Greenhouses | | | |
| | Food industry (excluding greenhouses) | | | |
| | Industrial (please specify particular sectors) | | | |
| | Other (please specify) | | | |
| TOTAL all sectors | | 222* | 119** | 18 |
| Total capacity of combustion plants | MW _{th} | 535* | 1266** | 501 |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | boilers & turbines & furnaces & engines | boilers & turbines & furnaces & engines | boilers & turbines & furnaces & engines |
| Total fuel consumption split by fuel type | Biomass (please specify type(s) and units) | n.a | n.a | n.a |
| | Other solid fuels (coal, lignite, etc.: please specify type(s) and units) | n.a | n.a | n.a |
| | Liquid (please specify type(s) and units) | n.a | n.a | n.a |
| | Natural gas (please specify units) | n.a | n.a | n.a |
| | Other gases (please specify type(s) and units) | n.a | n.a | n.a |
| Emissions of key pollutants – annual quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | Dust | 126* | 126** | 23,5 |
| | SO ₂ | 107* | 193** | 137 |
| | NO _x | 926* | 794** | 541 |

³⁷ <http://www.uradni-list.si/1/content?id=102899> No English translation is available.

| | | | | |
|---|--|-----|-----|-----|
| Emissions of key pollutants – contribution to total national emissions | HCl | n.a | n.a | n.a |
| | Heavy metals | n.a | n.a | n.a |
| | Expressed as a percentage | n.a | n.a | n.a |
| | How do you expect this % contribution to change by 2015, 2020, 2025? | n.a | n.a | n.a |
| How many plants would already be covered by the IE Directive as ‘directly associated activities’? | | | | |
| Legislative requirements. Please provide copies of the legislation or weblinks. | What is the permitting regime? | | | |
| | What ELVs are applied? | | | |
| | What are the monitoring requirements? | | | |
| | What other requirements are made? | | | |
| Abatement measures – current and future | Type, costs, effectiveness | | | |

* Only boilers using solid fuel

** Not included boilers using natural gas below 10 MW

Sweden

New quantitative data

The competent authority has provided a dataset which shows for each boiler in Sweden: capacity (MW), electricity produced, percentage fuel consumption by fuel type, combustion technique, abatement technique and emissions of NO_x for the year 2009.

No fuel consumption was reported, but AMEC has calculated fuel input using the supplied total heat and electricity output by assuming efficiency factors (agreed with the Swedish authorities).

The data provided can be summarised as:

| Capacity class | Summary of data provided |
|-----------------------|---|
| 1-5MW _{th} | 4 plants with a combined capacity of 16 MW _{th} . Information supplied on the generation techniques employed was found to include errors, but it can be said that the majority of plants are CHP or steam boilers, with a small number of gas turbines and electricity generating plants. The fuel consumption for all plants is 46TJ: Solid biofuels (100%). Total NO ₂ emissions: 39t. |
| 5-20MW _{th} | 173 plants with a combined capacity of 1,802 MW _{th} . Information supplied on the generation techniques employed was found to include errors, but it can be said that the majority of plants are CHP or steam boilers, with a small number of gas turbines and electricity generating plants. The fuel consumption for all plants is 40TJ: Gas (5%), Fuel-oil (1%), peat (1%), waste (21%), and solid biofuel (72%). Total NO ₂ emissions: 2,923t |
| 20-50MW _{th} | 105 plants with a combined capacity of 2,975 MW _{th} . Information supplied on the generation techniques employed was found to include errors, but it can be said that the majority of plants are CHP or steam boilers, with a small number of gas turbines and electricity generating plants. The fuel consumption for all plants is 59TJ: Gas (16%), Fuel-oil (7%), peat (3%), waste (27%), and biofuel (47%). Total Total NO ₂ emissions: 6,723t |

Current regulatory regime for combustion installations <50MW_{th}

The competent authority has stated that permit conditions for <50MW_{th} plants in Sweden are decided on a case-by-case basis; the only General Binding Rules for ELVs applied are from the LCP and Waste Incineration Directives.

Measures and techniques suggested for reduction of emissions from combustion installations <50MW_{th}

The dataset provided by the Swedish competent authorities also included details of the NO_x emission reduction measures applied at each plant, which is summarised in the table below.

| NO _x Abatement measure | 1-5MW _{th} (% of plants) | 5-20MW _{th} (% of plants) | 20-50MW _{th} (% of plants) |
|-----------------------------------|-----------------------------------|------------------------------------|-------------------------------------|
| Waste Gas Recirculation (WGR) | 0% | 32% | 13% |
| Unspecified | 0% | 1% | 2% |
| Low-NO _x burners | 0% | 3% | 3% |
| Combustion modification | 25% | 4% | 1% |
| Over Fire Air (including rotary) | 0% | 3% | 4% |

| NO_x Abatement measure | 1-5MW_{th} (% of plants) | 5-20MW_{th} (% of plants) | 20-50MW_{th} (% of plants) |
|---|---|--|---|
| ECOTUBE (injection of reducing agents) | 0% | 3% | 1% |
| ROTAMIX (injection of reducing agents) | 0% | 1% | 1% |
| Selective Catalytic Reduction | 0% | 1% | 1% |
| Selective Non-Catalytic Reduction | 0% | 30% | 73% |

Socio-economic situations or contexts

None received from competent authority.

Spain

The competent authority has provided a completed proforma document which is included below without amendment.

| Category of data | | Rated thermal input category | | |
|---|---|------------------------------|----------|------------------|
| | | 1-5MWth | 5-20MWth | 20-50MWth |
| Number of combustion plants in each sector | Public electricity generation | | | 104 |
| | Public heat generation (including district heating) | | | |
| | Combined heat and power generation (include cogeneration and combustion in industries different from the ones on the industrial category below) | | | 422 |
| | Hospitals and universities | | | |
| | Greenhouses | | | |
| | Food industry (excluding greenhouses) | | | |
| | Industrial (please specify particular sectors: mineral oil refinery, coke ovens, metal ore roasting or sintering, pig iron or steel, cement clinker or lime, glass included glass fibre, ceramic products by firing, pulp, paper and board) | | | 604 |
| Other (please specify) | | | | |
| TOTAL all sectors | | | | 1130 |
| Total capacity of combustion plants | MW _{th} | | | |
| Typical combustion techniques in use | e.g. boilers, turbines, furnaces, engines | | | |
| Total fuel consumption split by fuel type | Biomass (please specify type(s) and units) | | | |
| | Other solid fuels (coal, lignite, etc.: please specify type(s) and units): coal | | | 26 installations |
| | Liquid (please specify type(s) and units): fuel oil | | | 10 installations |
| | Natural gas (please specify units) | | | |
| | Other gases (please specify type(s) and units) | | | |
| Emissions of key pollutants – annual quantities emitted to air (tonnes). Please provide the reference (e.g. CLRTAP, CITL, other please specify) | Dust or PM ₁₀ (please specify) | | | |
| | SO ₂ | | | |
| | NO _x | | | |
| | HCl | | | |
| | Heavy metals | | | |
| Emissions of key pollutants – contribution to total national emissions | Expressed as a percentage | | | |
| | How do you expect this % contribution to change by 2015, 2020, 2025? | | | |

| | | | |
|--|----------------------------|--|---|
| How many plants would already be covered by the IE Directive as 'directly associated activities'? | | | |
| <p>Legislative requirements. Please provide copies of the legislation or weblinks.</p> <p>What is the permitting regime?</p> <p>What ELVs are applied?</p> <p>What are the monitoring requirements?</p> <p>What other requirements are made?</p> | | | <p>Permits in accordance to de IE Directive for > 50 MW installations</p> <p>The ELV reflected in their permits. They are set out by the competent authorities of the Autonomous Communities. This values are based on national o local legislation.</p> |
| Abatement measures – current and future | Type, costs, effectiveness | | |

United Kingdom

The UK competent authority have responded that their most up-to-date information on SCPs is contained in AEA (2007), 'Assessment of the benefits and costs of the potential application of the IPPC Directive (EC/96/61) to industrial combustion installations with 20-50 MW rated thermal input'. More up-to-date information on the number of plants and fuel combustion in Northern Ireland has been provided, but this cannot be used to update the existing information, as data in AEA (2007) is not disaggregated between countries within the UK.

Current regulatory regime for combustion installations <50MW_{th}

In the UK MCIs (20-50 MW_{th}) are generally regulated under Part B of the LAPPC regime; Part B activities are regulated at a local authority level and only for air pollution emissions. A number of guidance documents have been developed by Defra for 20-50 MW_{th} combustion installations:

- PG 1/3 (95) – for boilers and furnaces of 20 – 50 MW_{th};
- PG 1/4 (95) – for gas turbines of 20 -50 MW_{th}.

The Scottish Environmental Protection Agency (SEPA) have indicated that plants below 20MW_{th} would not normally be regulated unless the plant was directly associated to a Part A activity under IPPC. The majority of plants less than 20MW_{th} are regulated by Local Authorities under the statutory nuisance provisions included in the Environmental Protection Act 1990³⁸; this regulation does not stipulate mandatory ELVs.

Typical abatement equipment currently in use (provided by DALKIA)

- Gas boilers typically use low NO_x burners (150mg/nm³)
- Gas turbines can get down to 25mg/Nm³ NO_x or lower
- Gas engines operate at 250mg/Nm³ NO_x, although NO_x vs. CO is an issue in engines particularly
- For oil boilers, low sulphur fuel and technology similar to gas burners is acceptable
- Small biomass plants use high efficiency cyclones, over fire air and possibly economisers and combustion air preheat to maximise efficiency and improve combustion

³⁸ <http://www.legislation.gov.uk/ukpga/1990/43/part/III/enacted>

Appendix D

Industry responses to the proforma

Dalkia

IED emission control on plant rated below 50MW

Have Dalkia begun to consider the impact of the IED on its operations?

Dalkia have been closely involved with the IED and prior legislation (IPPC, EPR, LCPD and WID for example) and are continuing to liaise with customers, suppliers and other industry groups on the implementation of the IED. We have begun the process of understanding how our existing permitted sites will be impacted by the new directive. In particular, we have a number of sites covered by the LCPD which will need to adhere to new (lower) emission limit values in the future. It is likely that these new limits will imply an improvement notice on these permitted sites. In some instances, meeting this improvement notice will only be achievable through investment.

The number of sites in our portfolio impacted by the current de minimis level (50MW) is relatively limited and the large scale of the associated activity means it is usually better placed than smaller sites to invest in Best Available Techniques. If the limit was to drop to a lower MW level, the effect of the IED will be felt much more widely across our portfolio and the wider UK industry. This would force many sites to incur the considerable cost of permitting, both direct and administrative, and often pay for plant or abatement techniques that might be totally disproportionate for the site, either in terms of size, space, cost of installation, or cost of operation. These additional costs would typically represent a much larger fraction of the overall operating cost of smaller sites relative to that for existing IPPC sites.

How the sector (<50MW combustion plant) is likely to develop going forward; what growth do you foresee in these units? and in which industrial sectors?

It is difficult to foresee how each industrial sector will evolve in the coming years. The manufacturing industry in the chemical, pharmaceutical and metal sectors appears to be shrinking in the UK (Alcan are closing their aluminium smelter because they cannot afford the environmental compliance demands) and even food and drink plants are less widespread, with breweries closing and other foods being imported.

Nonetheless, assuming the nature of industry remains broadly consistent in the UK, most sites on the gas network will likely continue to rely on gas-fired steam boilers in the short to medium term (the 10 tonne 10 bar boiler being the standard unit in many factories). Modern gas-fired systems are very efficient, have low emissions, and are less costly to operate so this 'combustion sector' is likely to remain and grow as the gas network evolves and industry locates itself close to the network.

Sites currently off the gas network are typically reliant on heavy fuel oil or coal. As the cost and environmental implications of running these sites grow, more will likely look to

biomass to help reduce their operational costs. Biomass is unlikely to be a complete solution for these sites with fossil-fuel boilers usually being required to provide top-up and back-up steam since biomass boilers require more maintenance and are often not suited to rapid load modulation which is typical in industry. This need for a wider variety of boiler solutions will often lead to an increase in the total boiler capacity for a given site off the gas network (thus pulling some of these sites with an equivalent thermal demand into the IPPC net). In the long term, this will lead to a closure of industrial sites in rural towns (not supplied with gas) and a concentration of industry closer to cities.

One sector which will continue to have many combustion plants in the 20MW to 50MW range is the health sector. Hospitals typically require redundancy of boiler plant to maintain supply in all eventualities. They also require back-up generators to maintain electricity supply during mains failure. Furthermore, they regularly incorporate CHP in order to reduce energy costs and limit their carbon exposure. A 2MWe gas engine will typically add 6MW of thermal input to a site. As a result, it would not be uncommon to see a hospital with a 12MW peak thermal demand have over 40MW of thermal input capacity to ensure the energy needs of the site are delivered continuously and at the lowest possible cost. It would seem inappropriate to impose permitting obligations on such a site, especially since onsite CHP is a carbon-friendly solution.

Comment on the policy landscape of EU policies that will impact on these plants (e.g. the impact of the Renewable Heat Incentive in UK)

There are a number of different policies which are impacting upon the operation of plant, which include:

Renewable Heat Incentive and the potential implication when Phase II commences to place emissions limits of 30g/GJ for particulates and 150g/GJ for NOx. We understand from Government decisions on the RHI that these limits are intended for sub 20MWth installations. It shall be challenging to achieve these limits unless significant post combustion cleanup of the emissions takes place - which is likely to absorb a significant proportion of the 1p/kWh RHI payment for 'Large Commercial Biomass' and almost certainly defer some organisations from progressing a biomass solution.

We have experienced an increasing degree of regulation and costs surrounding CO2 emissions. We have single installations which are within the scope of the EU Emissions Trading System, The CRC Energy Efficiency Scheme and potentially, the Carbon Price Support system. Whilst we accept the need to impose an absolute cap on carbon emissions, we would prefer some legislative simplification to lower our own (administrative) cost burden.

Typical technologies and fuel types used; currently and in future

Natural gas is the current fuel of choice and will remain so in the short to medium term. This means no sulphur, very limited particulates, and relatively easy NOx management, in boiler plant and gas engines/turbines.


Biomass plants are increasing in popularity and some fall into the IPPC already because of the fuel source (e.g clean waste wood combustion plant > 3MWth). A whole range of possible pollutants and abatement issues can arise with biomass plant since fuel composition can vary and the solid fuel combustion process is often not as simple and regular as that for liquid or gas fuels. In order to truly control emissions from these installations, expensive abatement plant and Continuous Energy Monitoring systems (CEMs) could be required by the regulatory authority. This equipment is costly to install and maintain and, since these installations are often installed to save energy and environmental cost, this negatively impacts the business case for biomass. This is particularly the case for smaller installations since the cost of abatement equipment and CEMs becomes proportionally much greater (£/MW input) as combustion capacity decreases.

Coal is unlikely to return in any great amount in the UK, being restricted to a few very large power plants. Large WID plants already have to fit ESP or bag filters, SNCR, HCL and metals abatement, and other costly techniques.

Typical pollutant emissions concentrations from different technology and fuel-type combinations

Most of the sites that we operate are not currently covered by the IPPC meaning emissions monitoring is not a regulatory requirement. The emissions data we do have relates to installations that are either Large Combustion Plant (>50MW) or smaller plant which are covered by the IPPC as a result of the manufacturing activity on those sites. The installations for which we do have emissions data are generally gas-fired sites.

The Combustion Engineering Association (CEA), of which Dalkia is a member, recently produced a Large Combustion Plant BREF review submission to put forward its views to the Technical Working Group (TWG) charged with reviewing the LCP BREF document. As part of the submission, the members of the CEA gathered existing emissions data from our respective sites. The graph below depicts the NOx and CO emissions data for a range of gas fired boilers. Many of the installations in the lower capacity range of the graph are Dalkia sites.



We would not have sufficient data to demonstrate clearly the respective emission levels that prevail for other fuels. However, we would like to stress that the emissions achievable from biomass combustion plant depends strongly on the boiler technology employed which in turn depends on other key project parameters (fuel type, fuel quality, scale, schedule, economic feasibility, available space etc.).

Typical abatement techniques already applied and abatement techniques which would be required to meet the proposed ELVs and the costs of these abatement techniques.

Most abatement for smaller installations is delivered through NOx management and fuel choice. Typically:

- Gas boilers will have low NOx burners (150mg or less)
- Gas turbines can get down to 25mg NOx or lower
- Gas engines are already at 250mg NOx, although NOx vs. CO is an issue in engines particularly
- For oil boilers, low sulphur fuel and technology similar to gas burners is acceptable
- Small biomass plants use high efficiency cyclones, over fire air and possibly economisers and combustion air preheat to maximise efficiency and improve combustion

It is difficult to know what additional abatement would be required to meet new ELVs without knowing what they are but presumably some sites which do not have recent gas or oil burners would need to upgrade them to achieve target emissions levels. In some instances, this will bring forward the need to replace the site boiler(s). Existing and

future biomass plant could be required to employ very expensive abatement solutions (beyond cyclone(s)):

- Bag filters
- Electrostatic precipitators
- SNCR
- SCR

For prospective installations (notably in the smaller range), the need to employ abatement technologies such as these could lead to the project being shelved at the evaluation stage. Biomass boiler projects are most often undertaken as retrofit solutions to existing sites for the purposes of reducing energy costs. In this instance, as financial savings is the main driver for the project, the considerable additional capital cost required for the abatement equipment can render the solution uneconomic. It will be very difficult for the UK to meet its renewable heat targets if support mechanisms such as the RHI for large biomass plants (>1MW) are only offered to plants that meet the proposed stringent emission limits.

Appendix E

Adjustments made to data provided by Member States

Note: Member States not listed in this appendix either provided complete data for the MS or provided no data (and were therefore gap-filled in an alternative manner).

Austria

Number and capacity of plants (5-20MW_{th})

The information provided by the MS covers estimated numbers of plants (=stack) with steam boilers firing solid fuels, biomass and non-standard fuels in capacity classes 5-20MW and 20-50MW. The data originate from a data bank about emission reports from plant operators of steam boilers.

The reported numbers of plants in the 20-50MW capacity class are suggested to be correct, but that those in the 5-20MW capacity class are likely to be an underestimate, and potentially a significant underestimate.

Adjustments need to be made to the data to take account of the following exclusions:

- The number of plants excludes combustion plants that are not steam boilers. The MS has indicated that “*most of the combustion plants with a rated thermal input > 5 MW are steam boilers*”.
- The number of plants excludes combustion plants 5-10MW using gas oil or natural gas.

The following adjustments have been made to the 5-20MW numbers and capacities:

- vii. Based on a review of indications submitted by other Member States, assumed that approximately 75% are steam boilers, therefore multiply numbers and capacity by a factor of 1.33 to take account of missing data.
- viii. Assume that one third of the plants are in the capacity range 5-10MW_{th}, i.e. one third of the capacity range 5 to 20MW_{th}.³⁹ The data for Slovakia (a neighbouring MS) suggest that 80% of fuel consumption is natural gas. We assume this ratio is also true for numbers/capacity of plants in AT, i.e. that the data provided for 5-10MW_{th} (which excludes plants using gas oil or natural gas) represents

³⁹ Although it could be argued that a greater number of plants than a third would lie in the capacity bracket 5-10MW_{th}, without robust data to suggest an alternative figure, a simple assumption of one third is adopted. For capacity of plants, the assumption of one third may well be more appropriate than for numbers of plants.

20% of all plants. Therefore adjust the number of plants in the (sub) 5-10MW_{th} category by a factor of 5. This leads to an overall multiplying factor of 2.33 for the 5-20MW sector.⁴⁰

Belgium

Data for Belgium comprises data provided separately from each of the three regions of Flanders, Wallonia and Brussels.

Wallonia

The data on numbers, capacity and emissions provided by the Wallonia authorities exclude data on the following plants:

- Boilers in the tertiary sector (hospitals, schools) above 1 MW_{th}
- Boilers in the residential sector above 1 MW_{th}

In order to account for these two exclusions, the following adjustments are made:

- ix. To account for missing tertiary sector, the average contribution this sector comprises of each capacity class from other MS data (Figure 3.4 in the interim report) is utilised for data on numbers and capacity (and as a total of 1-50MW_{th} for emissions): 25% 1-5MW_{th}, 9% 5-20MW_{th}, 9% 20-50MW_{th}, 18% 1-50MW_{th}. I.e. the numbers and capacity data for capacity classes 1-5, 5-20 and 20-50MW_{th} are multiplied by factors 1.33, 1.1 and 1.1 respectively. The emissions data are multiplied by a factor of 1.22.
- x. To account for the missing residential sector, comparison was made with the detailed sector data provided by SK, in which the residential sector comprised only an appreciate proportion of total number of plants in the 1-5MW_{th} capacity class, and in this instance comprised 4% of the total. Therefore an uplift factor for the 1-5MW_{th} capacity class of 1.04 is used for numbers and capacity data only.

The emissions data were provided as a total for the three capacity classes. In order to apportion these data across the three capacity classes:

- xi. It is proposed to use the ratio of installed capacity among the three capacity classes to split the emissions data. This inherently assumes that plant emission levels across the three capacity classes are the same. A comparison of the ELVs for Flanders and Wallonia suggests that this is a reasonable assumption.

⁴⁰ This is in-line with an approximate factor estimated by the Austrian authorities.

Flanders and Brussels

The data provided by the Brussels region is provided at the boiler level. We are unable to convert these data into the stack level, and so are accepted as a known limitation of the data. Note: we have not attempted to adjust the boiler-level data into a number of stacks as per the approach for Sweden and Finland, as the ratio of boilers to stacks for Brussels is not necessarily the same as for the Scandinavian countries. The implication is that the number of plants for Brussels (and Belgium) and thus estimates based on this (e.g. costs) may be overestimates.

Neither of the regions provided emissions data whilst Wallonia did. Therefore, there is a gap in the emissions data for Belgium.

- xii. It is proposed to utilise the ratio in capacity data of the Flanders and Brussels region to that of the Wallonia region to extrapolate estimated emissions for the whole of Belgium. This inherently assumes that plant emission levels across the three Belgian regions are the same. A comparison of the ELVs for Flanders and Wallonia suggests that this is a reasonable assumption.

Cyprus

Data on fuel consumption and emissions were provided by the MS as an aggregate for the capacity class 1 to 20MW_{th}. Data on numbers and capacity of plants were however provided separately for the two capacity classes 1-5MW_{th} and 5-20MW_{th}.

- xiii. The fuel consumption and emissions data for the combined capacity class 1-20MW_{th} are proposed to be split into the two separate capacity classes in accordance with the ratio of the capacity classes.

Finland

The data provided by Finland are provided at the boiler level. It is possible from the data provided to make preliminary estimates of the number of Finnish plants (stack) using the unique (x,y,z) coordinates of boilers supplied by the Finnish authorities. These estimates have not been confirmed by the authorities.

- xiv. Propose to use estimated revised numbers at the stack level: 136 1-5MW_{th} plants, 140 5-20MW_{th} plants, 133 20-50MW_{th} plants.

France

The data on numbers (and capacity) provided appear to be high. There is a need to try to verify the figures. The number of plants 1-20MW_{th} provided is 20,000, and that of 20-50MW_{th} is 1,500.

The estimate for the number of 20-50MW_{th} plants has been checked as follows:

- The number of combustion installations >20MW_{th} in the 2009 CITL database is 787
- The number of combustion facilities >50MW_{th} in the 2009 E-PRTR database is 137

- The number of combustion plants >50MW_{th} in the 2009 LCPD dataset is 241
- From the above data points it is implied (assuming one facility is equivalent to one installation) that there are approximately 650 combustion installations 20-50MW_{th}. Looking at the ratio of the number of combustion plants (stack) vs. installation >50MW_{th} suggests a ratio of plant:installation of 241:137. If the same ratio remained true for 20-50MW_{th} installations, the estimated number of combustion plants(stack) 20-50MW_{th} is $(241/137)*650 = 1143$ plants.

The estimate derived of 1,143 is 25% lower than the estimate provided by the FR authorities. It should be noted that it is the same order of magnitude, and because of this, it is proposed to retain the estimate provided by the French authorities.

The estimate of the number of 1-20MW_{th} plants has been checked as follows:

- The average ratio of number of plants 1-20MW to 20-50MW from those MS that provided full data is 30:1. Such a ratio applied to either estimate of FR 20-50MW_{th} plants yields a figure much higher than 20,000.
- Compared against the estimate by AMEC for Germany (data not provided by the DE authorities) of 1-20MW_{th} plants of 21,430, and against the estimate for NL by the Dutch authorities of 9,245, the estimate for France appears plausible.

To adopt the figures provided by the FR authorities, it is necessary to split the data into the 1-5MW_{th} and 5-20MW_{th} capacity classes. This is proposed to be undertaken by adopting the average split of data between these two capacity classes from Member States where full data have been provided.

Germany

Fuel consumption data were provided both for the 20-50MW_{th} capacity class and for a 1-50MW_{th} capacity class. Therefore, combined data on fuel consumption for a 1-20MW_{th} capacity class are derivable through simple subtraction.

The average load factor implied for the 20-50MW_{th} capacity class (from the capacity and fuel consumption data; of 1864hrs/annum), is used to calculate the capacity of a 1-20MW_{th} capacity class from the derived 1-20MW_{th} fuel consumption. The capacity and fuel consumption estimates for 1-20MW_{th} plants are split into the 1-5MW_{th} and 5-20MW_{th} plants by using the average ratio of capacity for those EU MS that did provide data. The numbers of plants are estimated from the capacity data by assuming average plant sizes as reported by those MS that did provide data (average plant size in the 1-5MW_{th} and 5-20MW_{th} capacity categories are 2.5MW_{th} and 10MW_{th}).

The emissions data – which were provided by the DE authorities as a total for the 1-50MW_{th} capacity class, have been split across the three capacity sub classes in the ratio of the estimated fuel consumption for each capacity class. This is because the applicable recommended limit values for plants <50MW_{th} in Germany are the same for all plants 1-50MW_{th}.

The German authorities provided some additional descriptive information about biogas plants on top of the numeric data on 1-50MW_{th} plants. We have been unable to match these data and thus they have not been included. It is noted however that some of the biogas plant fall below the 1MW_{th} threshold for inclusion in this study.

Poland

The data provided for capacity class 5-20MW_{th} represent only two plants and are considered incomplete. These data have not been included in the database.

Slovenia

1-5MW_{th} plants

The data (numbers, capacity and emissions) on plants 1-5MW_{th} represent only plants fired with solid fuel. It is therefore necessary to adjust these data to be representative of all plants in Slovenia. It is proposed to use the ratio of fuels used in 20-50MW_{th} SI plants to fill this gap.⁴¹

- xv. The data provided (on solid fuel plants) on numbers and capacity should be multiplied by a factor of 9 in order to be representative of all fuels, since it is assumed that a total of 11% of the fuel consumption is of solid fuels (biomass and other solid fuels).
- xvi. The data provided (on solid fuel plants) on emissions should not be multiplied by a factor of 9 as the emission level of fuels other than solid fuels (primarily natural gas) are lower than solid fuels. It is proposed to multiply the NO_x emissions data (only) by a factor of $[9 * \text{[emission level of natural gas plant]} / \text{[emission level of coal plant]}]$. Since SO₂ and dust emissions from natural gas are ignored, no change is proposed to these emissions.

5-20MW_{th} plants

The data (numbers, capacity and emissions) on plants 5-20MW_{th} excludes data for those plants which are <10MW_{th} and which are fired with natural gas. It is therefore necessary to adjust these data to be representative of all plants in Slovenia.

- xvii. It is proposed to use the ratio of fuels at 20-50MW_{th} plants in SI⁴², shown below, coupled with an assumption that natural gas consumption at plants 5-10MW_{th} is one third of natural gas consumption at

⁴¹ The data for Slovakia, a country considered to have similar fuel mix profile was also investigated, i.e. whether the SK data on the fuel mix in the 1-5MW_{th} capacity class could be used instead of the SI data on the fuel mix in 20-50MW_{th} plants. The results of this investigation show that a very similar factor would result (SK proportion of fuel consumption that is solid fuels is 9% in 1-5MW_{th} capacity class compared to the 11% in SI 20-50MW_{th} plants).

⁴² As for 1-5MW_{th} plants, data on 5-20MW_{th} plants in Slovakia were also investigated for use instead of utilising the fuel mix of Slovenian 20-50MW_{th} plants. The results of this investigation show that a very similar factor would

5-20MW_{th} plants. These two assumptions leads to an estimate that the data provided on numbers and capacity represent 71% of the actual situation, i.e. that the data on numbers and capacity should be multiplied by a factor of 1.4.

- xviii. The data provided on emissions should not be multiplied by a factor of 1.4 as the emission levels of natural gas are lower than for other fuels. It is proposed to multiply the NO_x emissions data (only) by a factor of $[1.4 * [\text{emission level of natural gas plant}] / [\text{emission level of coal plant}]]$. Since SO₂ and dust emissions from natural gas are ignored, no change is proposed to these emissions.

Fuel consumption of all plants

- xix. Total fuel consumption data should be estimated from Slovenian capacity data using EU average load factors in line with other Member States.
- xx. The split among fuel types should be adopted (from Table 3-5 of the AEA (2007) study) as:

| Biomass | Other Solid | Liquid | Nat Gas | Other |
|---------|-------------|--------|---------|-------|
| 6.0% | 5.0% | 2.4% | 86.6% | 0.0% |

Sweden

The data for the capacity class 1-5MW_{th} appear quite small. The data source from the SE authorities for all the plants is the NO_x charge databank; since the NO_x charge applies to boilers producing >25GWh per year, this effectively means that it will not cover any plants in the 1-5MW_{th} capacity class. Therefore the small amount of data provided by the MS for this capacity class will be gap-filled.

It is unclear whether the Swedish figures for numbers of plants are at a boiler level. For Finland, an estimate has been made on the number of plants the boiler inventory represents. Although this ratio used in Finland could be utilised for Sweden, the existing data appear robust in terms of the average capacity per plant being 10MW_{th} in the 5-20MW_{th} category and 28MW_{th} in the 20-50MW_{th} category.

United Kingdom

The data provided for capacity classes 1-5MW_{th} and 5-20MW_{th} are representative for the region of Northern Ireland only. Since this is only a small part of the United Kingdom it is not thought that these data are representative of the UK as a whole. Therefore, the gap-filling process for 1-5MW_{th} and 5-20MW_{th} capacity classes is proposed to be as if no data were provided.

result (SK proportion of fuel consumption that is natural gas is 85.0% in 5-20MW_{th} capacity class, compared to 86.6% in SI 20-50MW_{th} plants).

- xxi. Overwrite UK provided data on 1-5MW_{th} and 5-20MW_{th} plants and estimate these from other methods as per all MS.

For the capacity class 20-50MW_{th}, it is proposed to utilise a dataset developed for the UK Government by AMEC instead of the data provided. As this is a separate, existing dataset, it is documented in Section 4.3.

Appendix F

ELVs applied in Member State national legislation on combustion plants less than 50MW_{th}.

This appendix lists the emission limit values from Member States' national legislation that apply to combustion plants between 1MW_{th} and 50MW_{th}. The pragmatic approach taken to gathering the limit values from national legislation has been to select limit value most likely to be most widely applied when considering that legislation often differentiates by age category of the plant. Each piece of national legislation has a different definition of what is a 'new' plant compared to an 'existing' plant. The pragmatic approach taken has considered, for the period 2015 to 2020, and taking into account plant lifetimes ranging from 10 to 30 years, which ELV (i.e. for 'existing' plants or for 'new' plants) is most likely to be most widely in force. In the absence of readily available information (for example legislation that is not in English), the default choice has been the ELVs for 'existing' plants.

Table F.2 General case emission levels (applied in the absence of Member State-specific ELVs)

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm ³) |
|--------------|-----------------|----------------|-------------------|--------------------|--|-----------------------------------|
| AT | Dust | 1-50 MW | Biomass | 13% O ₂ | new steam boilers / existing from 2018 | 50 |
| AT | NO _x | 1-5 MW | Biomass | 13% O ₂ | steam boilers. Average 250-500 range | 375 |
| AT | NO _x | 5-20 MW | Biomass | 13% O ₂ | steam boilers. Average 200-350 range | 275 |
| AT | NO _x | 20-50 MW | Biomass | 13% O ₂ | steam boilers. Average 200-350 range | 275 |
| AT | Dust | 1-50 MW | Other solid fuels | 6% O ₂ | new steam boilers / existing from 2018 | 50 |
| AT | NO _x | 1-5 MW | Other solid fuels | 6% O ₂ | new steam boilers / existing from 2018 | 400 |
| AT | NO _x | 5-20 MW | Other solid fuels | 6% O ₂ | new steam boilers / existing from 2018 | 350 |
| AT | NO _x | 20-50 MW | Other solid fuels | 6% O ₂ | new steam boilers / existing from 2018 | 350 |
| AT | SO ₂ | 5-20 MW | Other solid fuels | 6% O ₂ | new steam boilers / existing from 2018 | 400 |
| AT | SO ₂ | 20-50 MW | Other solid fuels | 6% O ₂ | new steam boilers / existing from 2018 | 400 |
| AT | NO _x | 1-5 MW | Natural gas | 3% O ₂ | new steam boilers / existing from 2018 | 125 |
| AT | Dust | 1-5 MW | Liquid fuels | 11% O ₂ | steam boilers. Average of 30-60 range | 45 |
| AT | Dust | 5-20 MW | Liquid fuels | 11% O ₂ | steam boilers. Average of 30-60 range | 45 |
| AT | Dust | 20-50 MW | Liquid fuels | 11% O ₂ | steam boilers. Average of 30-50 range | 40 |
| AT | NO _x | 1-5 MW | Liquid fuels | 11% O ₂ | steam boilers. 150 gasoil | 400 |
| AT | NO _x | 5-20 MW | Liquid fuels | 11% O ₂ | steam boilers. 150 gasoil | 350 |
| AT | NO _x | 20-50 MW | Liquid fuels | 11% O ₂ | steam boilers. 150 gasoil | 350 |
| AT | NO _x | 5-20 MW | Natural gas | 3% O ₂ | new steam boilers / existing from 2018 | 100 |
| AT | NO _x | 20-50MWth | Natural gas | 3% O ₂ | new steam boilers / existing from 2018 | 100 |
| BE/Flanders | Dust | 1-50 MW | Other solid fuels | | plants licensed 1996-2005 | 50 |
| BE/Flanders | NO _x | 1-50 MW | Other solid fuels | | plants licensed 1996-2005 | 400 |
| BE/Flanders | SO ₂ | 1-50 MW | Other solid fuels | | plants licensed 1996-2005 | 1250 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm3) |
|--------------|-----------|----------------|--------------|------------------------------|--------------------------------------|----------------------|
| BE/Flanders | Dust | 1-50 MW | Liquid fuels | | plants licensed 1996-2005 | 50 |
| BE/Flanders | SO2 | 1-50 MW | Liquid fuels | | plants licensed 1996-2005 | 1700 |
| BE/Flanders | NOx | 1-5 MW | Liquid fuels | | plants licensed 1996-2005 | 400 |
| BE/Flanders | NOx | 5-20 MW | Liquid fuels | | plants licensed 1996-2005 | 400 |
| BE/Flanders | NOx | 20-50 MW | Liquid fuels | | plants licensed 1996-2005 | 300 |
| BE/Flanders | Dust | 1-5 MW | Biomass | Wood (contaminated and non-) | Incineration ELV | 150 |
| BE/Flanders | Dust | 5-20 MW | Biomass | Wood (contaminated and non-) | Incineration ELV | 30 |
| BE/Flanders | Dust | 20-50 MW | Biomass | Wood (contaminated and non-) | Incineration ELV | 30 |
| BE/Flanders | NOx | 1-5 MW | Biomass | Wood (contaminated and non-) | | 400 |
| BE/Flanders | NOx | 5-20 MW | Biomass | Wood (contaminated and non-) | Incineration ELV. Expressed in NO2 | 200 |
| BE/Flanders | NOx | 20-50 MW | Biomass | Wood (contaminated and non-) | Incineration ELV. Expressed in NO2 | 200 |
| BE/Flanders | NOx | 1-50 MW | Natural gas | | plants licensed 1996-2005 | 150 |
| BE/Wallonia | NOx | 1-50 MW | Natural gas | | Existing | 200 |
| BE/Wallonia | NOx | 1-5 MW | Natural gas | | New | 150 |
| BE/Wallonia | NOx | 5-20 MW | Natural gas | | New | 100 |
| BE/Wallonia | NOx | 20-50 MW | Natural gas | | New | 100 |
| BE/Wallonia | NOx | 1-5 MW | Biomass | clean wood | For existing plant. New plants = 400 | 500 |
| BE/Wallonia | NOx | 5-20 MW | Biomass | clean wood | For existing plant. New plants = 250 | 400 |
| BE/Wallonia | NOx | 20-50 MW | Biomass | clean wood | For existing plant. New plants = 250 | 400 |
| BE/Wallonia | Dust | 1-5 MW | Biomass | clean wood | For existing plant. New plants = 50 | 150 |
| BE/Wallonia | Dust | 5-20 MW | Biomass | clean wood | For existing plant. New plants = 20 | 50 |
| BE/Wallonia | Dust | 20-50 MW | Biomass | clean wood | For existing plant. New plants = 20 | 50 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm3) |
|--------------|-----------|----------------|-------------------|-------------|--|----------------------|
| CZ | SO2 | 1-5 MW | Other solid fuels | Solid fuel | | 2500 |
| CZ | SO2 | 5-20 MW | Other solid fuels | Solid fuel | 800 in fluidised bed | 2500 |
| CZ | SO2 | 20-50 MW | Other solid fuels | Solid fuel | 800 in fluidised bed | 2500 |
| CZ | SO2 | 1-50 MW | Biomass | Solid fuel | | 2500 |
| CZ | NOx | 1-5 MW | Other solid fuels | Solid fuel | Other furnace, biomass. 400mg/Nm3 for fluid combustion chamber | 650 |
| CZ | NOx | 5-20 MW | Other solid fuels | Solid fuel | | 650 |
| CZ | NOx | 20-50 MW | Other solid fuels | Solid fuel | | 650 |
| CZ | NOx | 1-50 MW | Biomass | Solid fuel | Other furnace, biomass. 400mg/Nm3 for fluid combustion chamber | 650 |
| CZ | Dust | 1-50 MW | Biomass | Solid fuel | Biomass | 250 |
| CZ | Dust | 5-20 MW | Other solid fuels | Solid fuel | 100mg/Nm3 for fluid combustion chamber | 150 |
| CZ | Dust | 20-50 MW | Other solid fuels | Solid fuel | 100mg/Nm3 for fluid combustion chamber | 150 |
| CZ | Dust | 1-5 MW | Other solid fuels | Solid fuel | | 250 |
| CZ | SO2 | 1-5 MW | Liquid fuels | | | 1700 |
| CZ | SO2 | 5-20 MW | Liquid fuels | | | 1700 |
| CZ | SO2 | 20-50 MW | Liquid fuels | | | 1700 |
| CZ | NOx | 1-5 MW | Liquid fuels | | | 500 |
| CZ | NOx | 5-20 MW | Liquid fuels | | | 450 |
| CZ | NOx | 20-50 MW | Liquid fuels | | | 450 |
| CZ | Dust | 1-5 MW | Liquid fuels | | | 100 |
| CZ | Dust | 5-20 MW | Liquid fuels | | | 100 |
| CZ | Dust | 20-50 MW | Liquid fuels | | | 100 |
| CZ | Dust | 1-50 MW | Natural gas | Natural gas | Average 50-100 range | 75 |
| CZ | SO2 | 1-50 MW | Natural gas | Natural gas | Except for outside of public distribution networks | 35 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm ³) |
|--------------|-----------------|----------------|-------------------|-------------|---|-----------------------------------|
| CZ | NOx | 1-50 MW | Natural gas | Natural gas | | 200 |
| PT | NOx | 20-50 MW | Natural gas | | | 500 |
| PT | SO ₂ | 20-50 MW | Liquid fuels | | | 500 |
| PT | NOx | 20-50 MW | Liquid fuels | | | 500 |
| PT | Dust | 20-50 MW | Liquid fuels | | | 150 |
| PT | SO ₂ | 20-50 MW | Other solid fuels | | | 500 |
| PT | NOx | 20-50 MW | Other solid fuels | | | 500 |
| PT | Dust | 20-50 MW | Other solid fuels | | | 150 |
| PT | NOx | 20-50 MW | Biomass | | | 500 |
| PT | Dust | 20-50 MW | Biomass | | | 150 |
| CY | Dust | 5-20 MW | Liquid fuels | | | 100 |
| CY | Dust | 20-50 MW | Liquid fuels | | | 100 |
| CY | Dust | 5-20 MW | Biomass | | | 100 |
| CY | Dust | 20-50 MW | Biomass | | | 100 |
| CY | Dust | 1-5 MW | Liquid fuels | | | 150 |
| CY | SO ₂ | 20-50 MW | Liquid fuels | | Specific permit for ICE back up plants | 565 |
| CY | NOx | 20-50 MW | Liquid fuels | | Specific permit for ICE back up plants | 1800 |
| DE | SO ₂ | 1-50 MW | Natural gas | | | 5 |
| DE | NOx | 1-50 MW | Natural gas | | 100 for boiler temperatures <110C and pressure <0.05MPa; 110 for boiler temperatures 110-210C and pressure 0.05-1.8 MPa; 150 for boiler temperatures >210C and pressure >1.8 MPa. | 110 |
| DE | Dust | 1-50 MW | Natural gas | | | 10 |
| DE | SO ₂ | 1-50 MW | Other solid fuels | | 350 for fluidised bed furnaces | 1300 |
| DE | NOx | 1-5 MW | Other solid fuels | | 300 for fluidised bed furnaces | 500 |
| DE | NOx | 5-20 MW | Other solid fuels | | 300 for fluidised bed furnaces | 400 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm ³) |
|--------------|-----------------|----------------|---------------------|-------------|---|-----------------------------------|
| DE | NOx | 20-50 MW | Other solid fuels | | 300 for fluidised bed furnaces | 400 |
| DE | Dust | 1-5 MW | Other solid fuels | | | 50 |
| DE | Dust | 5-20 MW | Other solid fuels | | | 20 |
| DE | Dust | 20-50 MW | Other solid fuels | | | 20 |
| DE | SO ₂ | 1-50 MW | Liquid fuels | | | 850 |
| DE | NOx | 1-50 MW | Liquid fuels | | 180 for boiler temperatures <110C and pressure <0.05MPa; 200 for boiler temperatures 110-210C and pressure 0.05-1.8 MPa; 250 for boiler temperatures >210C and pressure >1.8 MPa. | 200 |
| DE | Dust | 1-50 MW | Liquid fuels | | | 50 |
| DE | Dust | 1-5 MW | Biomass | | | 100 |
| DE | Dust | 5-20 MW | Biomass | | | 20 |
| DE | Dust | 20-50 MW | Biomass | | | 20 |
| DE | NOx | 1-50 MW | Biomass | | | 250 |
| DE | NOx | 1-50 MW | Other gaseous fuels | | | 200 |
| DE | SO ₂ | 1-50 MW | Other gaseous fuels | | | 350 |
| FI | SO ₂ | 1-50 MW | Liquid fuels | | New and existing | 850 |
| FI | NOx | 1-5 MW | Liquid fuels | | 800 for new plants | 900 |
| FI | NOx | 5-20 MW | Liquid fuels | | 800 for new plants | 900 |
| FI | NOx | 20-50 MW | Liquid fuels | | 500 for new plants | 600 |
| FI | NOx | 1-5 MW | Natural gas | | 340 for new plants | 400 |
| FI | NOx | 5-20 MW | Natural gas | | 340 for new plants | 400 |
| FI | NOx | 20-50 MW | Natural gas | | 200 for new plants | 300 |
| FI | NOx | 1-5 MW | Other gaseous fuels | | 340 for new plants | 400 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm ³) |
|--------------|-----------------|----------------|---------------------|-------------|--------------------------|-----------------------------------|
| FI | NOx | 5-20 MW | Other gaseous fuels | | 340 for new plants | 400 |
| FI | NOx | 20-50 MW | Other gaseous fuels | | 200 for new plants | 300 |
| FI | SO ₂ | 1-50 MW | Other solid fuels | | 850 for new plants | 1100 |
| FI | NOx | 1-50 MW | Other solid fuels | | 270 for new plants | 420 |
| FI | Dust | 1-5 MW | Other solid fuels | | | 50 |
| FI | Dust | 5-20 MW | Other solid fuels | | 40 for new plants | 50 |
| FI | Dust | 20-50 MW | Other solid fuels | | 40 for new plants | 50 |
| FI | SO ₂ | 1-50 MW | Biomass | | | 200 |
| FI | NOx | 1-50 MW | Biomass | | 375 for new plants | 450 |
| FI | Dust | 1-5 MW | Biomass | | 200 for new plants | 300 |
| FI | Dust | 5-20 MW | Biomass | | 50 for 1-10MW new plants | 150 |
| FI | Dust | 20-50 MW | Biomass | | 40 for new plants | 50 |
| FR | SO ₂ | 1-5 MW | Biomass | | | 200 |
| FR | SO ₂ | 5-20 MW | Biomass | | | 200 |
| FR | NOx | 1-5 MW | Biomass | | | 500 |
| FR | NOx | 5-20 MW | Biomass | | | 500 |
| FR | Dust | 1-5 MW | Biomass | | | 150 |
| FR | Dust | 5-20 MW | Biomass | | | 100 |
| FR | SO ₂ | 1-5 MW | Liquid fuels | | | 1700 |
| FR | SO ₂ | 5-20 MW | Liquid fuels | | | 1700 |
| FR | NOx | 1-5 MW | Liquid fuels | | | 550 |
| FR | NOx | 5-20 MW | Liquid fuels | | | 500 |
| FR | Dust | 1-5 MW | Liquid fuels | | | 150 |
| FR | Dust | 5-20 MW | Liquid fuels | | | 100 |
| FR | SO ₂ | 1-5 MW | Natural gas | | | 35 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm3) |
|--------------|-----------|----------------|-------------------|-------------|---------|----------------------|
| FR | SO2 | 5-20 MW | Natural gas | | | 35 |
| FR | NOx | 1-5 MW | Natural gas | | | 200 |
| FR | NOx | 5-20 MW | Natural gas | | | 150 |
| FR | Dust | 1-5 MW | Natural gas | | | 5 |
| FR | Dust | 5-20 MW | Natural gas | | | 5 |
| FR | SO2 | 20-50 MW | Liquid fuels | | | 1700 |
| FR | NOx | 20-50 MW | Liquid fuels | | | 600 |
| FR | Dust | 20-50 MW | Liquid fuels | | | 100 |
| FR | SO2 | 20-50 MW | Natural gas | | | 35 |
| FR | NOx | 20-50 MW | Natural gas | | | 225 |
| FR | Dust | 20-50 MW | Natural gas | | | 5 |
| FR | SO2 | 20-50 MW | Biomass | | | 2000 |
| FR | NOx | 20-50 MW | Biomass | | | 600 |
| FR | Dust | 20-50 MW | Biomass | | | 100 |
| HU | SO2 | 1-50 MW | Natural gas | | boilers | 35 |
| HU | NOx | 1-50 MW | Natural gas | | boilers | 350 |
| HU | Dust | 1-50 MW | Natural gas | | boilers | 5 |
| HU | SO2 | 1-50 MW | Liquid fuels | | boilers | 1700 |
| HU | NOx | 1-50 MW | Liquid fuels | | boilers | 450 |
| HU | Dust | 1-50 MW | Liquid fuels | | boilers | 80 |
| HU | SO2 | 1-50 MW | Other solid fuels | | boilers | 2000 |
| HU | NOx | 1-50 MW | Other solid fuels | | boilers | 650 |
| HU | Dust | 1-50 MW | Other solid fuels | | boilers | 150 |
| HU | SO2 | 1-50 MW | Biomass | | boilers | 2000 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm ³) |
|--------------|---|----------------|---------------------|-------------|--------------|-----------------------------------|
| HU | NOx | 1-50 MW | Biomass | | boilers | 650 |
| HU | Dust | 1-50 MW | Biomass | | boilers | 150 |
| LV | SO ₂ | 20-50 MW | Natural gas | | | 35 |
| LV | NOx | 20-50 MW | Natural gas | | | 350 |
| LV | Dust | 20-50 MW | Natural gas | | | 5 |
| LV | SO ₂ | 20-50 MW | Liquid fuels | | | 1700 |
| LV | NOx | 20-50 MW | Liquid fuels | | | 450 |
| LV | Dust | 20-50 MW | Liquid fuels | | | 50 |
| LV | SO ₂ | 20-50 MW | Other solid fuels | | | 2300 |
| LV | NOx | 20-50 MW | Other solid fuels | | | 600 |
| LV | Dust | 20-50 MW | Other solid fuels | | | 500 |
| LV | SO ₂ | 20-50 MW | Biomass | | | 200 |
| PL | SO ₂ | 20-50 MW | Other solid fuels | | 800 for coke | 1500 |
| PL | NOx | 20-50 MW | Other solid fuels | | | 400 |
| PL | Dust | 20-50 MW | Other solid fuels | | | 400 |
| PL | SO ₂ | 20-50 MW | Biomass | | | 800 |
| PL | NOx | 20-50 MW | Natural gas | | | 300 |
| PL | SO ₂ | 20-50 MW | Other gaseous fuels | | | 800 |
| PL | NOx | 20-50 MW | Other gaseous fuels | | | 300 |
| PL | Dust | 20-50 MW | Other gaseous fuels | | | 10 |
| RO | The details of the applicable legislation in Romania were provided too late to be included within the analysis. | | | | | |
| UK | SO ₂ | 20-50 MW | Natural gas | | | 35 |
| UK | NOx | 20-50 MW | Natural gas | | | 140 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm ³) |
|--------------|-----------------|----------------|-------------------|-------------|---|-----------------------------------|
| UK | Dust | 20-50 MW | Natural gas | | | 5 |
| UK | SO ₂ | 20-50 MW | Other solid fuels | | 3000 for indigenous coal, 2000 for imported | 2500 |
| UK | NO _x | 20-50 MW | Other solid fuels | | 450 for stoker firing, 650 for other methods | 550 |
| UK | Dust | 20-50 MW | Other solid fuels | | | 300 |
| UK | SO ₂ | 20-50 MW | Liquid fuels | | | 1700 |
| UK | NO _x | 20-50 MW | Liquid fuels | | 450 for HFO; 200 for distillates | 325 |
| UK | Dust | 20-50 MW | Liquid fuels | | 150 for HFO; 100 for distillates | 125 |
| UK | SO ₂ | 20-50 MW | Biomass | | as solid fuels | 2500 |
| UK | NO _x | 20-50 MW | Biomass | | as solid fuels | 550 |
| UK | Dust | 20-50 MW | Biomass | | as solid fuels | 300 |
| SI | Dust | 1-5 MW | Biomass | | | 50 |
| SI | Dust | 5-20 MW | Biomass | | | 20 |
| SI | Dust | 20-50 MW | Biomass | | | 20 |
| SI | Dust | 1-5 MW | Other solid fuels | | | 50 |
| SI | Dust | 5-20 MW | Other solid fuels | | | 20 |
| SI | Dust | 20-50 MW | Other solid fuels | | | 20 |
| SI | NO _x | 1-50 MW | Biomass | | new: 250 (Art 23 makes overriding exception for existing plant) | 650 |
| SI | NO _x | 1-5 MW | Other solid fuels | | new: 400 (Art 23 makes overriding exception for existing plant) | 650 |
| SI | NO _x | 5-20 MW | Other solid fuels | | new: 500 (Art 23 makes overriding exception for existing plant) | 650 |
| SI | NO _x | 20-50 MW | Other solid fuels | | new: 500 (Art 23 makes overriding exception for existing plant) | 650 |
| SI | SO ₂ | 1-50 MW | Other solid fuels | | new plants: 1300; existing plants (Art 23): 1700 | 1700 |
| SI | Dust | 5-20 MW | Liquid fuels | | | 50 |
| SI | Dust | 20-50 MW | Liquid fuels | | | 50 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm ³) |
|--------------|-----------|----------------|---------------------|-------------|---|-----------------------------------|
| SI | NOx | 1-50 MW | Liquid fuels | | new plants: 180 for boiler temperatures <110C and pressure <0.05MPa; 200 for boiler temperatures 110-210C and pressure 0.05-1.8 MPa; 250 for boiler temperatures >210C and pressure >1.8 MPa. Overriding applicable ELV for existing plants (Art. 23) | 300 |
| SI | SO2 | 5-20 MW | Liquid fuels | | new plants: 850 for fuels other than HFO; 1300 for HFO existing plants (Art 23): 1700 | 1700 |
| SI | SO2 | 20-50 MW | Liquid fuels | | new plants: 850 for fuels other than HFO; 1300 for HFO existing plants (Art 23): 1700 | 1700 |
| SI | NOx | 1-50 MW | Natural gas | | new plants: 100 for boiler temperatures <110C and pressure <0.05MPa; 110 for boiler temperatures 110-210C and pressure 0.05-1.8 MPa; 150 for boiler temperatures >210C and pressure >1.8 MPa. Existing plants subject to overriding ELV in Art 23 | 200 |
| SI | NOx | 1-50 MW | Other gaseous fuels | | | 200 |
| SI | SO2 | 5-20 MW | Other gaseous fuels | | | 50 |
| SI | SO2 | 20-50 MW | Other gaseous fuels | | | 50 |
| SK | Dust | 1-5 MW | Biomass | | 150 for 2.5MW to 7MW; 150 for 1 to 2.5MW new after 31.08.2009; 250 for 1 to 2.5MWth new before 31.08.2009 | 200 |
| SK | Dust | 5-20 MW | Biomass | | | 150 |
| SK | Dust | 20-50 MW | Biomass | | | 150 |
| SK | NOx | 1-50 MW | Biomass | | | 650 |
| SK | Dust | 1-5 MW | Other solid fuels | | 150 for 2.5MW to 7MW; 150 for 1 to 2.5MW new after 31.08.2009; 250 for 1 to 2.5MWth new before 31.08.2009 | 200 |
| SK | Dust | 5-20 MW | Other solid fuels | | | 100 |
| SK | Dust | 20-50 MW | Other solid fuels | | | 100 |
| SK | NOx | 1-5 MW | Other solid fuels | | 400 for 2.5MW to 7MW; 650 for 1 to 2.5MW | 525 |
| SK | NOx | 5-20 MW | Other solid fuels | | | 400 |
| SK | NOx | 20-50 MW | Other solid fuels | | | 400 |
| SK | SO2 | 1-50 MW | Other solid fuels | | | 2500 |
| SK | SO2 | 1-50 MW | Liquid fuels | | | 1700 |

| Member State | Pollutant | Capacity class | Fuel | Fuel detail | Notes | limit value (mg/Nm3) |
|--------------|-----------|----------------|---------------------|-------------|--------------------------------------|----------------------|
| SK | NOx | 1-5 MW | Liquid fuels | | | 500 |
| SK | NOx | 5-20 MW | Liquid fuels | | | 450 |
| SK | NOx | 20-50 MW | Liquid fuels | | | 450 |
| SK | Dust | 1-50 MW | Liquid fuels | | | 100 |
| SK | NOx | 1-50 MW | Natural gas | | | 200 |
| SK | SO2 | 1-50 MW | Other gaseous fuels | | 800 for biogas, and industrial gases | 100 |
| SK | NOx | 1-50 MW | Other gaseous fuels | | | 200 |

Appendix G

EU27 dataset on 1-50 MW_{th} combustion plants

This appendix presents the dataset on numbers, capacity, fuel consumption and emissions of combustion plants between 1MW_{th} and 50MW_{th} (at Member State level) as described in Section 4. The dataset comprises (i) data provided by Member States, (ii) data from existing studies on the sector, and (iii) data extrapolated from (i) and (ii).

Table G.3 Number of combustion plants

| Member State | 1-5MW _{th} | 5-20MW _{th} | 20-50MW _{th} | Total |
|--------------|---------------------|----------------------|-----------------------|----------------|
| AT | 3,043 | 591 | 116 | 3,750 |
| BE | 2,926 | 904 | 147 | 3,977 |
| BG | 1,915 | 549 | 73 | 2,536 |
| CY | 172 | 36 | 3 | 211 |
| CZ | 4,068 | 748 | 175 | 4,991 |
| DE | 18,000 | 5,472 | 658 | 24,130 |
| DK | 7,111 | 2,037 | 271 | 9,419 |
| EE | 537 | 174 | 29 | 740 |
| EL | 300 | 86 | 11 | 397 |
| ES | 6,663 | 1,909 | 254 | 8,826 |
| FI | 136 | 140 | 133 | 409 |
| FR | 15,547 | 4,453 | 1,500 | 21,500 |
| HU | 2,256 | 646 | 86 | 2,988 |
| IE | 1,650 | 473 | 63 | 2,186 |
| IT | 7,188 | 2,059 | 274 | 9,521 |
| LT | 1,050 | 301 | 40 | 1,391 |
| LU | 157 | 45 | 6 | 208 |
| LV | 990 | 284 | 38 | 1,311 |
| MT | 172 | 36 | 3 | 211 |
| NL | 6,995 | 2,250 | 110 | 9,355 |
| PL | 6,322 | 1,811 | 241 | 8,374 |
| PT | 892 | 255 | 34 | 1,181 |
| RO | 790 | 370 | 146 | 1,306 |
| SE | 2,754 | 173 | 105 | 3,032 |
| SI | 2,018 | 168 | 18 | 2,204 |
| SK | 2,023 | 600 | 93 | 2,716 |
| UK | 11,831 | 3,389 | 451 | 15,671 |
| EU27 | 107,506 | 29,958 | 5,078 | 142,542 |

Table G.4 Capacity of combustion plants (GW_{th})

| Member State | 1-5MW _{th} | 5-20MW _{th} | 20-50MW _{th} | Total |
|--------------|---------------------|----------------------|-----------------------|--------------|
| AT | 7.0 | 6.9 | 3.7 | 17.6 |
| BE | 6.7 | 8.7 | 4.7 | 20.1 |
| BG | 4.4 | 4.9 | 2.3 | 11.6 |
| CY | 0.4 | 0.3 | 0.1 | 0.7 |
| CZ | 8.5 | 7.2 | 5.2 | 20.9 |
| DE | 41.4 | 48.7 | 22.5 | 112.6 |
| DK | 16.4 | 18.1 | 8.7 | 43.2 |
| EE | 1.2 | 1.8 | 1.0 | 4.0 |
| EL | 0.7 | 0.8 | 0.4 | 1.8 |
| ES | 15.3 | 17.0 | 8.1 | 40.4 |
| FI | 0.6 | 2.1 | 6.4 | 9.1 |
| FR | 35.8 | 39.6 | 48.0 | 123.4 |
| HU | 5.2 | 5.8 | 3.8 | 14.8 |
| IE | 3.8 | 4.2 | 2.0 | 10.0 |
| IT | 16.5 | 18.3 | 9.3 | 44.2 |
| LT | 2.4 | 2.7 | 1.3 | 6.4 |
| LU | 0.4 | 0.4 | 0.2 | 1.0 |
| LV | 2.3 | 2.5 | 1.2 | 6.0 |
| MT | 0.4 | 0.3 | 0.1 | 0.7 |
| NL | 21.0 | 23.0 | 3.7 | 47.7 |
| PL | 14.5 | 16.1 | 8.1 | 38.8 |
| PT | 2.1 | 2.3 | 1.2 | 5.5 |
| RO | 1.6 | 2.7 | 3.1 | 7.4 |
| SE | 6.3 | 1.8 | 3.0 | 11.1 |
| SI | 4.9 | 1.8 | 0.5 | 7.1 |
| SK | 4.3 | 5.4 | 2.8 | 12.5 |
| UK | 27.2 | 30.2 | 13.3 | 70.7 |
| EU27 | 251 | 273 | 165 | 689 |

Table G.5 Total fuel consumption of combustion plants (PJ)

| Member State | 1-5MW _{th} | 5-20MW _{th} | 20-50MW _{th} | Total |
|--------------|---------------------|----------------------|-----------------------|--------------|
| AT | 47 | 77 | 28 | 152 |
| BE | 45 | 97 | 36 | 177 |
| BG | 29 | 54 | 13 | 97 |
| CY | 1 | 1 | 1 | 3 |
| CZ | 79 | 217 | 30 | 326 |
| DE | 277 | 326 | 151 | 754 |
| DK | 109 | 202 | 86 | 398 |
| EE | 6 | 9 | 10 | 25 |
| EL | 5 | 9 | 4 | 17 |
| ES | 103 | 189 | 103 | 395 |
| FI | 9 | 16 | 37 | 62 |
| FR | 239 | 442 | 365 | 1,046 |
| HU | 35 | 64 | 29 | 128 |
| IE | 25 | 47 | 20 | 92 |
| IT | 111 | 204 | 93 | 408 |
| LT | 16 | 30 | 13 | 59 |
| LU | 2 | 4 | 1 | 8 |
| LV | 15 | 28 | 12 | 56 |
| MT | 1 | 1 | 1 | 3 |
| NL | 132 | 160 | 40 | 332 |
| PL | 97 | 180 | 55 | 332 |
| PT | 14 | 25 | 15 | 54 |
| RO | 11 | 30 | 23 | 65 |
| SE | 42 | 40 | 59 | 142 |
| SI | 33 | 20 | 4 | 56 |
| SK | 13 | 18 | 13 | 43 |
| UK | 182 | 336 | 123 | 641 |
| EU27 | 1,678 | 2,826 | 1,367 | 5,871 |

Table G.6 Fuel consumption of 1-5MW_{th} combustion plants (PJ)

| Member State | Biomass (PJ) | Other solid fuel (PJ) | Liquid fuel (PJ) | Natural gas (PJ) | Other gaseous fuel (PJ) | Total |
|--------------|--------------|-----------------------|------------------|------------------|-------------------------|--------------|
| AT | 16.4 | 0.0 | 0.0 | 30.5 | 0.0 | 47 |
| BE | 0.6 | 0.0 | 8.5 | 35.6 | 0.0 | 45 |
| BG | 2.6 | 0.0 | 7.3 | 19.5 | 0.0 | 29 |
| CY | 0.0 | 0.0 | 0.9 | 0.0 | 0.1 | 1 |
| CZ | 1.8 | 1.8 | 0.7 | 74.6 | 0.0 | 79 |
| DE | 75.0 | 18.0 | 35.0 | 142.0 | 7.0 | 277 |
| DK | 6.0 | 0.0 | 27.2 | 76.3 | 0.0 | 109 |
| EE | 2.1 | 0.1 | 1.2 | 2.4 | 0.2 | 6 |
| EL | 0.3 | 0.0 | 1.1 | 3.2 | 0.0 | 5 |
| ES | 3.4 | 0.0 | 17.4 | 81.8 | 0.0 | 103 |
| FI | 3.8 | 1.2 | 1.2 | 2.1 | 0.5 | 9 |
| FR | 36.6 | 4.9 | 51.3 | 136.8 | 9.8 | 239 |
| HU | 1.7 | 0.0 | 3.5 | 29.5 | 0.0 | 35 |
| IE | 2.8 | 0.0 | 12.6 | 10.1 | 0.0 | 25 |
| IT | 0.0 | 0.0 | 22.1 | 88.5 | 0.0 | 111 |
| LT | 0.9 | 0.0 | 5.3 | 10.0 | 0.0 | 16 |
| LU | 0.0 | 0.0 | 0.0 | 2.4 | 0.0 | 2 |
| LV | 6.4 | 0.0 | 1.5 | 7.3 | 0.0 | 15 |
| MT | 0.0 | 0.0 | 0.9 | 0.0 | 0.1 | 1 |
| NL | 1.0 | 1.0 | 0.0 | 130.0 | 0.0 | 132 |
| PL | 0.4 | 77.5 | 0.4 | 18.6 | 0.6 | 97 |
| PT | 4.0 | 0.0 | 3.6 | 6.1 | 0.0 | 14 |
| RO | 0.6 | 0.0 | 1.5 | 8.6 | 0.0 | 11 |
| SE | 30.3 | 9.3 | 0.6 | 2.2 | 0.0 | 42 |
| SI | 0.8 | 1.9 | 1.6 | 28.2 | 0.0 | 33 |
| SK | 0.7 | 0.5 | 0.0 | 11.2 | 0.2 | 13 |
| UK | 1.8 | 6.2 | 0.3 | 172.6 | 1.2 | 182 |
| EU27 | 200 | 122 | 206 | 1,130 | 20 | 1,678 |

Table G.7 Fuel consumption of 5-20MW_{th} combustion plants (PJ)

| Member State | Biomass (PJ) | Other solid fuel (PJ) | Liquid fuel (PJ) | Natural gas (PJ) | Other gaseous fuel (PJ) | Total |
|--------------|--------------|-----------------------|------------------|------------------|-------------------------|--------------|
| AT | 26.9 | 0.0 | 0.0 | 49.9 | 0.0 | 77 |
| BE | 1.2 | 0.0 | 18.4 | 77.1 | 0.0 | 97 |
| BG | 4.8 | 0.1 | 13.5 | 36.1 | 0.0 | 54 |
| CY | 0.0 | 0.0 | 0.6 | 0.0 | 0.1 | 1 |
| CZ | 1.8 | 1.1 | 0.4 | 214.0 | 0.0 | 217 |
| DE | 88.0 | 21.0 | 41.0 | 167.0 | 9.0 | 326 |
| DK | 11.0 | 0.0 | 50.3 | 140.8 | 0.0 | 202 |
| EE | 2.5 | 0.1 | 1.4 | 4.5 | 0.1 | 9 |
| EL | 0.5 | 0.0 | 2.1 | 5.9 | 0.0 | 9 |
| ES | 6.2 | 0.0 | 32.1 | 151.0 | 0.0 | 189 |
| FI | 4.4 | 1.5 | 5.5 | 4.0 | 0.6 | 16 |
| FR | 67.6 | 9.0 | 94.7 | 252.4 | 18.0 | 442 |
| HU | 3.2 | 0.0 | 6.4 | 54.5 | 0.0 | 64 |
| IE | 5.1 | 0.0 | 23.2 | 18.6 | 0.0 | 47 |
| IT | 0.0 | 0.0 | 40.8 | 163.4 | 0.0 | 204 |
| LT | 1.6 | 0.0 | 9.8 | 18.4 | 0.0 | 30 |
| LU | 0.0 | 0.0 | 0.0 | 4.5 | 0.0 | 4 |
| LV | 11.9 | 0.0 | 2.7 | 13.6 | 0.0 | 28 |
| MT | 0.0 | 0.0 | 0.6 | 0.0 | 0.1 | 1 |
| NL | 0.0 | 0.0 | 0.0 | 160.0 | 0.0 | 160 |
| PL | 0.7 | 143.0 | 0.7 | 34.3 | 1.0 | 180 |
| PT | 7.3 | 0.0 | 6.7 | 11.3 | 0.0 | 25 |
| RO | 1.6 | 0.0 | 4.2 | 24.5 | 0.0 | 30 |
| SE | 28.9 | 8.9 | 0.5 | 2.1 | 0.0 | 40 |
| SI | 0.5 | 1.2 | 1.0 | 17.2 | 0.0 | 20 |
| SK | 1.7 | 1.0 | 0.0 | 14.9 | 0.0 | 18 |
| UK | 3.3 | 11.4 | 0.6 | 318.7 | 2.3 | 336 |
| EU27 | 280 | 198 | 358 | 1,959 | 31 | 2,826 |

Table G.8 Fuel consumption of 20-50MW_{th} combustion plants (PJ)

| Member State | Biomass (PJ) | Other solid fuel (PJ) | Liquid fuel (PJ) | Natural gas (PJ) | Other gaseous fuel (PJ) | Total |
|--------------|--------------|-----------------------|------------------|------------------|-------------------------|--------------|
| AT | 9.9 | 0.0 | 0.0 | 18.3 | 0.0 | 28 |
| BE | 0.5 | 0.0 | 6.9 | 28.7 | 0.0 | 36 |
| BG | 1.2 | 0.0 | 3.3 | 8.8 | 0.0 | 13 |
| CY | 0.0 | 0.0 | 1.2 | 0.0 | 0.0 | 1 |
| CZ | 2.9 | 6.0 | 2.0 | 18.7 | 0.0 | 30 |
| DE | 10.0 | 13.0 | 6.0 | 117.0 | 5.0 | 151 |
| DK | 4.7 | 0.0 | 21.4 | 60.0 | 0.0 | 86 |
| EE | 2.8 | 0.3 | 0.7 | 2.1 | 4.2 | 10 |
| EL | 0.2 | 0.0 | 0.9 | 2.5 | 0.0 | 4 |
| ES | 3.4 | 0.0 | 17.5 | 82.5 | 0.0 | 103 |
| FI | 9.0 | 8.0 | 10.2 | 8.9 | 1.1 | 37 |
| FR | 55.9 | 7.4 | 78.2 | 208.6 | 14.9 | 365 |
| HU | 1.5 | 0.0 | 2.9 | 24.7 | 0.0 | 29 |
| IE | 2.2 | 0.0 | 9.9 | 8.0 | 0.0 | 20 |
| IT | 0.0 | 0.0 | 18.6 | 74.4 | 0.0 | 93 |
| LT | 0.7 | 0.0 | 4.2 | 7.8 | 0.0 | 13 |
| LU | 0.0 | 0.0 | 0.0 | 1.5 | 0.0 | 1 |
| LV | 5.2 | 0.0 | 1.2 | 6.0 | 0.0 | 12 |
| MT | 0.0 | 0.0 | 1.2 | 0.0 | 0.0 | 1 |
| NL | 0.0 | 0.0 | 0.0 | 40.0 | 0.0 | 40 |
| PL | 0.2 | 44.0 | 0.2 | 10.5 | 0.3 | 55 |
| PT | 4.4 | 0.0 | 4.0 | 6.7 | 0.0 | 15 |
| RO | 1.2 | 0.0 | 3.3 | 19.0 | 0.0 | 23 |
| SE | 28.0 | 17.7 | 4.0 | 9.6 | 0.0 | 59 |
| SI | 0.1 | 0.2 | 0.2 | 3.3 | 0.0 | 4 |
| SK | 3.1 | 1.9 | 0.0 | 7.5 | 0.0 | 13 |
| UK | 1.2 | 4.2 | 0.2 | 116.6 | 0.8 | 123 |
| EU27 | 148 | 103 | 198 | 892 | 26 | 1,367 |

Table G.9 Emissions (kt) of combustion plants

| Member State | SO2 emissions (kt) | | | NOX emissions (kt) | | | Dust emissions (kt) | | |
|--------------|--------------------|------------|-----------|--------------------|------------|------------|---------------------|-----------|-----------|
| | 1-5 MW | 5-20 MW | 20-50 MW | 1-5 MW | 5-20 MW | 20-50 MW | 1-5 MW | 5-20 MW | 20-50 MW |
| AT | 0.0 | 0.0 | 0.0 | 3.0 | 3.7 | 1.4 | 0.3 | 0.4 | 0.2 |
| BE | 5.1 | 6.6 | 3.6 | 15.3 | 19.9 | 10.9 | 1.4 | 1.9 | 1.0 |
| BG | 3.5 | 6.5 | 1.6 | 3.9 | 7.1 | 1.5 | 0.5 | 1.0 | 0.2 |
| CY | 0.6 | 0.4 | 0.5 | 0.1 | 0.1 | 2.0 | 0.6 | 0.3 | 0.0 |
| CZ | 1.8 | 1.2 | 4.1 | 1.9 | 2.0 | 2.2 | 0.3 | 0.3 | 0.2 |
| DE | 10.9 | 12.9 | 6.0 | 23.1 | 27.2 | 12.6 | 1.4 | 1.6 | 0.8 |
| DK | 12.9 | 23.8 | 4.5 | 13.9 | 25.6 | 8.8 | 1.6 | 3.0 | 1.2 |
| EE | 4.4 | 0.6 | 4.0 | 0.6 | 0.8 | 0.5 | 1.1 | 1.0 | 1.4 |
| EL | 0.5 | 1.0 | 0.2 | 0.6 | 1.1 | 0.4 | 0.1 | 0.1 | 0.1 |
| ES | 8.2 | 15.2 | 1.5 | 11.6 | 21.4 | 4.1 | 1.0 | 1.9 | 0.4 |
| FI | 0.6 | 1.8 | 3.7 | 1.7 | 1.9 | 4.4 | 0.2 | 0.3 | 0.3 |
| FR | 8.8 | 9.7 | 8.0 | 17.2 | 19.1 | 10.3 | 1.8 | 2.0 | 2.5 |
| HU | 1.6 | 3.0 | 2.1 | 3.4 | 6.3 | 2.7 | 0.2 | 0.3 | 0.3 |
| IE | 6.0 | 11.0 | 2.1 | 4.3 | 7.9 | 2.2 | 0.8 | 1.4 | 0.6 |
| IT | 10.5 | 19.4 | 3.7 | 12.5 | 23.1 | 9.1 | 0.9 | 1.7 | 0.7 |
| LT | 2.5 | 4.6 | 0.9 | 2.2 | 4.1 | 1.3 | 0.3 | 0.5 | 0.2 |
| LU | 0.0 | 0.0 | 0.0 | 0.2 | 0.4 | 0.1 | 0.0 | 0.0 | 0.0 |
| LV | 0.7 | 1.3 | 0.5 | 2.3 | 4.3 | 1.5 | 0.6 | 1.1 | 0.5 |
| MT | 0.6 | 0.4 | 0.5 | 0.1 | 0.1 | 2.0 | 0.6 | 0.3 | 0.0 |
| NL | 0.9 | 0.0 | 0.0 | 8.6 | 11.7 | 1.6 | 0.2 | 0.0 | 0.0 |
| PL | 71.8 | 132.6 | 5.6 | 20.4 | 37.7 | 11.9 | 7.2 | 8.0 | 3.8 |
| PT | 1.7 | 3.2 | 0.6 | 2.2 | 4.0 | 2.1 | 0.5 | 0.9 | 0.4 |
| RO | 0.7 | 2.0 | 1.6 | 1.2 | 3.4 | 2.3 | 0.1 | 0.3 | 0.2 |
| SE | 8.9 | 8.5 | 18.3 | 9.1 | 2.9 | 3.8 | 3.4 | 2.9 | 3.5 |
| SI | 0.1 | 0.2 | 0.1 | 2.3 | 0.2 | 0.5 | 0.1 | 0.1 | 0.0 |
| SK | 0.1 | 0.3 | 0.2 | 0.7 | 1.2 | 0.8 | 0.3 | 0.2 | 0.1 |
| UK | 5.9 | 10.9 | 4.0 | 16.8 | 31.0 | 9.0 | 0.7 | 0.9 | 0.6 |
| EU27 | 170 | 277 | 78 | 179 | 268 | 110 | 26 | 32 | 19 |